

DEHOSTOS

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-5169	4-21-16		Initial	5.08	4-23-16	
002	16-5170	4-21-16		Flushed	LT 1.00	4-24-16	
003	16-5171	4-21-16		Initial	3.95	4-24-16	
005	16-5173	4-21-16		Initial	1.84	5-28-16	
006	16-5174	4-21-16		Flushed	LT 1.00	5-26-16	
007	16-5175	4-21-16		Initial	1.14	5-28-16	
008	16-5176	4-21-16		Flushed	LT 1.00	5-28-16	
009	16-5177	4-21-16		Initial	LT 1.00	4-24-16	
011	16-5179	4-21-16		Initial	1.31	5-28-16	
012	16-5180	4-21-16		Flushed	LT 1.00	5-26-16	
013	16-5181	4-21-16		Initial	1.56	4-24-16	
015	16-5183	4-21-16		Initial	LT 1.00	4-24-16	
017	16-5185	4-21-16		Initial	LT 1.00	4-24-16	
018	16-5186	4-21-16		Initial	4.33	5-28-16	
019	16-5187	4-21-16		Flushed	LT 1.00	5-26-16	
020	16-5188	4-21-16		Initial	2.47	5-28-16	
021	16-5189	4-21-16		Flushed	LT 1.00	5-26-16	
022	16-5190	4-21-16		Initial	LT 1.00	5-28-16	
024	16-5192	4-21-16		Initial	LT 1.00	5-28-16	
026	16-5194	4-21-16		Initial	7.95	4-24-16	
028	16-5196	4-21-16		Initial	2.20	4-24-16	
030	16-5198	4-21-16		Initial	10.9	5-28-16	
032	16-5200	4-21-16		Initial	2.51	5-28-16	
034	16-5202	4-21-16		Initial	9.18	5-28-16	
035	16-5203	4-21-16		Flushed	1.96	5-28-16	
036	16-5204	4-21-16	<b>Faucet Rm 104</b>	<b>Initial</b>	<b>31.6</b>	<b>5-28-16</b>	<b>Replaced &amp; POSTED</b>
037	16-5205	4-21-16	"	Flushed	LT 1.00	5-30-16	
038	16-5206	4-21-16		Initial	LT 1.00	5-28-16	
039	16-5207	4-21-16		Initial	5.24	5-28-16	
041	16-5209	4-21-16		Initial	1.62	4-24-16	
043	16-5211	4-21-16		Initial	3.40	4-24-16	
045	16-5213	4-21-16		Initial	2.57	4-24-16	
047	16-5215	4-21-16		Initial	4.33	5-28-16	
049	16-5217	4-21-16		Initial	4.11	5-28-16	
051	16-5219	4-21-16		Initial	LT 1.00	4-24-16	
052	16-5220	4-21-16	<b>Faucet Rm 202</b>	<b>Initial</b>	<b>36.5</b>	<b>5-28-16</b>	<b>Replaced &amp; POSTED</b>

DEHOSTOS

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
053	16-5221	4-21-16	"	Flushed	LT 1.00	5-30-16	
054	16-5222	4-21-16		Flushed	LT 1.00	4-24-16	
055	16-5223	4-21-16		Initial	3.41	4-24-16	
056	16-5224	4-21-16		Initial	7.40	4-24-16	
058	16-5226	4-21-16		Initial	2.15	5-28-16	
DEH-01	16-11868	9-24-16		Initial	LT 1.00	9-30-16	
03	16-11870	9-24-16		Initial	LT 1.00	9-30-16	
05	16-11872	9-24-16		Initial	LT 1.00	9-30-16	
07	16-11874	9-24-16		Initial	LT 1.00	9-30-16	
09	16-11876	9-24-16		Initial	LT 1.00	9-30-16	
11	16-11878	9-24-16		Initial	LT 1.00	9-30-16	
13	16-11881	9-24-16		Initial	2.33	9-30-16	
15	16-11883	9-24-16		Initial	LT 1.00	9-30-16	
17	16-11885	9-24-16		Initial	LT 1.00	9-30-16	
19	16-11887	9-24-16		Initial	LT 1.00	9-30-16	
21	16-11889	9-24-16		Initial	1.59	9-30-16	
23	16-11891	9-24-16		Initial	1.07	9-30-16	
25	16-11893	9-24-16		Initial	LT 1.00	9-30-16	
27	16-11895	9-24-16		Initial	LT 1.00	9-30-16	
29	16-11897	9-24-16		Initial	LT 1.00	9-30-16	
31	16-11899	9-24-16		Initial	4.07	9-30-16	
33	16-11901	9-24-16		Initial	LT 1.00	9-30-16	
35	16-11903	9-24-16		Initial	6.48	9-30-16	
37	16-11905	9-24-16		Initial	LT 1.00	9-30-16	
39	16-11907	9-24-16		Initial	LT 1.00	1-23-17	
41	16-11909	9-24-16		Initial	LT 1.00	9-30-16	
43	16-11911	9-24-16		Initial	LT 1.00	9-30-16	
45	16-11913	9-24-16		Initial	1.06	9-30-16	
47	16-11915	9-24-16		Initial	LT 1.00	9-30-16	
49	16-11917	9-24-16		Initial	LT 1.00	9-30-16	
51	16-11919	9-24-16		Initial	1.55	9-30-16	
53	16-11921	9-24-16		Initial	LT 1.00	9-30-16	
55	16-11923	9-24-16	Hose Bib near Gym	Initial	113	9-30-16	SHUT OFF
56	16-11924	9-24-16	"	Flushed	3.11	10-1-16	

**DEHOSTOS**

**City of Yonkers, Bureau of Water's Laboratory**

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
57	16-11925	9-24-16	Hose Bib near Nurse	Initial	37.9	9-30-16	SHUT OFF
58	16-11926	9-24-16	"	Flushed	3.67	10-1-16	
59	16-11927	9-24-16	Hose Bib near Playground	Initial	28.9	9-30-16	SHUT OFF
60	16-11928	9-24-16	"	Flushed	8.95	10-1-16	

OUTLETS SAMPLED	61
OUTLETS ACTIONABLE	5
OUTLETS PENDING	0
POST 9-6-16	30