

# SCHOOL 5

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-6778	5-14-16		Initial	1.43	5-17-16	
003	16-6780	5-14-16		Initial	LT 1.00	5-17-16	
005	16-6782	5-14-16	<b>Faucet Room 116</b>	<b>Initial</b>	<b>19.1</b>	<b>5-23-16</b>	<b>SHUT OFF</b>
007	16-6784	5-14-16		Initial	2.43	5-17-16	
009	16-6786	5-14-16		Initial	2.65	5-17-16	
011	16-6788	5-14-16		Initial	4.27	5-17-16	
013	16-6790	5-14-16	<b>Faucet Room 212</b>	<b>Initial</b>	<b>28.4</b>	<b>5-23-16</b>	<b>SHUT OFF</b>
014	16-6791	5-14-16	"	Flushed	2.75	5-23-16	
015	16-6792	5-14-16		Initial	1.44	5-17-16	
017	16-6794	5-14-16		Initial	11.0	5-17-16	
019	16-6796	5-14-16		Initial	5.18	5-17-16	
021	16-6798	5-14-16		Initial	4.33	5-17-16	
023	16-6800	5-14-16		Initial	2.84	5-17-16	
025	16-6802	5-14-16	<b>Faucet Room 102</b>	<b>Initial</b>	<b>84.0</b>	<b>5-17-16</b>	<b>SHUT OFF</b>
026	16-6803	5-14-16	"	Flushed	2.16	5-17-16	
027	16-6804	5-14-16	<b>Faucet Rm. 103</b>	<b>Initial</b>	<b>35.2</b>	<b>5-23-16</b>	<b>SHUT OFF</b>
028	16-6805	5-14-16	"	Flushed	LT 1.00	5-24-16	
029	16-6806	5-14-16		Initial	13.0	5-23-16	
031	16-6808	5-14-16		Initial	LT 1.00	5-17-16	
032	16-6809	5-14-16		Initial	8.98	5-23-16	
034	16-6811	5-14-16		Initial	2.52	5-17-16	
036	16-6813	5-14-16		Initial	6.59	5-17-16	
038	16-6815	5-14-16	<b>Faucet Room 9</b>	<b>Initial</b>	<b>70.7</b>	<b>5-17-16</b>	<b>SHUT OFF</b>
039	16-6816	5-14-16	"	Flushed	LT 1.00	5-18-16	
040	16-6817	5-14-16		Initial	11.1	5-17-16	
041	16-6818	5-14-16		Flushed	LT 1.00	5-18-16	
042	16-6819	5-14-16		Initial	2.70	5-17-16	
044	16-6821	5-14-16		Initial	1.58	5-17-16	
046	16-6823	5-14-16		Initial	1.30	5-17-16	
048	16-6825	5-14-16		Initial	7.85	5-17-16	
5-1	16-12424	9-28-16		Initial	2.13	10-7-16	
2	16-12425	9-28-16		Initial	4.70	10-7-16	
3	16-12426	9-28-16		Initial	6.07	10-7-16	
4	16-12427	9-28-16	<b>3rd Floor Slop Sink</b>	<b>Initial</b>	<b>98.7</b>	<b>10-7-16</b>	<b>POSTED</b>
5	16-12428	9-28-16		Initial	1.73	10-7-16	
6	16-12429	9-28-16	<b>2nd Floor Slop Sink</b>	<b>Initial</b>	<b>25.6</b>	<b>3-1-17</b>	<b>POSTED</b>
7A	16-12430	9-28-16		Initial	4.48	10-7-16	

# SCHOOL 5

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
8	16-12431	9-28-16		Initial	3.92	10-7-16	
9	16-12432	9-28-16		Initial	12.2	3-1-17	
10	16-12433	9-28-16		Initial	3.90	10-7-16	
11	16-12434	9-28-16		Initial	5.29	10-7-16	
12	16-12435	9-28-16		Initial	3.40	10-7-16	
13	16-12436	9-28-16		Initial	2.08	10-7-16	
14B	16-12437	9-28-16		Initial	1.12	10-7-16	
15B	16-12438	9-28-16		Initial	2.06	10-7-16	
16	16-12439	9-28-16		Initial	6.01	10-7-16	
17	16-12440	9-28-16		Initial	7.66	10-7-16	
18A	16-12441	9-28-16		Initial	3.92	10-7-16	
19B	16-12442	9-28-16		Initial	14.8	10-7-16	
20	16-12443	9-28-16		Initial	6.08	10-7-16	
21B	16-12444	9-28-16		Initial	1.43	10-7-16	
22	16-12445	9-28-16		Initial	3.60	10-7-16	
23	16-12446	9-28-16	<b>Basement Shop</b>	<b>Initial</b>	<b>15.0</b>	<b>10-7-16</b>	<b>POSTED</b>
24	16-12447	9-28-16		Initial	1.46	10-7-16	
25	16-12448	9-28-16		Initial	2.07	10-7-16	
26	16-12449	9-28-16	<b>Boy's Gym Bathroom: "Not in use"</b>	<b>Initial</b>	<b>796</b>	<b>10-7-16</b>	<b>SHUT OFF</b>
27	16-12450	9-28-16		Initial	LT 1.00	10-7-16	
28A	16-12451	9-28-16	<b>Kitchen Faucet A</b>	<b>Initial</b>	<b>15.5</b>	<b>10-7-16</b>	<b>POSTED</b>
29B	16-12452	9-28-16		Initial	1.12	10-7-16	
30C	16-12453	9-28-16		Initial	2.28	10-7-16	
31	16-12454	9-28-16		Initial	4.65	10-7-16	
32	16-12455	9-28-16		Initial	3.60	10-7-16	
33	16-12456	9-28-16		Initial	3.18	10-7-16	
34	16-12457	9-28-16		Initial	7.10	10-7-16	
35	16-12458	9-28-16		Initial	11.6	10-7-16	
36B	16-12459	9-28-16		Initial	4.71	10-7-16	
37A	16-12460	9-28-16		Initial	4.51	10-7-16	
38	16-12461	9-28-16		Initial	1.73	10-7-16	
39	16-12462	9-28-16		Initial	5.04	10-7-16	
40	16-12463	9-28-16		Initial	6.85	10-7-16	

# SCHOOL 5

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
---------	----------	--------------------	--------------------	-------------------	-------------------------	------------------	--------------

OUTLETS SAMPLED	65
OUTLETS ACTIONABLE	10
OUTLETS PENDING	0
POST 9-6-16	40