

SCHOOL 9

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
03	16-4527	4-13-16		Initial	4.78	4-19-16	
05	16-4529	4-13-16		Initial	LT 1.00	4-19-16	
07	16-4531	4-13-16		Initial	LT 1.00	4-19-16	
08	7069402002	10-27-18	Faucet Rm 7	Initial	2.5	10-31-18	RETURNED TO USE
10	7069402001		Faucet Rm 6	Initial	1.3	10-31-18	RETURNED TO USE
12	16-4536	4-13-15		Initial	2.12	4-19-16	
14	7076417001	01-11-19	Chiller Hallway by Rm 2	Initial	2.6	01-14-19	RETURNED TO USE
15	7076417001	01-11-19	Chiller Hallway by Rm 11	Initial	1.7	01-14-19	RETURNED TO USE
9-1	16-13519	10-6-16		Initial	1.95	11-30-16	
2B	16-13520	10-6-16		Initial	LT 1.00	11-30-16	
3A	16-13521	10-6-16		Initial	LT 1.00	11-30-16	
4B	16-13522	10-6-16		Initial	2.28	11-30-16	
5	16-13523	10-6-16		Initial	1.27	12-1-16	
6	16-13524	10-6-16		Initial	1.90	12-1-16	
7	16-13525	10-6-16		Initial	LT 1.00	12-1-16	
8	16-13526	10-6-16		Initial	2.29	12-1-16	
9	16-13527	10-6-16		Initial	1.30	12-1-16	
10	7069402003	10-27-18	Staff Basement Bathroom	Initial	6.3	10-31-18	RETURNED TO USE
11A	16-13529	10-6-16		Initial	1.36	12-1-16	
12B	16-13530	10-6-16		Initial	1.05	12-1-16	
13B	16-13531	10-6-16		Initial	LT 1.00	12-1-16	
14	16-13532	10-6-16		Initial	4.50	12-1-16	
15	16-13533	10-6-16		Initial	LT 1.00	12-1-16	
16	16-13534	10-6-16		Initial	LT 1.00	12-1-16	
17	7069402004	10-27-18	Main Office Faucet	Initial	1	10-31-18	RETURNED TO USE

OUTLETS TESTED	25
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY*	1
REMEDATION/REPLACEMENT PENDING	0

* Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"

01	16-4525	4-13-16	BUILDING SERVICE SPIGOT	Initial	12.6	6-1-16	LOCKED/POSTED
----	---------	---------	-------------------------	---------	------	--------	---------------

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

As per regulations, in order to pass lead testing, potable water fixtures must have levels below 15 micrograms per liter (ug/L) or 15 parts per billion (ppb) of lead. Below is a list of the various terms used in the report for Action Taken, depending on latest test results.

Definitions of Terms used under "Action Taken" Column:

RETURNED TO USE	new fixture test passes for safe use
LOCKED	a locked fixture or in a locked room
POSTED	sign posted "Do Not Drink"
OFF	fixture is shut off/disabled
PENDING REPL.	fixure is waiting for replacement
PENDING TEST	fixture is waiting for testing
PENDING REMEDIATION	fixture requires further investigation for remediation of lead
ELIMINATED	fixure has been removed