

SCHOOL 13

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
003	18-4861	5-11-18	101 Sink 1	Initial	7.25	5-18-18	RETURNED TO USE
005	18-4862	5-11-18	101 Sink 2	Initial	10.6	5-18-18	RETURNED TO USE
006	16-4583	4-14-16	"	Flushed	3.51	6-2-16	
007	16-4584	4-14-16	101 Fountain	Initial	8.36	4-19-16	
009	16-4586	4-14-16	102 Sink	Initial	1.45	4-19-16	
011	16-4588	4-14-16	103 Sink	Initial	6.95	4-19-16	
013	16-4590	4-14-16	Fountain near 103	Initial	3.84	4-19-16	
015	16-4592	4-14-16	Kitchen Sink (SS) Left	Initial	2.58	4-19-16	
017	16-4594	4-14-16	Kitchen Sink (Porc) Right	Initial	1.85	4-19-16	
019	18-5429	5-25-18	Nurses Office Sink	Initial	318	6-13-18	OFF/PENDING REMEDIATION
021	16-4598	4-14-16	Faculty Room Sink	Initial	9.59	4-20-16	
023	16-4600	4-14-16	107 Sink 1	Initial	2.58	4-20-16	
025	16-4602	4-14-16	107 Sink 2	Initial	LT 1.00	4-20-16	
027	16-4604	4-14-16	107 Bubbler	Initial	LT 1.00	4-20-16	
029	16-4606	4-14-16	108 Sink 1	Initial	2.22	4-20-16	
031	16-4608	4-14-16	108 Sink 2	Initial	1.07	4-20-16	
033	16-4610	4-14-16	108 Bubbler	Initial	1.64	6-1-16	
035	16-4612	4-14-16	109 Sink 1	Initial	9.85	6-1-16	
037	16-4614	4-14-16	109 Sink 2	Initial	1.23	4-20-16	
039	16-4616	4-14-16	109 Bubbler (on sink 2)	Initial	1.29	4-20-16	
041	16-4618	4-14-16	111 Sink 1	Initial	1.62	4-20-16	
043	18-4864	5-11-18	111 Sink 2	Initial	5.6	5-14-18	RETURNED TO USE
045	16-4622	4-14-16	111 Bubbler	Initial	3.98	4-20-16	
047	16-4624	4-14-16	Fountain by Faculty	Initial	LT 1.00	4-20-16	
049	16-4626	4-14-16	115 Sink	Initial	4.51	4-20-16	
051	18-4865	5-11-18	112 Sink ***				DUPLICATE/SEE BELOW
053	16-4630	4-14-16	114 Sink	Initial	3.50	4-20-16	
055	16-4632	4-14-16	114 Bubbler	Initial	10.8	4-20-16	
057	16-4634	4-14-16	113 Sink	Initial	2.83	6-1-16	
059	16-4636	4-14-16	113 Bubbler	Initial	1.65	4-20-16	
061	16-4638	4-14-16	112A Sink	Initial	7.89	4-20-16	
063	16-4640	4-14-16	216 Sink	Initial	4.01	4-20-16	
065	16-4642	4-14-16	216 Bubbler	Initial	13.3	4-20-16	
067	16-4644	4-14-16	217 Sink	Initial	4.80	4-20-16	
069	16-4646	4-14-16	217 Bubbler	Initial	7.08	4-20-16	
071	16-4648	4-14-16	215 Sink***			4-20-16	DUPLICATE/SEE BELOW
073	16-4650	4-14-16	218 Sink	Initial	8.04	4-20-16	
075	16-4652	4-14-16	218 Bubbler	Initial	7.64	4-20-16	
077	16-4654	4-14-16	219 Sink	Initial	8.45	4-20-16	
079	16-4656	4-14-16	Fountain by 2nd fl. Bathroom	Initial	1.94	4-20-16	
081	16-4658	4-14-16	214 Sink 1	Initial	5.24	4-20-16	
083	18-4866	5-11-18	214 Sink 2	Initial	8.7	5-18-18	RETURNED TO USE
085	18-4867	5-11-18	214 Bubbler	Initial	6.46	5-14-18	RETURNED TO USE
087	16-4664	4-14-16	213 Sink 1	Initial	1.87	6-1-16	
089	18-4868	5-11-18	213 Sink 2	Initial	3.26	5-18-18	RETURNED TO USE

SCHOOL 13

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
091	16-4668	4-14-16	213 Bubbler	Initial	1.72	4-20-16	
093	16-4670	4-14-16	Chiller hallway by 212	Initial	1.98	4-20-16	
094	19-11653	11-8-19	212 Sink 1	Initial	2.86	11-21-19	RETURNED TO USE
095	16-4672	4-14-16	"	Flushed	LT 1.00	6-2-16	
096	19-11654	11-8-19	212 Sink 2	Initial	3.87	11-21-19	
097	16-4674	4-14-16	212 Sink 2	Flushed	LT 1.00	6-2-16	
098	16-4675	4-14-16	212 Bubbler	Initial	LT 1.00	4-20-16	
100	16-4677	4-14-16	211 Sink 1	Initial	LT 1.00	4-20-16	
102	16-4679	4-14-16	211 Sink 2	Initial	1.15	4-20-16	
104	16-4681	4-14-16	211 Bubbler	Initial	1.51	4-20-16	
106	16-4683	4-14-16	210 Sink 1	Initial	1.89	4-20-16	
108	16-4685	4-14-16	210 Sink 2	Initial	1.81	4-21-16	
110	16-4687	4-14-16	210 Bubbler	Initial	LT 1.00	4-21-16	
112	18-4870	5-11-18	207 Sink ***				DUPLICATE/SEE BELOW
113	16-4690	4-14-16	"	Flushed	3.87	6-2-16	
114	16-4691	4-14-16	206 Sink	Initial	10.3	4-21-16	
116	18-4871	5-11-18	205 Sink	Initial	13.3	5-18-18	RETURNED TO USE
117	16-4694	4-14-16	"	Flushed	5.59	4-22-16	
118	16-4695	4-14-16	204 Sink	Initial	3.26	4-21-16	
120	16-4697	4-14-16	203 Sink ***				DUPLICATE/SEE BELOW
121	16-4698	4-14-16	"	Flushed	11.3	6-2-16	
122	16-4699	4-14-16	201 Sink 1	Initial	3.85	4-21-16	
124	16-4701	4-14-16	201 Sink 2	Initial	2.03	4-21-16	
126	16-4703	4-14-16	201 Bubbler	Initial	2.81	6-1-16	
128	16-4705	4-14-16	202 Sink 1	Initial	2.78	4-21-16	
130	16-4707	4-14-16	202 Sink 2	Initial	8.48	6-1-16	
132	16-4709	4-14-16	202 Bubbler	Initial	2.40	4-21-16	
134	16-4711	4-14-16	310 Sink ***				DUPLICATE/SEE BELOW
135	16-4712	4-14-16	"	Flushed	1.95	4-22-16	
136	16-4713	4-14-16	302 Sink	Initial	5.54	4-21-16	
138	16-4715	4-14-16	?? In hallway by 302	Initial	LT 1.00	4-21-16	
140	18-4872	5-11-18	Faucet Rm 305	Initial	6.9	5-18-18	RETURNED TO USE
141	16-4718	4-14-16	"	Flushed	10.2	4-22-16	
13-001A	16-13189	10-1-16	301 Girls bathroom sink A	Initial	5.2	11-11-16	
002B	16-13190	10-1-16	301 Girls bathroom sink B	Initial	8.51	11-11-16	
003	7088638004	5-4-19	310 Sink (replacment fixture)	Initial	5.9	5-12-19	RETURNED TO USE
004	16-13192	10-1-16	304 Slop Sink	Initial	3.15	11-11-16	
005A	16-13193	10-1-16	306 Boys bathroom sink A	Initial	9.38	11-11-16	
006B	16-13194	10-1-16	306 Boys bathroom sink B	Initial	4.49	11-21-16	
007	16-13195	10-1-16	203.1 Slop Sink	Initial	1.18	11-11-16	
008A	16-13196	10-1-16	203.02 Boys Bathroom Sink A	Initial	1.45	11-11-16	
009B	18-4874	5-11-18	203.02 Boys Bathroom Sink B	Initial	2.15	5-18-18	RETURNED TO USE
010C	16-13198	10-1-16	203.02 Boys Bathroom Sink C	Initial	3.09	11-21-16	
011D	16-13199	10-1-16	203.02 Boys Bathroom Sink D	Initial	2.13	11-21-16	
012A	16-13200	10-1-16	202 Sink A	Initial	4.41	11-11-16	

SCHOOL 13

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
013B	18-4875	5-11-18	202 Sink B	Initial	3.12	5-18-18	RETURNED TO USE
014	18-4870	5-11-18	207 Sink (replacement fixture)	Initial	6.41	5-18-18	
015	18-5430	5-25-18	203 Sink (replacement fixture)	Initial	6.93	6-7-18	RETURNED TO USE
016	16-13204	10-1-16	214B bathroom sink	Initial	2.69	11-21-16	
017A	16-13205	10-1-16	208 bathroom sink A	Initial	6.24	11-21-16	
018B	16-13206	10-1-16	208 bathroom sink B	Initial	3.38	11-22-16	
019C	16-13207	10-1-16	208 bathroom sink C	Initial	3.12	11-22-16	
020D	16-13208	10-1-16	208 bathroom sink D	Initial	2.18	11-22-16	
022A	16-13210	10-1-16	(New Wing 2nd Fl.) Boys bath west sink A	Initial	1.66	11-22-16	
022B	16-13211	10-1-16	(New Wing 2nd Fl.) Boys bath west sink B	Initial	2.11	11-22-16	
024	16-13212	10-1-16	2nd floor west slop sink	Initial	3.49	11-22-16	
025A	16-13213	10-1-16	Girls bathroom west sink A	Initial	1.56	11-22-16	
026B	16-13214	10-1-16	Girls bathroom west sink B	Initial	2.30	11-22-16	
026C	16-13215	10-1-16	Girls bathroom west sink C	Initial	3.00	11-22-16	
028	7094258001	6-15-19	215 Sink (replacement fixture)***	Initial	1.5	6-28-19	RETURNED TO USE
029	18-4865	5-11-18	112 Sink replacement fixture	Initial	11.4	5-14-18	RETURNED TO USE
032	16-13219	10-1-16	111 Bubbler	Initial	3.02	11-28-16	
033A	16-13220	10-1-16	111 Sink A	Initial	2.63	11-28-16	
034B	16-13221	10-1-16	111 Sink B (or Sink 2)	Initial	2.42	11-28-16	
035	16-13222	10-1-16	111 bathroom sink	Initial	4.04	11-28-16	
036	19-11652	11-8-19	109 bathroom sink	Initial	9.80	11-21-19	RETURNED TO USE
037	16-13224	10-1-16	219 speech room sink	Initial	6.24	11-28-16	
038	16-13225	10-1-16	108 bathroom sink	Initial	5.32	11-28-16	
039	16-13226	10-1-16	107 bathroom sink	Initial	6.63	11-28-16	
040	16-13227	10-1-16	113.01 Slop Sink	Initial	4.98	11-28-16	
041	16-13228	10-1-16	106A bathroom sink	Initial	4.03	11-28-16	
042	16-13229	10-1-16	Staff bathroom by 119	Initial	8.36	11-28-16	
043	7094258002	6-15-19	121 Nurse's bathroom sink	Initial	1.3	6-28-19	RETURNED TO USE
044	16-13231	10-1-16	Teacher's lounge sink	Initial	9.63	11-28-16	
045C	16-13232	10-1-16	120 girls bathroom sink C	Initial	2.00	11-28-16	
046A	16-13233	10-1-16	122.1 boys bathroom sink A	Initial	1.24	11-28-16	
047C	16-13234	10-1-16	122.1 boys bathroom sink C	Initial	1.12	11-28-16	
048	16-13235	10-1-16	124 Slop Sink	Initial	5.54	11-28-16	
049	16-13236	10-1-16	Boiler Room bathroom sink	Initial	1.49	11-28-16	

OUTLETS TESTED	111
OUTLETS ACTIONABLE	1
REMOVED FROM POTABLE INVENTORY	5
REMEDIATION/REPLACEMENT PENDING	1

* Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"

002	16-4578	4-14-16	BUILDING SERVICE SPIGOT	Initial	84.5	4-19-16	LOCKED/POSTED
-----	---------	---------	-------------------------	---------	------	---------	---------------

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
021	16-13209	10-1-16	209 Slop Sink	Initial	27.1	11-22-16	LOCKED/POSTED
030	16-13289	10-1-16	1st floor west slop sink	Initial	15.4	11-28-16	LOCKED/POSTED
031	16-13218	10-1-16	1st floor west slop sink	Initial	23.8	11-28-16	LOCKED/POSTED
050	16-13237	10-1-16	Slop sink Rm 24 Basement	Initial	42.8	3-7-17	LOCKED/POSTED

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

As per regulations, in order to pass lead testing, potable water fixtures must have levels below 15 micrograms per liter (ug/L) or 15 parts per billion (ppb) of lead. Below is a list of the various terms used in the report for Action Taken, depending on latest test results.

Definitions of Terms used under "Action Taken" Column:

RETURNED TO USE	new fixture test passes for safe use
LOCKED	a locked fixture or in a locked room
POSTED	sign posted "Do Not Drink"
OFF	fixture is shut off/disabled
PENDING REPL.	fixure is waiting for replacement
PENDING TEST	fixture is waiting for testing
PENDING REMEDIATION	fixture requires further investigation for remediation of lead
ELIMINATED	fixure has been removed