

Scholastic 18

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
03	16-5582	4-27-16		Initial	2.13	5-2-16	
05	7071628001	11-17-18	Nurse's drinking fountain	Initial	10.7	11-27-18	RETURNED TO USE
06	16-5585	4-27-16		Initial	LT 1.00	5-2-16	
08	16-5587	4-27-16		Initial	1.78	5-2-16	
10	16-5589	4-27-16		Initial	LT 1.00	5-2-16	
12	16-5591	4-27-16		Initial	6.18	5-2-16	
18-01	16-12090	9-24-16		Initial	LT 1.00	10-3-16	
03A	16-12092	9-24-16		Initial	3.40	10-3-16	
05B	16-12094	9-24-16		Initial	LT 1.00	10-3-16	
07C	16-12096	9-24-16		Initial	LT 1.00	10-3-16	
09	16-12098	9-24-16		Initial	2.71	10-3-16	
11A	16-12100	9-24-16		Initial	2.38	10-3-16	
13B	16-12102	9-24-16		Initial	1.65	10-3-16	
15	16-12104	9-24-16		Initial	13.2	10-3-16	
17A	16-12106	9-24-16		Initial	1.27	10-3-16	
19B	16-12108	9-24-16		Initial	4.88	10-3-16	
21	16-12110	9-24-16		Initial	1.80	10-3-16	
23	16-12112	9-24-16		Initial	2.33	10-3-16	
25A	7071628002	11-17-18	2nd Fl North side Boy's BR Faucet	Initial	2.3	11-27-18	RETURNED TO USE
27B	16-12116	9-24-16		Initial	2.24	10-3-16	
29	16-12118	9-24-16		Initial	LT 1.00	10-3-16	
31	7090577001	5-18-19	Teachers Lounge Bath Sink	Initial	LT 1.00	5-29-19	RETURNED TO USE
33	16-12122	9-24-16		Initial	1.75	10-3-16	
35	16-12124	9-24-16		Initial	3.43	10-3-16	
37	16-12126	9-24-16		Initial	1.76	10-3-16	
39	16-12128	9-24-16		Initial	1.01	10-3-16	
41	16-12130	9-24-16		Initial	9.40	10-3-16	
43	16-12132	9-24-16		Initial	1.22	10-4-16	
45A	16-12134	9-24-16		Initial	LT 1.00	10-4-16	
47B	16-12136	9-24-16		Initial	LT 1.00	10-4-16	
49	16-12138	9-24-16		Initial	1.10	10-4-16	
51	16-12140	9-24-16		Initial	2.99	10-4-16	

Scholastic 18

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
53	16-12142	9-24-16		Initial	LT 1.00	10-4-16	
55A	16-12144	9-24-16		Initial	LT 1.00	10-4-16	
57B	16-12146	9-24-16		Initial	LT 1.00	10-4-16	
59	16-12148	9-24-16		Initial	LT 1.00	10-4-16	
61	16-12150	9-24-16		Initial	LT 1.00	10-4-16	
63A	16-12152	9-24-16		Initial	LT 1.00	10-4-16	
65B	16-12154	9-24-16		Initial	LT 1.00	10-4-16	
67	16-12156	9-24-16		Initial	4.38	10-4-16	
69A	16-12158	9-24-16		Initial	LT 1.00	10-4-16	
71B	16-12160	9-24-16		Initial	LT 1.00	10-4-16	
73	16-12162	9-24-16		Initial	3.87	10-4-16	
74	16-12163	9-24-16		Initial	1.79	10-4-16	
76	16-12165	9-24-16		Initial	2.77	10-4-16	
78A	16-12167	9-24-16		Initial	2.39	10-4-16	
80B	7071628003	11-17-18	Girl's Gym Bathroom Sink B	Initial	1.7	11-27-18	RETURNED TO USE
82C	16-12171	9-24-16		Initial	LT 1.00	10-4-16	
84A	16-12173	9-24-16		Initial	1.99	10-4-16	
86B	16-12175	9-24-16		Initial	3.28	10-4-16	

OUTLETS TESTED	50
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY	2
REMEDIATION/REPLACEMENT PENDING	0

*** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

01	16-5580	4-27-16	BUILDING SERVICE SPIGOT	Initial	387.0	5-26-16	LOCKED/POSTED
88	16-12177	9-24-16	Boy's Gym Bathroom Slop Sink	Initial	490	10-4-16	LOCKED/POSTED