

**SCHOOL 23**

**Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action**

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
001	16-6827	5-14-16		Initial	3.00	5-18-16	
003	16-6829	5-14-16		Initial	3.71	5-18-16	
005	16-6831	5-14-16		Initial	6.50	5-18-16	
007	16-6833	5-14-16		Initial	6.77	5-18-16	
009	16-6835	5-14-16		Initial	3.83	5-18-16	
011	16-6837	5-14-16		Initial	3.44	5-18-16	
013	7071631001	11-17-18	Faucet Room # 13	Initial	8.1	11-27-18	RETURNED TO USE
015	7076422003	1-11-19	Bubbler Room 13	Initial	4.7	1-14-19	RETURNED TO USE
016	16-6842	5-14-16	"	Flushed	6.86	5-18-16	
017	16-6843	5-14-16		Initial	4.44	5-18-16	
019	16-6845	5-14-16		Initial	2.52	5-18-16	
021	7071631002	11-17-18	Library Faucet	Initial	7.7	11-27-18	RETURNED TO USE
022	16-6848	5-14-16		Flushed	1.12	5-18-16	
023	16-6849	5-14-16		Initial	1.01	5-18-16	
024	16-6850	5-14-16		Initial	1.69	5-18-16	
026	16-6852	5-14-16		Initial	1.49	5-18-16	
028	7071631003	11-17-18	Kitchen Faucet #1	Initial	1.5	11-27-18	RETURNED TO USE
029	16-6855	5-14-16	"	Flushed	LT 1.00	5-18-16	
030	16-6856	5-14-16		Initial	1.79	5-18-16	
032	16-6858	5-14-16		Initial	3.56	5-18-16	
23-01	16-12008	9-24-16		Initial	LT 1.00	10-3-16	
03	16-12010	9-24-16		Initial	LT 1.00	10-3-16	
05	16-12012	9-24-16		Initial	5.32	1-23-17	
07	16-12014	9-24-16		Initial	3.79	10-3-16	
09	16-12016	9-24-16		Initial	4.81	10-3-16	
13	12-12020	9-24-16		Initial	LT 1.00	10-3-16	
15	16-12022	9-24-16		Initial	4.41	10-3-16	
17	16-12024	9-24-16		Initial	4.01	10-3-16	
19	7076422002	1-11-19	Faucet Rm 7	Initial	1.6	1-14-19	RETURNED TO USE
21	16-12028	9-24-16		Initial	3.74	10-3-16	
23	7071631005	11-17-18	Rm 9 Faucet (ex'g fixture)	Initial	14.6	11-27-18	RETURNED TO USE
24	16-12031	9-24-16	"	Flushed	1.11	1-25-17	

# SCHOOL 23

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
25	16-12032	9-24-16		Initial	2.24	10-3-16	
27	16-12034	9-24-16		Initial	1.94	10-3-16	
29	16-12036	9-24-16		Initial	3.16	10-3-16	
31	16-12038	9-24-16		Initial	2.91	10-3-16	
33A	16-12040	9-24-16		Initial	3.70	10-3-16	
35B	16-12042	9-24-16		Initial	5.15	10-3-16	
37	16-12044	9-24-16		Initial	1.71	10-3-16	
39A	16-12046	9-24-16		Initial	4.99	10-3-16	
41B	16-12048	9-24-16		Initial	2.65	10-3-16	
43C	16-12050	9-24-16		Initial	3.30	10-3-16	
45A	16-12052	9-24-16		Initial	1.56	10-3-16	
47B	16-12054	9-24-16		Initial	1.29	10-3-16	
49C	16-12056	9-24-16		Initial	1.30	10-3-16	
51D	16-12058	9-24-16		Initial	1.29	10-3-16	
53E	16-12060	9-24-16		Initial	1.06	10-3-16	
55A	16-12062	9-24-16		Initial	2.20	10-3-16	
57B	16-12064	9-24-16		Initial	1.19	10-3-16	
59	16-12066	9-24-16		Initial	7.81	1-23-17	
61	16-12068	9-24-16		Initial	LT 1.00	10-3-16	
63A	16-12070	9-24-16		Initial	4.18	10-3-16	
65B	16-12072	9-24-16		Initial	1.48	10-3-16	
67A	16-12074	9-24-16		Initial	1.67	10-3-16	
69B	16-12076	9-24-16		Initial	1.10	10-3-16	
71C	16-12078	9-24-16		Initial	1.00	10-3-16	
73A	16-12080	9-24-16		Initial	6.19	10-3-16	
75B	16-12082	9-24-16		Initial	3.30	10-3-16	
77	16-12084	9-24-16		Initial	2.93	10-3-16	

**SCHOOL 23**

**Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action**

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
79	7076422001	1-11-19	Room #1 Bathroom Faucet	Initial	4.7	1-14-19	RETURNED TO USE
80	16-12087	9-24-16	"	Flushed	4.06	10-4-16	
81	16-12088	9-24-16		Initial	1.53	10-3-16	

OUTLETS TESTED	57
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY*	1
REMEDIATION/REPLACEMENT PENDING	0

**\* Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

11	16-12018	9-24-16	Front Entrance Slop Sink	Initial	16.9	1-23-17	LOCKED/POSTED
----	----------	---------	--------------------------	---------	------	---------	---------------

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

As per regulations, in order to pass lead testing, potable water fixtures must have levels below 15 micrograms per liter (ug/L) or 15 parts per billion (ppb) of lead. Below is a list of the various terms used in the report for Action Taken, depending on latest test results.

### **Definitions of Terms used under "Action Taken" Column:**

RETURNED TO USE	new fixture test passes for safe use
LOCKED	a locked fixture or in a locked room
POSTED	sign posted "Do Not Drink"
OFF	fixture is shut off/disabled
PENDING REPL.	fixure is waiting for replacement
PENDING TEST	fixture is waiting for testing
PENDING REMEDIATION	fixture requires further investigation for remediation of lead
ELIMINATED	fixure has been removed