

Montessori 27

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
001	16-6568	5-12-16		Initial	1.51	5-16-16	
003	16-6570	5-12-16		Initial	10.9	5-16-16	
005	16-6572	5-12-16		Initial	6.79	5-16-16	
007	16-6574	5-12-16		Initial	2.46	5-16-16	
009	16-6576	5-12-16		Initial	4.22	5-16-16	
013	7086816001	4-4-19	Rm 204 Fac. Lounge Sink	Initial	4.0	4/29/19	RETURNED TO USE
015	16-6582	5-12-16		Initial	LT 1.00	5-16-16	
016	7072981001	12-1-18	Faucet Rm 213	Initial	6.4	12-10-18	RETURNED TO USE
017	16-6584	5-12-16		Flushed	1.78	5-17-16	
018	16-6585	5-12-16		Initial	3.16	5-16-16	
020	16-6587	5-12-16		Initial	14.2	5-16-16	
021	16-6588	5-12-16		Flushed	13.7	5-17-16	
022	16-6589	5-12-16		Initial	2.45	5-16-16	
024	16-6591	5-12-16		Initial	14.4	5-16-16	
025	16-6592	5-12-16		Flushed	7.37	5-17-16	
026	16-6593	5-12-16		Initial	4.49	5-17-16	
027	16-6594	5-12-16		Flushed	2.59	5-16-16	
028	16-6595	5-12-16		Initial	8.76	5-16-16	
030	16-6597	5-12-16		Initial	1.78	5-16-16	
032	16-6599	5-12-16		Initial	2.09	5-16-16	
034	16-6601	5-12-16		Initial	2.75	5-16-16	
036	16-6603	5-12-16		Initial	4.84	5-16-16	
038	16-6605	5-12-16		Initial	4.25	5-16-16	
040	16-6607	5-12-16		Initial	1.70	5-16-16	
042	16-6609	5-12-16		Initial	4.03	5-16-16	
044	16-6611	5-12-16		Initial	2.22	5-16-16	
046	16-6613	5-12-16		Initial	4.69	5-16-16	
048	16-6615	5-12-16		Initial	1.46	5-17-16	
050	16-6617	5-12-16		Initial	2.59	5-17-16	
052	16-6619	5-12-16		Initial	2.92	5-17-16	
054	16-6621	5-12-16		Initial	1.25	5-17-16	
056	16-6623	5-12-16		Initial	2.98	5-17-16	

Montessori 27

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
058	16-6625	5-12-16		Initial	1.20	5-17-16	
060	16-6627	5-12-16		Initial	LT 1.00	5-17-16	
27-1A	16-12754	9-30-16		Initial	5.07	10-17-16	
2B	16-12755	9-30-16		Initial	4.25	10-17-16	
3	16-12756	9-30-16		Initial	1.86	10-17-16	
4	7072981002	12-1-18	Faucet Rm. 233	Initial	10.1	12-10-18	RETURNED TO USE
5	7072981003	12-1-18	Faucet Rm. 235	Initial	51.5	12-10-18	RETURNED TO USE
6	16-12759	9-30-16		Initial	6.77	10-17-16	
7	16-12760	9-30-16		Initial	5.96	10-17-16	
8	16-12761	9-30-16		Initial	2.99	10-17-16	
9	16-12762	9-30-16		Initial	2.42	10-17-16	
10	16-12763	9-30-16		Initial	3.91	10-17-16	
11	7072981004	12-1-18	Faucet Rm. 238	Initial	7.3	12-10-18	RETURNED TO USE
12A	16-12765	9-30-16		Initial	1.42	10-17-16	
13B	16-12766	9-30-16		Initial	3.56	10-17-16	
14	16-12767	9-30-16		Initial	4.36	10-17-16	
15A	16-12768	9-30-16		Initial	1.90	10-17-16	
16B	16-12769	9-30-16		Initial	1.28	10-17-16	
17	16-12770	9-30-16		Initial	3.53	10-17-16	
18	16-12771	9-30-16		Initial	4.80	10-17-16	
19A	16-12772	9-30-16		Initial	3.34	10-18-16	
20B	16-12773	9-30-16		Initial	1.71	10-18-16	
21	16-12774	9-30-16		Initial	2.08	10-18-16	
22A	16-12775	9-30-16		Initial	3.35	10-18-16	
23B	16-12776	9-30-16		Initial	4.40	10-18-16	
24	7094261001	6-15-19	Green House	Initial	12.5	6-28-19	RETURNED TO USE
25	16-12778	9-30-16		Initial	6.09	10-18-16	
26	16-12779	9-30-16		Initial	3.61	10-18-16	
27	16-12780	9-30-16		Initial	3.47	10-18-16	
28	16-12781	9-30-16		Initial	2.81	10-18-16	
29	16-12782	9-30-16		Initial	2.75	10-18-16	
30	16-12783	9-30-16		Initial	1.52	10-18-16	
31	16-12784	9-30-16		Initial	2.18	10-18-16	
32	16-12785	9-30-16		Initial	1.70	10-18-16	
33	7072981006	12-1-18	RM 129 Bathroom Faucet	Initial	7.9	12-10-18	RETURNED TO USE

Montessori 27

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
---------	----------	--------------------	--------------------	-------------------	--	------------------	--------------

OUTLETS TESTED	63
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY	3
REMEDIATION/REPLACEMENT PENDING	0

** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"*

011	16-6578	5-12-16	Main Spigot	Initial	83.0	5-23-16	LOCKED/POSTED
34	16-12787	9-30-16	Spigot West	Initial	16.3	10-18-16	LOCKED/POSTED
35	16-12788	9-30-16	East Spigot	Initial	3000.0	3-1-17	LOCKED/POSTED