

Montessori 31

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
001	16-6208	5-7-16		Initial	9.39	5-11-16	
003	16-6210	5-7-16		Initial	6.17	5-11-16	
005	16-6212	5-7-16		Initial	5.45	5-11-16	
007	16-6214	5-7-16		Initial	4.10	5-12-16	
009	16-6216	5-7-16		Initial	LT 1.00	5-12-16	
010	16-6217	5-7-16		Initial	4.29	5-12-16	
012	16-6219	5-7-16		Initial	5.80	5-12-16	
014	16-6221	5-7-16		Initial	4.25	5-12-16	
016	16-6223	5-7-16		Initial	8.48	5-12-16	
018	16-6225	5-7-16		Initial	2.00	5-12-16	
020	16-6227	5-7-16		Initial	LT 1.00	5-12-16	
022	16-6229	5-7-16		Initial	3.01	5-12-16	
024	16-6231	5-7-16		Initial	1.26	5-12-16	
026	16-6233	5-7-16		Initial	1.98	5-12-16	
028	16-6235	5-7-16		Initial	11.4	5-12-16	
029	16-6236	5-7-16		Flushed	1.86	5-13-16	
030	16-6237	5-7-16		Initial	1.06	5-12-16	
033	16-6240	5-7-16		Flushed	9.37	5-13-16	
034	16-6241	5-7-16		Initial	5.48	5-12-16	
036	16-6243	5-7-16		Initial	1.02	5-12-16	
038	16-6245	5-7-16		Initial	4.21	5-12-16	
040	16-6247	5-7-16		Initial	LT 1.00	5-12-16	
042	16-6249	5-7-16		Initial	3.96	5-12-16	
31-1	16-12564	9-29-16		Initial	5.63	10-10-16	
2	7094252001	6-15-19	Nurse's Bathroom Faucet	Initial	225.0	6-28-19	POSTED /PENDING REMEDIATION
3	16-12566	9-29-16		Initial	5.80	10-10-16	
4	7088639002	5-4-19	Bubbler in Gym	Initial	11.1	5-12-19	RETURNED TO USE
5	16-12568	9-29-16		Initial	14.7	10-10-16	
6	16-12569	9-29-16		Initial	2.63	10-10-16	
7	16-12570	9-29-16		Initial	1.81	10-10-16	
8	16-12571	9-29-16		Initial	2.72	10-10-16	
9	16-12572	9-29-16		Initial	2.74	10-10-16	
10	16-12573	9-29-16		Initial	1.98	10-10-16	
11	16-12574	9-29-16		Initial	1.31	10-11-16	
12	16-12575	9-29-16		Initial	LT 1.00	10-11-16	
13	16-12576	9-29-16		Initial	11.2	10-11-16	
14	16-12577	9-29-16		Initial	6.08	10-11-16	
15	16-12578	9-29-16		Initial	1.98	10-11-16	

Montessori 31

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
16	16-12579	9-29-16		Initial	4.41	10-11-16	
17	16-12580	9-29-16		Initial	6.99	10-11-16	
18	16-12581	9-29-16		Initial	5.35	10-11-16	
20	16-12583	9-29-16		Initial	6.50	10-11-16	
21	16-12584	9-29-16		Initial	14.2	10-11-16	
22	16-12585	9-29-16		Initial	5.67	10-11-16	
23	16-12586	9-29-16		Initial	7.11	10-11-16	
24	16-12587	9-29-16		Initial	1.82	10-11-16	

OUTLETS TESTED	44
OUTLETS ACTIONABLE	1
REMOVED FROM POTABLE INVENTORY	3
REMEDATION/REPLACEMENT PENDING	1

*** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

032	16-6239	5-7-16	Faucet Rm 12 Nurse's Office	Initial	286.0	5-12-16	DUPLICATE RECORD
19	16-12582	9-29-16	Slop Sink Rm 61A	Initial	25.0	10-11-16	POSTED & LOCKED
25	16-12588	9-29-16	Front outside Spigot	Initial	97	3-1-17	POSTED & LOCKED

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

As per regulations, in order to pass lead testing, potable water fixtures must have levels below 15 micrograms per liter (ug/L) or 15 parts per billion (ppb) of lead. Below is a list of the various terms used in the report for Action Taken, depending on latest test results.

Definitions of Terms used under "Action Taken" Column:

RETURNED TO USE	new fixture test passes for safe use
LOCKED	a locked fixture or in a locked room
POSTED	sign posted "Do Not Drink"
OFF	fixture is shut off/disabled
PENDING REPL.	fixure is waiting for replacement
PENDING TEST	fixture is waiting for testing
PENDING REMEDIATION	fixture requires further investigation for remediation of lead
ELIMINATED	fixure has been removed