

# PEARLS HAWTHORNE

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
003	16-3507	4-5-16	Porcelain Fountain Annex by Gym	Initial	2.67	4-8-16	
005	16-3509	4-5-16	Porcelain Fountain Annex by Kitchen	Initial	2.40	4-8-16	
007	16-3511	4-5-16	SS Sink #1 Kitchen	Initial	4.22	6-9-16	
009	16-3513	4-5-16	SS Sink L Kitchen	Initial	2.49	4-8-16	
011	16-3515	4-5-16	SS Sink R Kitchen	Initial	1.75	4-8-16	
013	16-3517	4-5-16	Kitchen Porcelain Hand Sink	Initial	1.41	4-8-16	
015	16-3519	4-5-16	Kitchen SS Sink R2	Initial	4.40	6-9-16	
017	16-3521	4-5-16	Kitchen SS Sink L2	Initial	5.52	4-8-16	
019	16-3523	4-5-16	SS Single Kitchen Sink	Initial	2.50	6-9-16	
021	16-3525	4-5-16	Porcelain Fountain 2nd Fl. Annex Hall	Initial	4.28	4-8-16	
023	16-3527	4-5-16	Main Line, Meter Room, Main Bldg.	Initial	LT 1.00	6-9-16	
024	16-3528	4-5-16	"	Flushed	LT 1.00	6-9-16	
025	16-3529	4-5-16	SS Fountain Chiller Lower Gym	Initial	1.68	4-8-16	
026	16-3530	4-5-16	SS Fountain Hallway by L7	Initial	1.24	4-7-16	
028	16-3532	4-5-16	Porcelain Slop Sink Rm L6	Initial	3.96	4-7-16	
030	16-3534	4-5-16	Porcelain Sink Rm L5	Initial	1.90	4-7-16	
032	16-3536	4-5-16	SS Sink Rm 105	Initial	LT 1.00	4-7-16	
035	16-3538	4-5-16	SS Fountain Hall Rm 105	Initial	4.80	4-7-16	
036	16-3539	4-5-16	"	Flushed	1.02	6-9-16	
037	16-3540	4-5-16	SS Sink Rm 104	Initial	LT 1.00	4-7-16	
039	16-3542	4-5-16	SS Sink Rm 103	Initial	2.34	4-7-16	
041	16-3544	4-5-16	SS Sink Rm 102	Initial	2.15	4-7-16	
043	16-3546	4-5-16	SS Sink Rm 101	Initial	LT 1.00	4-7-16	
045	16-3548	4-5-16	SS Fountain Hallway by Rm 101	Initial	1.92	4-7-16	
047	16-3550	4-5-16	Porcelain Sink Asst. Principal	Initial	4.74	6-9-16	
049	16-3552	4-5-16	SS Fountain Hallway Rm 115	Initial	2.12	4-7-16	
051	16-3554	4-5-16	SS Sink Rm 115	Initial	2.76	4-7-16	
052	16-3555	4-5-16	"	Flushed	LT 1.00	4-7-16	
053	16-3556	4-5-16	SS Sink Rm 114	Initial	LT 1.00	4-7-16	
055	16-3558	4-5-16	SS Sink Rm 113	Initial	LT 1.00	4-7-16	
057	16-3560	4-5-16	SS Fountain Hallway by Rm 113	Initial	3.70	4-7-16	
059	16-3562	4-5-16	SS Sink Rm 112	Initial	LT 1.00	4-8-16	
061	16-3564	4-5-16	SS Sink Hallway by Rm 213	Initial	2.99	4-8-16	
063	16-3566	4-5-16	SS Fountain Hallway by Rm 216	Initial	2.92	4-8-16	
065	16-3568	4-5-16	SS Fountain Rm 205	Initial	5.91	4-8-16	
067	13-3570	4-5-16	SS Fountain Hallway by Rm 302	Initial	7.92	4-8-16	
HAW-01	16-11790	9-24-16		Initial	1.61	1-23-17	
03	16-11792	9-24-16		Initial	3.42	9-29-16	
05	16-11794	9-24-16		Initial	1.51	9-29-16	

# PEARLS HAWTHORNE

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
07	16-11796	9-24-16		Initial	3.16	9-29-16	
09	16-11798	9-24-16		Initial	3.84	9-29-16	
11	16-11800	9-24-16		Initial	4.26	9-29-16	
13	7090588001	5-18-19	Staff Bathroom Faucet	Initial	6.8	5-29-19	RETURNED TO USE
14	16-11803	9-24-16	"	Flushed	3.05	9-30-16	
15	16-11804	9-24-16		Initial	LT 1.00	9-29-16	
17	16-11806	9-24-16		Initial	3.77	9-29-16	
19	16-11808	9-24-16		Initial	9.81	9-29-16	
21	7072983002	12-1-18	Coaches' Office Gym Annex	Initial	7.9	12-10-18	RETURNED TO USE
22	16-11811	9-24-16	"	Flushed	1.52	9-30-16	
23	16-11812	9-24-16		Initial	1.57	9-29-16	
25	7072983003	12-1-18	Girls' Room 3rd Floor	Initial	10	12-10-18	RETURNED TO USE
26	16-11815	9-24-16	"	Flushed	<b>6.16</b>	1-25-17	
27	16-11816	9-24-16		Initial	8.31	9-29-16	
29	16-11818	9-24-16		Initial	3.46	9-29-16	
31	16-11820	9-24-16		Initial	5.75	9-29-16	
33	16-11822	9-24-16		Initial	5.01	9-29-16	
35	16-11824	9-24-16		Initial	4.11	9-29-16	
37	16-11826	9-24-16		Initial	1.39	9-29-16	
39	16-11828	9-24-16		Initial	1.64	9-29-16	
41	16-11830	9-24-16		Initial	1.93	9-30-16	
43	16-11832	9-24-16		Initial	6.20	9-30-16	
45	16-11834	9-24-16		Initial	10.6	9-30-16	
47	16-11836	9-24-16		Initial	5.68	9-30-16	
49	16-11838	9-24-16		Initial	5.51	9-30-16	
51	16-11840	9-24-16		Initial	1.98	9-30-16	
53	16-11842	9-24-16		Initial	4.23	9-30-16	
55	16-11844	9-24-16		Initial	3.75	9-30-16	
57	16-11846	9-24-16		Initial	2.81	9-30-16	
59	16-11848	9-24-16		Initial	8.53	9-30-16	
61	16-11850	9-24-16		Initial	4.14	9-30-16	
65	16-11854	9-24-16		Initial	12.0	9-30-16	
67	16-11856	9-24-16		Initial	LT 1.00	9-30-16	
69	16-11858	9-24-16		Initial	LT 1.00	9-30-16	

# PEARLS HAWTHORNE

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
73	16-11862	9-24-16		Initial	4.36	9-30-16	
75	16-11864	9-24-16		Initial	1.77	9-30-16	

OUTLETS TESTED	69
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY	4
REMEDIATION/REPLACEMENT PENDING	0

**\* Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

001	16-3505	4-5-16	Basement Water Main Spigot	Initial	76.4	6-9-16	LOCKED/POSTED
63	16-11852	9-24-16	Slop Sink Locker RM	Initial	18.5	9-30-16	LOCKED/POSTED
71	16-11860	9-24-16	Slop Sink Lower Level	Initial	32.1	9-30-16	LOCKED/POSTED
77	16-11866	9-24-16	Hose Bib by Handicap Ramp outside	Initial	144.0	9-30-16	LOCKED/POSTED