

ROOSEVELT HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
001	16-6251	5-7-16		Initial	LT 1.00	5-12-16	
003	16-6253	5-7-16		Initial	LT 1.00	5-12-16	
005	7076418001	1-11-19	Sink in Staff Lounge near 202	Initial	2.0	1-14-19	RETURNED TO USE
006	16-6256	5-7-16		Flushed	1.09	5-13-16	
007	16-6257	5-7-16		Initial	1.55	5-12-16	
009	16-6259	5-7-16		Initial	LT 1.00	5-12-16	
011	16-6261	5-7-16		Initial	LT 1.00	5-12-16	
013	7070747002	11-11-18	Faucet Nurse's Office	Initial	7.2	11-14-18	RETURNED TO USE
014	16-6264	5-7-16	"	Flushed	16.2	5-13-16	
015	16-6265	5-7-16		Initial	4.33	5-13-16	
017	16-6267	5-7-16		Initial	8.18	5-13-16	
019	16-6269	5-7-16		Initial	1.81	5-13-16	
021	16-6271	5-7-16		Initial	1.78	5-13-16	
023	16-6273	5-7-16		Initial	LT 1.00	5-13-16	
026	16-6276	5-7-16		Initial	1.16	5-13-16	
028	16-6278	5-7-16		Initial	LT 1.00	5-13-16	
030	16-6280	5-7-16		Initial	LT 1.00	5-13-16	
032	16-6282	5-7-16		Initial	2.42	5-13-16	
034	16-6284	5-7-16		Initial	3.58	5-13-16	
036	16-6286	5-7-16		Initial	3.06	5-13-16	
038	16-6288	5-7-16		Initial	9.37	5-13-16	
039	16-6289	5-7-16		Flushed	4.54	5-14-16	
040	16-6290	5-7-16		Initial	2.29	5-13-16	
042	16-6292	5-7-16		Initial	1.03	5-13-16	
044	16-6294	5-7-16		Initial	2.83	5-13-16	
046	16-6296	5-7-16		Initial	7.88	5-13-16	
048	16-6298	5-7-16		Initial	2.47	5-13-16	
050	16-6300	5-7-16		Initial	12.1	5-13-16	
052	16-6302	5-7-16		Initial	2.65	5-13-16	
054	16-6304	5-7-16		Initial	5.16	5-13-16	
056	16-6306	5-7-16		Initial	2.86	5-13-16	
058	16-6308	5-7-16		Initial	1.63	5-13-16	
060	16-6310	5-7-16		Initial	LT 1.00	5-13-16	
062	16-6312	5-7-16		Initial	LT 1.00	5-13-16	
064	16-6314	5-7-16		Initial	1.65	5-13-16	
066	16-6316	5-7-16		Initial	1.34	5-13-16	
068	16-6318	5-7-16		Initial	2.93	5-14-16	
070	16-6320	5-7-16		Initial	10.4	5-14-16	

ROOSEVELT HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
071	16-6321	5-7-16		Flushed	1.28	5-16-16	
072	16-6322	5-7-16		Initial	LT 1.00	5-14-16	
073	16-6323	5-7-16		Initial	2.50	5-14-16	
04	16-13936	10-15-16		Initial	7.31	12-6-16	
05	16-13937	10-15-16		Initial	8.07	12-6-16	
06	16-13938	10-15-16		Initial	5.83	12-6-16	
07	16-13939	10-15-16		Initial	4.20	12-6-16	
18	7070747003	11-11-18	3rd Fl. Men's Staff BR, Faucet #1	Initial	4.1	11-14-18	RETURNED TO USE
19	16-13951	10-15-16		Initial	8.30	12-6-16	
20	16-13952	10-15-16		Initial	12.9	12-6-16	
21	16-13953	10-15-16		Initial	14.1	12-6-16	
22	16-13954	10-15-16		Initial	6.02	12-6-16	
23	16-13955	10-15-16		Initial	10.2	12-6-16	
26	16-13958	10-15-16		Initial	7.22	12-6-16	
27	16-13959	10-15-16		Initial	7.37	12-6-16	
29	16-13961	10-15-16		Initial	6.88	12-6-16	
30	16-13962	10-15-16		Initial	3.75	12-6-16	
31	16-13963	10-15-16		Initial	1.95	12-6-16	
32	16-13964	10-15-16		Initial	2.46	12-6-16	
33	16-13965	10-15-16		Initial	1.85	12-6-16	
34	16-13966	10-15-16		Initial	10.1	12-6-16	
35	16-13967	10-15-16		Initial	3.22	12-6-16	
36	16-13968	10-15-16		Initial	7.77	12-6-16	
37	7070747004	11-11-18	2nd Fl. Teach-Lounge Transgen BR Faucet	Initial	2.1	11-14-18	RETURNED TO USE
39	16-13971	10-15-16		Initial	8.23	12-7-16	
40	16-13972	10-15-16		Initial	2.76	12-7-16	
41	16-13973	10-15-16		Initial	6.56	12-7-16	
42	16-13974	10-15-16		Initial	3.03	12-7-16	
43	16-13975	10-15-16		Initial	3.90	12-7-16	
44	16-13976	10-15-16		Initial	10.3	12-7-16	
45	16-13977	10-15-16		Initial	1.95	12-7-16	
46	16-13978	10-15-16		Initial	3.65	12-7-16	
47	16-13979	10-15-16		Initial	5.24	3-14-17	
48	16-13980	10-15-16		Initial	1.26	12-7-16	
49	16-13981	10-15-16		Initial	2.58	12-7-16	
50	16-13982	10-15-16		Initial	3.81	12-7-16	
51	16-13983	10-15-16		Initial	3.57	12-7-16	
52	16-13984	10-15-16		Initial	7.08	12-7-16	

ROOSEVELT HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
54 CIP-repl	7070747015	11-10-18	Boys Lock.Rm, BR Faucet S (lckr#101)	Initial	10.4	11-14-18	RETURNED TO USE
55 CIP-repl	7070747014	11-10-18	Boys Lock.Rm, BR Coach Faucet	Initial	7.6	11-14-18	RETURNED TO USE
55.5 CIP-new	7070747013	11-10-18	Boys Lock.Rm, BR Faucet N (lckr#375)	Initial	14.2	11-14-18	RETURNED TO USE
56 CIP-repl	7076418002	1-11-19	Boys Bathroom by Gym Fauc 1	Initial	2.6	1-14-19	RETURNED TO USE
57 CIP-repl	7072975002	12-1-18	Boys Bathroom by Gym Fauc 2	Initial	1.0	12-10-18	RETURNED TO USE
57.5 CIP-new	7070747009	11-11-18	Boys Bathroom by Gym Fauc 3	Initial	12.9	11-14-18	RETURNED TO USE
58 CIP-repl	7072975003	12-1-18	Girls Bathroom by Gym Fauc 1	Initial	4.2	12-10-18	RETURNED TO USE
59 CIP-repl	7072975004	12-1-18	Girls Bathroom by Gym Fauc 2	Initial	1.8	12-10-18	RETURNED TO USE
60 CIP-repl	7070747012	11-11-18	Girls Bathroom by Gym Fauc 3	Initial	11.2	11-14-18	RETURNED TO USE
61	16-13993	10-15-16		Initial	1.93	12-7-16	
62	16-13994	10-15-16		Initial	6.47	12-7-16	
63	16-13995	10-15-16		Initial	6.01	12-7-16	
64	16-13996	10-15-16		Initial	3.22	12-7-16	
65	7070747013	11-11-18	Football Visitor Lockerroom Bathroom	Initial	14.20	11-14-18	
66	16-13998	10-15-16		Initial	2.38	12-7-16	
67	16-13999	10-15-16		Initial	3.24	12-7-16	
68	16-14000	10-15-16		Initial	3.87	12-7-16	
69	7090576001	5-18-19	Men's Faculty BR 1st Fl. By Stairwell D Faucet 3	Initial	1.3	5-29-19	RETURNED TO USE
70	16-14002	10-15-16		Initial	12.9	12-7-16	
71	16-14003	10-15-16		Initial	3.54	12-7-16	
72	16-14004	10-15-16		Initial	4.76	12-8-16	
73	16-14005	10-15-16		Initial	LT 1.00	12-8-16	
74	16-14006	10-15-16		Initial	5.51	12-8-16	
75	16-14007	10-15-16		Initial	2.12	12-8-16	
76	16-14008	10-15-16		Initial	4.84	12-8-16	
77	16-14009	10-15-16		Initial	4.65	12-8-16	
78	16-14010	10-15-16		Initial	8.71	12-8-16	
79	16-14011	10-15-16		Initial	3.06	12-8-16	
80	16-14012	10-15-16		Initial	1.76	12-8-16	
81	16-14013	10-15-16		Initial	4.50	12-8-16	
82	16-14014	10-15-16		Initial	4.82	12-8-16	
83	7070747005	11-11-18	Kitchen Bath Room Faucet #1	Initial	4.0	11-14-18	RETURNED TO USE
84	7070747006	11-11-18	Kitchen Bath Room Faucet #2	Initial	5.1	11-14-18	RETURNED TO USE
85	16-14017	10-15-16		Initial	8.86	12-8-16	
88	16-14020	10-15-16		Initial	5.61	12-8-16	
89	16-14021	10-15-16		Initial	13.6	12-8-16	

ROOSEVELT HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
91	16-14023	10-15-16		Initial	3.10	12-8-16	

OUTLETS TESTED	109
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY*	23
REMEDIATION/REPLACEMENT PENDING	0

*** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

024	16-6274	5-7-16	Main Spigot	Initial	167.0	5-23-16	LOCKED/POSTED
R--01	16-13933	10-15-16	Room # 302 Faucet #1	Initial	30.7	12-6-16	LOCKED/POSTED
02	16-13934	10-15-16	Room # 302 faucet #2	Initial	58.6	12-6-16	LOCKED/POSTED
03	16-13935	10-15-16	Room # 302 Faucet #3	Initial	21.2	12-6-16	LOCKED/POSTED
08	16-13940	10-15-16	Room # 303 Faucet #2	Initial	176.3	12-6-16	LOCKED/POSTED
09	16-13941	10-15-16	Rm 306 Faucet 1-1	Initial	20.8	3-10-17	LOCKED/POSTED
10	16-13942	10-15-16	Rm 306 Faucet 1-2	Initial	21.4	3-10-17	LOCKED/POSTED
11	16-13943	10-15-16	Rm 306 Faucet 2-1	Initial	72.3	3-14-17	LOCKED/POSTED
12	16-13944	10-15-16	Rm 306 Faucet 2-2	Initial	46.8	3-14-17	LOCKED/POSTED
13	16-13945	10-15-16	Rm 306 Faucet 3-1	Initial	30.6	3-14-17	LOCKED/POSTED
14	16-13946	10-15-16	Rm 306 Faucet 3-2	Initial	16.8	3-14-17	LOCKED/POSTED
15	16-13947	10-15-16	Rm 306 Faucet 4-1	Initial	47.3	3-14-17	LOCKED/POSTED
16	16-13948	10-15-16	Rm 306 Faucet 4-2	Initial	44.8	3-14-17	LOCKED/POSTED
17	16-13949	10-15-16	Room # 306 Faucet Main Desk	Initial	18.8	12-6-16	LOCKED/POSTED
24	16-13956	10-15-16	Room # 307 Faucet #2	Initial	33.9	12-6-16	LOCKED/POSTED
25	16-13957	10-15-16	Room # 312 Faucet #1	Initial	40.0	12-6-16	LOCKED/POSTED
28	16-13960	10-15-16	Room #314 Faucet #2	Initial	20.0	12-6-16	LOCKED/POSTED
38	16-13970	10-15-16	Slop sink Faucet 2nd Fl. By Elevator	Initial	50.2	12-6-16	LOCKED/POSTED
53	16-13985	10-15-16	Slop sink Girl's Gym	Initial	108.0	3-14-17	LOCKED/POSTED
86	16-14018	10-15-16	Boiler Room B.R. Faucet	Initial	18.2	12-8-16	LOCKED/POSTED
87	16-14019	10-15-16	Court Yard Spigot	Initial	23.5	12-8-16	LOCKED/POSTED
90	16-14022	10-15-16	Auto Shop inside Spigot	Initial	27.5	12-8-16	LOCKED/POSTED
92	16-14024	10-15-16	Spigot outside Loading Dock, 207	Initial	34.7	3-14-17	LOCKED/POSTED