

GORTON HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
001	16-5795	4-30-16		Initial	1.42	5-5-16	
003	16-5797	4-30-16		Initial	LT 1.00	5-5-16	
004	16-5798	4-30-16		Initial	LT 1.00	5-5-16	
006	16-5800	4-30-16		Initial	6.30	5-5-16	
008	16-5802	4-30-16		Initial	1.91	5-5-16	
010	16-5804	4-30-16		Initial	2.70	5-5-16	
012	16-5806	4-30-16		Initial	1.25	5-5-16	
014	16-5808	4-30-16		Initial	LT 1.00	5-5-16	
016	16-5810	4-30-16		Initial	LT 1.00	5-5-16	
018	16-5812	4-30-16		Initial	2.03	5-5-16	
020	16-5814	4-30-16		Initial	1.22	5-5-16	
022	16-5816	4-30-16		Initial	1.29	5-5-16	
024	16-5818	4-30-16		Initial	3.78	5-23-16	
026	16-5820	4-30-16		Initial	1.78	5-5-16	
028	16-5822	4-30-16		Initial	2.46	5-5-16	
030	16-5824	4-30-16		Initial	5.55	5-5-16	
032	16-5826	4-30-16		Initial	3.84	5-5-16	
034	16-5828	4-30-16		Initial	5.21	5-5-16	
036	16-5830	4-30-16		Initial	12.3	5-5-16	
037	16-5831	4-30-16		Flushed	8.94	5-9-16	
038	16-5832	4-30-16		Initial	2.10	5-5-16	
040	16-5834	4-30-16		Initial	4.35	5-5-16	
042	16-5836	4-30-16		Initial	LT 1.00	5-5-16	
043	16-5837	4-30-16		Initial	2.39	5-5-16	
045	16-5839	4-30-16		Initial	LT 1.00	5-5-16	
047	16-5841	4-30-16		Initial	1.20	5-9-16	
049	16-5843	4-30-16		Initial	LT 1.00	5-9-16	
051	16-5845	4-30-16		Initial	LT 1.00	5-9-16	
052	16-5846	4-30-16		Initial	3.04	5-9-16	
054	16-5848	4-30-16		Initial	1.99	5-9-16	
055	16-5849	4-30-16		Initial	4.25	5-9-16	
057	16-5851	4-30-16		Initial	5.66	5-9-16	
061	16-5855	4-30-16		Initial	3.55	5-11-16	
G--01	16-14025	10-15-16		Initial	1.45	12-10-16	
02-A	16-14026	10-15-16	2nd Fl. Faculty Bathroom Sink 1 (near 225)	Initial	6.99	12-10-16	
03-B	16-14027	10-15-16	2nd Fl. Faculty Bathroom Sink 2 (near 225)	Initial	4.26	12-10-16	
04	16-14028	10-15-16		Initial	3.97	12-10-16	
11	16-14035	10-15-16		Initial	8.80	12-10-16	
16	16-14040	10-15-16		Initial	11.1	12-10-16	
17	16-14041	10-15-16		Initial	7.73	12-10-16	
18	16-14042	10-15-16		Initial	10.4	12-10-16	
19	7070753001	11-10-18	Faucet Sink -outside B.R. - 221	Initial	11.4	11-14-18	RETURNED TO USE
21	16-14045	10-15-16		Initial	12.6	12-10-16	
22	16-14046	10-15-16		Initial	2.85	12-10-16	

GORTON HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
23	16-14047	10-15-16		Initial	12.0	12-10-16	
28	16-14052	10-15-16		Initial	1.74	12-12-16	
29	16-14053	10-15-16		Initial	4.62	12-12-16	
30	7076419001	1-11-19	Faucet 1- Girl's B.R.-1st Fl. -Rm-107	Initial	LT 1.00	1-14-19	RETURNED TO USE
31	16-14055	10-15-16		Initial	6.78	12-12-16	
32	16-14056	10-15-16		Initial	6.25	12-12-16	
34	16-14058	10-15-16		Initial	2.09	12-12-16	
35	16-14059	10-15-16		Initial	8.75	12-12-16	
36	7076419002	1-11-19	Principal's Office Bathroom	Initial	5.2	1-14-19	RETURNED TO USE
37	16-14061	10-15-16		Initial	1.17	12-12-16	
38	16-14062	10-15-16		Initial	2.47	12-12-16	
39	16-14063	10-15-16		Initial	9.25	12-12-16	
40	16-14064	10-15-16		Initial	3.63	12-12-16	
41	16-14065	10-15-16		Initial	8.98	12-12-16	
42	16-14066	10-15-16		Initial	2.77	12-12-16	
43	16-14067	10-15-16		Initial	4.20	12-12-16	
44	16-14068	10-15-16		Initial	5.47	12-12-16	
45	16-14069	10-15-16		Initial	2.08	12-12-16	
46	16-14070	10-15-16		Initial	3.44	12-12-16	
47	16-14071	10-15-16		Initial	LT 1.00	12-12-16	
48	16-14072	10-15-16		Initial	10.7	12-12-16	
49	16-14073	10-15-16		Initial	4.97	12-12-16	
50	16-14074	10-15-16		Initial	5.07	12-12-16	
51	16-14075	10-15-16		Initial	6.43	12-12-16	
52	16-14076	10-15-16		Initial	6.09	12-12-16	
53	16-14077	10-15-16		Initial	11.5	12-13-16	
54	7070753004	11-10-18	Faucet - Room 5	Initial	10.9	11-14-18	RETURNED TO USE
56	16-14080	10-15-16		Initial	LT 1.00	12-13-16	
57	16-14081	10-15-16		Initial	2.97	12-13-16	
58	16-14082	10-15-16		Initial	3.31	12-13-16	
59	16-14083	10-15-16		Initial	4.05	12-13-16	
60	16-14084	10-15-16		Initial	4.93	12-13-16	
61	16-14085	10-15-16		Initial	13.2	12-13-16	
62	16-14086	10-15-16		Initial	3.88	12-13-16	
63	16-14087	10-15-16		Initial	3.33	12-13-16	
64.1	7070753010	11-10-18	Faucet Unisex Bathroom Left (NEW CIP)	Initial	LT 1.00	11-17-18	RETURNED TO USE
64.2	7070753009	11-10-18	Faucet Unisex Bathroom Right (NEW CIP)	Initial	LT 1.00	11-17-18	RETURNED TO USE
65	16-14089	10-15-16		Initial	10.0	12-13-16	
67	16-14091	10-15-16		Initial	7.38	3-14-17	
68	16-14092	10-15-16		Initial	4.49	12-13-16	
69	16-14093	10-15-16		Initial	7.19	12-13-16	
70	7070753005	11-10-18	Faucet 1-Room 10B-Staff Bath	Initial	5.4	11-14-18	RETURNED TO USE
71	16-14095	10-15-16		Initial	4.34	12-13-16	
75	16-14099	10-15-16		Initial	7.16	12-13-16	
76	16-14100	10-15-16		Initial	1.52	12-13-16	

GORTON HIGH

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
77	16-14101	10-15-16		Initial	1.65	12-13-16	
79	16-14103	10-15-16		Initial	11.6	12-13-16	

OUTLETS TESTED	90
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY*	27
REMEDIATION/REPLACEMENT PENDING	0

*** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

05	16-14029	10-15-16	Faucet #2- Lab Room 225	Initial	53.2	12-10-16	ELIMINATED
06	16-14030	10-15-16	3rd Fl. Lab Rm 225 Faucet 3	Initial	49.1	3-14-17	ELIMINATED
07	16-14031	10-15-16	Faucet Sink 3 Room 224 - 3rd Fl.	Initial	19.7	12-10-16	LOCKED/POSTED
08	16-14032	10-15-16	Faucet Sink 4- North Faucet - Rm 224 - 3rd Fl.	Initial	1720.0	12-10-16	LOCKED/POSTED
09	16-14033	10-15-16	Faucet Sink 5- South Faucet - Rm 224 - 3rd Fl.	Initial	30.5	12-10-16	LOCKED/POSTED
10	16-14034	10-15-16	Faucet Sink 7- East Faucet - Rm 224 - 3rd Fl.	Initial	118.5	12-10-16	LOCKED/POSTED
12	16-14036	10-15-16	Faucet Sink - Room 223-B	Initial	49.8	12-10-16	LOCKED/POSTED
13	16-14037	10-15-16	Faucet Sink 4- Room 223- 3rd Fl.	Initial	239.4	12-10-16	LOCKED/POSTED
14	16-14038	10-15-16	Faucet Sink 5- South Faucet Room 223- 3rd Fl.	Initial	64.6	12-10-16	LOCKED/POSTED
15	16-14039	10-15-16	Faucet Sink 5- North Faucet Room 223- 3rd Fl.	Initial	56.5	12-10-16	LOCKED/POSTED
20	16-14044	10-15-16	Faucet Sink 5 - Room 220 - 3rd Fl.	Initial	72.5	12-10-16	LOCKED/POSTED
24	16-14048	10-15-16	Faucet Sink West - Rm. 216 - 3rd Fl.	Initial	4660.0	12-10-16	ELIMINATED
25	16-14049	10-15-16	Faucet Slop Sink - South side Hall - 3rd Fl.	Initial	17.1	12-10-16	LOCKED/POSTED
26	16-14050	10-15-16	Faucet Sink right of door - Rm.213 - 3rd Fl.	Initial	121.8	12-10-16	LOCKED/POSTED
27	16-14051	10-15-16	Faucet-AP Office-2nd Fl. Rm # 212	Initial	48.2	12-10-16	ELIMINATED
33	16-14057	10-15-16	Faucet in stall - Girl's B.R.- Rm-107	Initial	28.3	12-12-16	ELIMINATED
55	16-14079	10-15-16	Faucet - Slop sink-Basement -Stairwy 4	Initial	24.4	12-13-16	LOCKED/POSTED
64	16-14088	10-15-16	Faucet - Sink- Room 15	Initial	3350.0	12-13-16	ELIMINATED
66	16-14090	10-15-16	Faucet - Room 13A	Initial	27.7	12-13-16	ELIMINATED
72	16-14096	10-15-16	Faucet 1 Girls bath at Café (removed)	Initial	2.8	12-13-16	ELIMINATED
73	16-14097	10-15-16	Faucet 2 Girls bath at Café (removed)	Initial	9.3	12-13-16	ELIMINATED
74	16-14098	10-15-16	Faucet Boys bath at Café (removed)	Initial	3.1	12-13-16	ELIMINATED
NEW	7070753006	11-10-18	Faucet 1 Girls bath @Café (NEW tempered fauc)	Initial	LT 1.00	11-14-18	LOCKED/POSTED
NEW	7070753007	11-10-18	Faucet 2 Girls bath @Café (NEW tempered fauc)	Initial	LT 1.00	11-14-18	LOCKED/POSTED
NEW	-	-	Faucet 1 Boys bath @Café (NEW tempered fauc)	Initial	-	-	LOCKED/POSTED
NEW	7070753008	11-10-18	Faucet 2 Boys bath @Café (NEW tempered fauc)	Initial	LT 1.00	11-14-18	LOCKED/POSTED
78	16-14102	10-15-16	Spigot east side of Cafeteria	Initial	71.7	12-13-16	LOCKED/POSTED

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

As per regulations, in order to pass lead testing, potable water fixtures must have levels below 15 micrograms per liter (ug/L) or 15 parts per billion (ppb) of lead. Below is a list of the various terms used in the report for Action Taken, depending on latest test results.

Definitions of Terms used under "Action Taken" Column:

RETURNED TO USE	new fixture test passes for safe use
LOCKED	a locked fixture or in a locked room
POSTED	sign posted "Do Not Drink"
OFF	fixture is shut off/disabled
PENDING REPL.	fixure is waiting for replacement
PENDING TEST	fixture is waiting for testing
PENDING REMEDIATION	fixture requires further investigation for remediation of lead
ELIMINATED	fixure has been removed