

BOYCE THOMPSON

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
03	7072980001	12-01-18	Faucet #1 Rm 109	Initial	5.9	12-10-18	RETURNED TO USE
04	16-6668	5-13-16	"	Flushed	LT 1.00	5-24-16	
05	16-6669	5-13-16		Initial	1.10	5-17-16	
07	16-6671	5-13-16		Initial	6.97	5-17-16	
09	16-6673	5-13-16		Initial	6.64	5-17-16	
11	16-6675	5-13-16		Initial	1.46	5-17-16	
13	7094264001	6-15-19	Stage Faucet	Initial	16.9	6-28-19	OFF/PENDING REMEDIATION
14	16-6678	5-13-16	"	Flushed	73.7	5-17-16	
BT-1	16-13007	10-1-16		Initial	1.68	10-27-16	
2	16-13008	10-1-16		Initial	1.45	10-27-16	
3	16-13009	10-1-16		Initial	LT 1.00	10-27-16	
4	16-13010	10-1-16		Initial	LT 1.00	10-27-16	
5	16-13011	10-1-16		Initial	4.96	10-27-16	
6	16-13012	10-1-16		Initial	6.83	10-27-16	
7	16-13013	10-1-16		Initial	LT 1.00	10-27-16	
9	16-13015	10-1-16		Initial	1.05	10-27-16	
10	16-13016	10-1-16		Initial	LT 1.00	10-27-16	
11	16-13017	10-1-16		Initial	1.52	10-27-16	
12	16-13018	10-1-16		Initial	1.81	10-27-16	
13	16-13019	10-1-16		Initial	5.52	10-27-16	
14	16-13020	10-1-16		Initial	6.81	3-7-17	
15	16-13021	10-1-16		Initial	LT 1.00	10-28-16	
16	16-13022	10-1-16		Initial	1.22	10-28-16	
17	16-13023	10-1-16		Initial	5.60	10-28-16	
18	16-13024	10-1-16		Initial	LT 1.00	10-28-16	
19	16-13025	10-1-16		Initial	1.76	10-28-16	
20	16-13026	10-1-16		Initial	LT 1.00	10-28-16	
21	16-13027	10-1-16		Initial	LT 1.00	10-28-16	
22	16-13028	10-1-16		Initial	2.36	10-28-16	
23	16-13029	10-1-16		Initial	LT 1.00	10-28-16	
24	16-13030	10-1-16		Initial	2.48	10-28-16	
25	16-13031	10-1-16		Initial	6.76	10-28-16	
26	16-13032	10-1-16		Initial	3.73	10-28-16	
27	16-13033	10-1-16		Initial	3.42	10-28-16	

BOYCE THOMPSON

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
28	16-13034	10-1-16		Initial	1.81	10-28-16	
29	16-13035	10-1-16		Initial	3.24	10-28-16	

OUTLETS TESTED	34
OUTLETS ACTIONABLE	1
REMOVED FROM POTABLE INVENTORY	2
REMEDATION/REPLACEMENT PENDING	1

*** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

01	16-6665	5-13-16	Main Spigot	Initial	57.6	5-17-16	LOCKED/POSTED
8	16-13014	10-1-16	Rm. 217 Slop Sink Faucet	Initial	20.5	10-27-16	LOCKED/POSTED