

# PALISADES PREP

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
003	16-3917	4-8-16		Initial	LT 1.00	6-7-16	
004	16-3918	4-8-16		Flushed	LT 1.00	6-7-16	
005	16-3919	4-8-16		Initial	2.10	6-7-16	
006	16-3920	4-8-16		Flushed	LT 1.00	6-7-16	
007	7070081001	11-3-18	Faucet SS Kitchen Sink #2	Initial	LT 1.00	11-12-18	RETURNED TO USE
008	16-3922	4-8-16	"	Flushed	LT 1.00	6-7-16	
009	16-3923	4-8-16		Initial	3.94	6-7-16	
010	16-3924	4-8-16		Flushed	LT 1.00	6-7-16	
011	7070081002	11-3-18	Faucet SS Kitchen Sink #4	Initial	LT 1.00	11-12-18	RETURNED TO USE
012	16-3926	4-8-16	"	Flushed	3.65	6-7-16	
013	16-3927	4-8-16		Initial	5.05	6-7-16	
014	16-3928	4-8-16		Flushed	LT 1.00	6-7-16	
015	16-3929	4-8-16		Initial	3.67	6-7-16	
016	16-3930	4-8-16		Flushed	1.55	6-7-16	
017	16-3931	4-8-16		Initial	10.4	6-7-16	
018	16-3932	4-8-16		Flushed	2.81	6-7-16	
019	16-3933	4-8-16		Initial	10.2	6-7-16	
020	16-3934	4-8-16		Flushed	1.03	6-7-16	
021	16-3935	4-8-16		Initial	7.66	6-7-16	
023	16-3937	4-8-16		Initial	LT 1.00	6-7-16	
024	16-3938	4-8-16		Initial	6.41	6-7-16	
026	16-3940	4-8-16		Initial	1.62	6-7-16	
028	16-3942	4-8-16		Initial	LT 1.00	4-13-16	
029	16-3943	4-8-16		Initial	3.84	6-3-16	
030	16-3944	4-8-16		Flushed	LT 1.00	6-3-16	
031	16-3945	4-8-16		Initial	LT 1.00	4-13-16	
033	16-3947	4-8-16		Initial	LT 1.00	4-13-16	
034	16-3948	4-8-16		Initial	LT 1.00	4-18-16	
035	16-3949	4-8-16		Initial	LT 1.00	4-13-16	
036	16-3950	4-8-16		Initial	LT 1.00	4-13-16	
038	16-3952	4-8-16		Initial	LT 1.00	4-13-16	
PP--01	16-14920	10-29-16		Initial	LT 1.00	1-11-17	
02	16-14921	10-29-16		Initial	LT 1.00	1-11-17	
03	16-14922	10-29-16		Initial	LT 1.00	1-11-17	
04	16-14923	10-29-16		Initial	LT 1.00	1-11-17	
05	16-14924	10-29-16		Initial	LT 1.00	1-11-17	
06	16-14925	10-29-16		Initial	11.4	1-11-17	
07	16-14926	10-29-16		Initial	4.67	1-11-17	

# PALISADES PREP

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
08	16-14927	10-29-16		Initial	3.46	1-11-17	
09	16-14928	10-29-16		Initial	LT 1.00	1-11-17	
10	16-14929	10-29-16		Initial	LT 1.00	1-11-17	
11	16-14930	10-29-16		Initial	LT 1.00	1-11-17	
12	16-14931	10-29-16		Initial	LT 1.00	1-12-17	
13	16-14932	10-29-16		Initial	LT 1.00	1-12-17	
14	16-14933	10-29-16		Initial	LT 1.00	1-12-17	
15	16-14934	10-29-16		Initial	1.90	1-12-17	
16	16-14935	10-29-16		Initial	LT 1.00	1-12-17	
17	16-14936	10-29-16		Initial	LT 1.00	1-12-17	
18	16-14937	10-29-16		Initial	LT 1.00	1-12-17	
19	16-14938	10-29-16		Initial	2.66	1-12-17	
20	16-14939	10-29-16		Initial	3.43	1-12-17	
21	16-14940	10-29-16		Initial	2.87	1-12-17	
22	16-14941	10-29-16		Initial	5.44	1-12-17	
23	16-14942	10-29-16		Initial	3.11	1-12-17	
24	16-14943	10-29-16		Initial	LT 1.00	1-12-17	
25	16-14944	10-29-16		Initial	LT 1.00	1-12-17	
26	16-14945	10-29-16		Initial	LT 1.00	1-12-17	
27	16-14946	10-29-16		Initial	7.08	1-12-17	
28	16-14947	10-29-16		Initial	2.24	1-12-17	
29	16-14948	10-29-16		Initial	LT 1.00	1-12-17	
30	16-14949	10-29-16		Initial	3.78	1-12-17	
31	16-14950	10-29-16		Initial	LT 1.00	1-12-17	
32	16-14951	10-29-16		Initial	LT 1.00	1-12-17	
33	16-14952	10-29-16		Initial	LT 1.00	1-12-17	
34	16-14953	10-29-16		Initial	LT 1.00	1-12-17	
35	16-14954	10-29-16		Initial	LT 1.00	1-12-17	
36	16-14955	10-29-16		Initial	LT 1.00	1-12-17	
37	16-14956	10-29-16		Initial	LT 1.00	1-12-17	
38	16-14957	10-29-16		Initial	LT 1.00	1-12-17	
39	16-14958	10-29-16		Initial	1.73	1-12-17	
40	16-14959	10-29-16		Initial	2.61	1-12-17	

# PALISADES PREP

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L (LT 1.0 = Less Than 1.0)	Date of Analysis	ACTION TAKEN
41	16-14960	10-29-16		Initial	LT 1.00	1-12-17	
42	16-14961	10-29-16		Initial	LT 1.00	1-13-17	
43	16-14962	10-29-16		Initial	LT 1.00	1-13-17	
44	16-14963	10-29-16		Initial	LT 1.00	1-13-17	
45	16-14964	10-29-16		Initial	LT 1.00	1-13-17	
46	16-14965	10-29-16		Initial	1.70	1-13-17	
47	16-14966	10-29-16		Initial	LT 1.00	1-13-17	
48	16-14967	10-29-16		Initial	1.36	1-13-17	
49	16-14968	10-29-16		Initial	LT 1.00	1-13-17	
50	16-14969	10-29-16		Initial	LT 1.00	1-13-17	
51	16-14970	10-29-16		Initial	1.29	1-13-17	
53	16-14972	10-29-16		Initial	LT 1.00	1-13-17	
54	16-14973	10-29-16		Initial	LT 1.00	1-13-17	
55	16-14974	10-29-16		Initial	LT 1.00	1-13-17	
56	16-14975	10-29-16		Initial	LT 1.00	1-13-17	
57	16-14976	10-29-16		Initial	LT 1.00	1-13-17	
58	16-14977	10-29-16		Initial	1.05	1-13-17	
59	16-14978	10-29-16		Initial	LT 1.00	1-13-17	
60	16-14979	10-29-16		Initial	LT 1.00	1-13-17	
61	16-14980	10-29-16		Initial	LT 1.00	1-13-17	
62	16-14981	10-29-16		Initial	LT 1.00	1-13-17	

OUTLETS TESTED	82
OUTLETS ACTIONABLE	0
REMOVED FROM POTABLE INVENTORY	2
REMEDIATION/REPLACEMENT PENDING	0

**\* Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"**

001	16-3915	4-8-16	Water Main Spigot	Initial	259.0	4-13-16	LOCKED/POSTED
52	16-14971	10-29-16	Slopsink Faucet near copy room	Initial	26.0	1-13-17	LOCKED/POSTED

## Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

As per regulations, in order to pass lead testing, potable water fixtures must have levels below 15 micrograms per liter (ug/L) or 15 parts per billion (ppb) of lead. Below is a list of the various terms used in the report for Action Taken, depending on latest test results.

### **Definitions of Terms used under "Action Taken" Column:**

RETURNED TO USE	new fixture test passes for safe use
LOCKED	a locked fixture or in a locked room
POSTED	sign posted "Do Not Drink"
OFF	fixture is shut off/disabled
PENDING REPL.	fixure is waiting for replacement
PENDING TEST	fixture is waiting for testing
PENDING REMEDIATION	fixture requires further investigation for remediation of lead
ELIMINATED	fixure has been removed