

SCHOOL 16

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

| BOE ID# | Lab ID # | Date of Collection | Sample Description | Initial / Flushed | Lead Concentration ug/L (LT 1.0 = Less Than 1.0) | Date of Analysis | ACTION TAKEN |
|---------|------------|--------------------|---------------------------|-------------------|--|------------------|---------------|
| 001 | 16-5265 | 4-22-16 | | Initial | 6.74 | 4-24-16 | |
| 003 | 16-5266 | 4-22-16 | | Initial | 2.83 | 4-24-16 | |
| 005 | 16-5268 | 4-22-16 | | Initial | 1.90 | 4-24-16 | |
| 007 | 16-5270 | 4-22-16 | | Initial | L.T 1.00 | 5-26-16 | |
| 16-1 | 16-12914 | 10-1-16 | | Initial | 4.97 | 10-24-16 | |
| 2 | 16-12915 | 10-1-16 | | Initial | 2.96 | 10-24-16 | |
| 3 | 16-12916 | 10-1-16 | | Initial | LT 1.00 | 10-24-16 | |
| 4 | 16-12917 | 10-1-16 | | Initial | 2.25 | 10-24-16 | |
| 5 | 16-12918 | 10-1-16 | | Initial | 2.16 | 10-24-16 | |
| 6 | 16-12919 | 10-1-16 | | Initial | 2.93 | 10-24-16 | |
| 7 | 16-12920 | 10-1-16 | | Initial | 1.59 | 10-26-16 | |
| 8 | 16-12921 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 9 | 16-12922 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 10 | 16-12923 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 11 | 16-12924 | 10-1-16 | | Initial | 2.32 | 10-26-16 | |
| 12 | 16-12925 | 10-1-16 | | Initial | 1.46 | 10-26-16 | |
| 13 | 16-12926 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 14 | 16-12927 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 15 | 16-12928 | 10-1-16 | | Initial | 3.44 | 10-26-16 | |
| 16 | 16-12929 | 10-1-16 | | Initial | 1.17 | 10-26-16 | |
| 17 | 16-12930 | 10-1-16 | | Initial | 1.23 | 10-26-16 | |
| 18 | 16-12931 | 10-1-16 | | Initial | 2.27 | 10-26-16 | |
| 19 | 16-12932 | 10-1-16 | | Initial | 1.28 | 10-26-16 | |
| 20 | 16-12933 | 10-1-16 | | Initial | 1.90 | 10-26-16 | |
| 21 | 16-12934 | 10-1-16 | | Initial | 3.67 | 10-26-16 | |
| 22 | 7090585001 | 5-18-19 | Nurse's Bathroom sink # 1 | Initial | LT 1.00 | 5-29-19 | RETURN TO USE |
| 23 | 16-12936 | 10-1-16 | | Initial | 2.57 | 10-26-16 | |
| 24 | 16-12937 | 10-1-16 | | Initial | 2.06 | 10-26-16 | |
| 25 | 16-12938 | 10-1-16 | | Initial | 5.67 | 3-7-17 | |
| 26 | 16-12939 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 27 | 16-12940 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |

SCHOOL 16

Yonkers Public Schools - Potable Water Outlets Sampling, Test Results and Action

Method of Analysis EPA Method 200.8 Rev. 5.4

| BOE ID# | Lab ID # | Date of Collection | Sample Description | Initial / Flushed | Lead Concentration ug/L (LT 1.0 = Less Than 1.0) | Date of Analysis | ACTION TAKEN |
|---------|----------|--------------------|--------------------|-------------------|--|------------------|--------------|
| 28 | 16-12941 | 10-1-16 | | Initial | 9.36 | 3-7-17 | |
| 29 | 16-12942 | 10-1-16 | | Initial | LT 1.00 | 10-26-16 | |
| 30 | 16-12943 | 10-1-16 | | Initial | 4.36 | 10-26-16 | |

| | |
|----------------------------------|----|
| OUTLETS TESTED | 34 |
| OUTLETS ACTIONABLE | 0 |
| REMOVED FROM POTABLE INVENTORY | 0 |
| REMEDICATION/REPLACEMENT PENDING | 0 |

** Fixtures Removed from Potable Inventory; LOCKED and POSTED "Do Not Drink"*

| | | | | | | | |
|--|--|--|--|--|--|--|--|
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |