

# SCHOOL 9

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
01	16-4525	4-13-16	<b>BUILDING SERVICE SPIGOT</b>	Initial	12.6	6-1-16	
02	16-4526	4-13-16	"	<b>Flushed</b>	<b>72.9</b>	<b>6-1-16</b>	<b>SHUT OFF</b>
03	16-4527	4-13-16		Initial	4.78	4-19-16	
05	16-4529	4-13-16		Initial	LT 1.00	4-19-16	
07	16-4531	4-13-16		Initial	LT 1.00	4-19-16	
08	16-4532	4-13-16	<b>Faucet Rm 7</b>	<b>Initial</b>	<b>191</b>	<b>6-1-16</b>	<b>SHUT OFF</b>
09	16-4533	4-13-16	"	Flushed	10.7	6-2-16	
10	16-4534	4-13-16	<b>Faucet Rm 6</b>	<b>Initial</b>	<b>300</b>	<b>4-19-16</b>	<b>SHUT OFF</b>
11	16-4535	4-13-16	"	Flushed	1.76	4-20-16	
12	16-4536	4-13-15		Initial	2.12	4-19-16	
14	16-4538	4-13-16	<b>Chiller Hallway by Rm 2</b>	<b>Initial</b>	<b>18.4</b>	<b>4-19-16</b>	<b>SHUT OFF</b>
15	16-4539	4-13-16	<b>Chiller Hallway by Rm 11</b>	<b>Initial</b>	<b>47.9</b>	<b>4-19-16</b>	<b>SHUT OFF</b>
9-1	16-13519	10-6-16		Initial	1.95	11-30-16	
2B	16-13520	10-6-16		Initial	LT 1.00	11-30-16	
3A	16-13521	10-6-16		Initial	LT 1.00	11-30-16	
4B	16-13522	10-6-16		Initial	2.28	11-30-16	
5	16-13523	10-6-16		Initial	1.27	12-1-16	
6	16-13524	10-6-16		Initial	1.90	12-1-16	
7	16-13525	10-6-16		Initial	LT 1.00	12-1-16	
8	16-13526	10-6-16		Initial	2.29	12-1-16	
9	16-13527	10-6-16		Initial	1.30	12-1-16	
10	16-13528	10-6-16	<b>Staff Basement Bathroom</b>	<b>Initial</b>	<b>21.60</b>	<b>3-10-17</b>	<b>POSTED</b>
11A	16-13529	10-6-16		Initial	1.36	12-1-16	
12B	16-13530	10-6-16		Initial	1.05	12-1-16	
13B	16-13531	10-6-16		Initial	LT 1.00	12-1-16	
14	16-13532	10-6-16		Initial	4.50	12-1-16	
15	16-13533	10-6-16		Initial	LT 1.00	12-1-16	
16	16-13534	10-6-16		Initial	LT 1.00	12-1-16	
17	16-13535	10-6-16	<b>Main Office Faucet</b>	<b>Initial</b>	<b>245</b>	<b>12-1-16</b>	<b>POSTED</b>

OUTLETS TESTED	26
OUTLETS ACTIONABLE	7
OUTLETS PENDING	0
POST 9-6-16	17