

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-3267	4-1-16	Rm 115 Sink #1 by wall	Initial	10.9	4-3-16	
003	16-3269	4-1-16	Rm 115 Sink #2	Initial	5.32	4-3-16	
005	16-3271	4-1-16	Rm 115 Sink #3	Initial	5.6	4-3-16	
007	16-3273	4-1-16	BUILDING SERVICE SPIGOT	Initial	LT 1.00	4-3-16	
009	16-3275	4-1-16	1st Floor Rm 107 Bubbler - Chiller	Initial	LT 1.00	4-3-16	
010	16-3276	4-1-16	2nd Floor Rm 211 Bubbler - Chiller	Initial	LT 1.00	4-3-16	
011	16-3277	4-1-16	2nd FI Hall by Rm 204 Sink #1	Initial	17.7	4-3-16	SHUT OFF
012	16-3278	4-1-16	"	Flushed	4.67	4-4-16	
013	16-3279	4-1-16	2nd FI Hall by Rm 204 Sink #2	Initial	8.42	4-3-16	
015	16-3281	4-1-16	2nd FI Hall by Rm 210 Sink #1	Initial	4.43	4-3-16	
017	16-3283	4-1-16	2nd FI Hall by Rm 210 Sink #2	Initial	71.1	4-3-16	SHUT OFF
018	16-3284	4-1-16	"	Flushed	2.52	4-4-16	
019	16-3285	4-1-16	2nd FI Hall by Rm 214 Faucet	Initial	30.1	4-3-16	SHUT OFF
020	16-3286	4-1-16	"	Flushed	14.1	4-4-16	
021	16-3287	4-1-16	2nd FI Hall by Rm 218 Faucet#1	Initial	2.82	4-3-16	
023	16-3289	4-1-16	2nd FI Hall by Rm 218 Faucet#2	Initial	15.6	4-3-16	SHUT OFF
024	16-3290	4-1-16	"	Flushed	2.19	4-4-16	
025	16-3291	4-1-16	2nd FI Hall by Rm 218 Sink #3	Initial	18.2	4-3-16	SHUT OFF
026	16-3292	4-1-16	"	Flushed	1.32	4-4-16	
027	16-3293	4-1-16	Teacher's Lounge sink	Initial	196	4-3-16	SHUT OFF
028	16-3294	4-1-16	"	Flushed	6.34	4-4-16	
030	16-3295	4-1-16	Kitchen 2nd Fl. Faucet 1	Initial	5.15	4-3-16	
029	16-3296	4-1-16	"	Flushed	LT 1.00	4-3-16	
031	16-3297	4-1-16	1	Initial	2.64	4-4-16	
01	16-14982	10-29-16		Initial	2.06	3-3-17	
02	16-14983	10-29-16		Initial	4.85	3-3-17	
03	16-14984	10-29-16	Slop sink faucet across from Rm 214	Initial	157	3-3-17	POSTED
04	16-14985	10-29-16		Initial	3.57	3-3-17	
05	16-14986	10-29-16		Initial	2.6	3-3-17	
06	16-14987	10-29-16		Initial	6.24	3-3-17	
07	16-14988	10-29-16		Initial	2.24	3-3-17	
08	16-14989	10-29-16		Initial	8.3	3-3-17	
09	16-14990	10-29-16	Kitchen Hand Sink Faucet	Initial	105	3-22-17	POSTED
10	16-14991	10-29-16	Hose Bib at rear of Bldg.	Initial	69.5	3-3-17	SHUT OFF
11	16-14992	10-29-16	Faucet- Staff Kitchen Bathroom	Initial	17.9	3-3-17	POSTED
12	16-14993	10-29-16		Initial	13.2	3-3-17	
13	16-14994	10-29-16		Initial	8.34	3-3-17	
14	16-14995	10-29-16	Faucet-Men's Staff by Lounge 1st Fl.	Initial	17.4	3-3-17	POSTED

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
15	16-14996	10-29-16	Faucet-Girl's BR- 1st Fl. Rm 112	Initial	27.5	3-3-17	POSTED
16	16-14997	10-29-16		Initial	1.99	3-3-17	
17	16-14998	10-29-16		Initial	1.96	3-3-17	
18	16-14999	10-29-16		Initial	8.58	3-3-17	
19	16-15000	10-29-16		Initial	2.31	3-3-17	
20	16-15001	10-29-16		Initial	3.58	3-3-17	
21	16-15002	10-29-16		Initial	14.4	3-3-17	
22	16-15003	10-29-16	Slop Sink Boiler Rm	Initial	20.3	3-22-17	POSTED

OUTLETS SAMPLED	39
OUTLETS ACTIONABLE	13
OUTLETS PENDING	0
POST 9-6-16	22