

SCHOOL 13

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
002	16-4578	4-14-16	BUILDING SERVICE SPIGOT	Initial	84.5	4-19-16	SHUT OFF
001	16-4579	4-14-16	"	Flushed	36.5	4-19-16	
003	16-4580	4-14-16	101 Sink 1	Initial	80.1	6-1-16	SHUT OFF
004	16-4581	4-14-16	"	Flushed	4.89	6-2-16	
005	16-4582	4-14-16	101 Sink 2	Initial	56.8	6-1-16	SHUT OFF
006	16-4583	4-14-16	"	Flushed	3.51	6-2-16	
007	16-4584	4-14-16	101 Fountain	Initial	8.36	4-19-16	
009	16-4586	4-14-16	102 Sink	Initial	1.45	4-19-16	
011	16-4588	4-14-16	103 Sink	Initial	6.95	4-19-16	
013	16-4590	4-14-16	Fountain near 103	Initial	3.84	4-19-16	
015	16-4592	4-14-16	Kitchen Sink (SS) Left	Initial	2.58	4-19-16	
017	16-4594	4-14-16	Kitchen Sink (Porc) Right	Initial	1.85	4-19-16	
019	16-4596	4-14-16	Nurses Office Sink	Initial	23.6	4-19-16	REPLACED & SHUT OFF*
020	16-4597	4-14-16	"	Flushed	13.2	4-20-16	
021	16-4598	4-14-16	Faculty Room Sink	Initial	9.59	4-20-16	
023	16-4600	4-14-16	107 Sink 1	Initial	2.58	4-20-16	
025	16-4602	4-14-16	107 Sink 2	Initial	LT 1.00	4-20-16	
027	16-4604	4-14-16	107 Bubbler	Initial	LT 1.00	4-20-16	
029	16-4606	4-14-16	108 Sink 1	Initial	2.22	4-20-16	
031	16-4608	4-14-16	108 Sink 2	Initial	1.07	4-20-16	
033	16-4610	4-14-16	108 Bubbler	Initial	1.64	6-1-16	
035	16-4612	4-14-16	109 Sink 1	Initial	9.85	6-1-16	
037	16-4614	4-14-16	109 Sink 2	Initial	1.23	4-20-16	
039	16-4616	4-14-16	109 Bubbler	Initial	1.29	4-20-16	
041	16-4618	4-14-16	111 Sink 1	Initial	1.62	4-20-16	
043	16-4620	4-14-16	111 Sink 2	Initial	28.2	4-20-16	RECONDITION/RE-TEST**
044	16-4621	4-14-16	"	Flushed	1.07	4-21-16	
045	16-4622	4-14-16	111 Bubbler	Initial	3.98	4-20-16	
047	16-4624	4-14-16	Fountain by Faculty	Initial	LT 1.00	4-20-16	
049	16-4626	4-14-16	115 Sink	Initial	4.51	4-20-16	
051	16-4628	4-14-16	112 Sink ***	Initial	16.0	4-20-16	REPLACED & SHUT OFF*
052	16-4629	4-14-16	"	Flushed	103	4-21-16	

SCHOOL 13

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
053	16-4630	4-14-16	114 Sink	Initial	3.50	4-20-16	
055	16-4632	4-14-16	114 Bubbler	Initial	10.8	4-20-16	
056	16-4633	4-14-16	114 Bubbler	Flushed	1.85	4-21-16	
057	16-4634	4-14-16	113 Sink	Initial	2.83	6-1-16	
059	16-4636	4-14-16	113 Bubbler	Initial	1.65	4-20-16	
061	16-4638	4-14-16	112A Sink	Initial	7.89	4-20-16	
063	16-4640	4-14-16	216 Sink	Initial	4.01	4-20-16	
065	16-4642	4-14-16	216 Bubbler	Initial	13.3	4-20-16	
066	16-4643	4-14-16	216 Bubbler	Flushed	2.66	4-21-16	
067	16-4644	4-14-16	217 Sink	Initial	4.80	4-20-16	
069	16-4646	4-14-16	217 Bubbler	Initial	7.08	4-20-16	
071	16-4648	4-14-16	215 Sink	Initial	29.0	4-20-16	REPLACED & SHUT OFF*
072	16-4649	4-14-16	"	Flushed	78.9	4-21-16	
073	16-4650	4-14-16	218 Sink	Initial	8.04	4-20-16	
075	16-4652	4-14-16	218 Bubbler	Initial	7.64	4-20-16	
077	16-4654	4-14-16	219 Sink	Initial	8.45	4-20-16	
079	16-4656	4-14-16	Fountain by 2nd fl. Bathroom	Initial	1.94	4-20-16	
081	16-4658	4-14-16	214 Sink 1	Initial	5.24	4-20-16	
083	16-4660	4-14-16	214 Sink 2	Initial	35.4	6-1-16	SHUT OFF
084	16-4661	4-14-16	"	Flushed	28.8	6-1-16	
085	16-4662	4-14-16	214 Bubbler	Initial	37.1	6-1-16	SHUT OFF
086	16-4663	4-14-16	"	Flushed	21.4	6-1-16	
087	16-4664	4-14-16	213 Sink 1	Initial	1.87	6-1-16	
089	16-4666	4-14-16	213 Sink 2	Initial	39.8	6-1-16	SHUT OFF
090	16-4667	4-14-16	"	Flushed	14.3	6-2-16	
091	16-4668	4-14-16	213 Bubbler	Initial	1.72	4-20-16	
093	16-4670	4-14-16	Chiller hallway by 212	Initial	1.98	4-20-16	
094	16-4671	4-14-16	212 Sink 1	Initial	58.5	6-1-16	SHUT OFF
095	16-4672	4-14-16	"	Flushed	LT 1.00	6-2-16	
096	16-4673	4-14-16	212 Sink 2	Initial	16.1	6-1-16	
097	16-4674	4-14-16	212 Sink 2	Flushed	LT 1.00	6-2-16	
098	16-4675	4-14-16	212 Bubbler	Initial	LT 1.00	4-20-16	

SCHOOL 13

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
100	16-4677	4-14-16	211 Sink 1	Initial	LT 1.00	4-20-16	
102	16-4679	4-14-16	211 Sink 2	Initial	1.15	4-20-16	
104	16-4681	4-14-16	211 Bubbler	Initial	1.51	4-20-16	
106	16-4683	4-14-16	210 Sink 1	Initial	1.89	4-20-16	
108	16-4685	4-14-16	210 Sink 2	Initial	1.81	4-21-16	
110	16-4687	4-14-16	210 Bubbler	Initial	LT 1.00	4-21-16	
112	16-4689	4-14-16	207 Sink ***	Initial	19.6	6-1-16	REPLACED & SHUT OFF*
113	16-4690	4-14-16	"	Flushed	3.87	6-2-16	
114	16-4691	4-14-16	206 Sink	Initial	10.3	4-21-16	
116	16-4693	4-14-16	205 Sink	Initial	24.3	4-21-16	REPLACED & SHUT OFF*
117	16-4694	4-14-16	"	Flushed	5.59	4-22-16	
118	16-4695	4-14-16	204 Sink	Initial	3.26	4-21-16	
120	16-4697	4-14-16	203 Sink ***	Initial	190	6-1-16	REPLACED & SHUT OFF*
121	16-4698	4-14-16	"	Flushed	11.3	6-2-16	
122	16-4699	4-14-16	201 Sink 1	Initial	3.85	4-21-16	
124	16-4701	4-14-16	201 Sink 2	Initial	2.03	4-21-16	
126	16-4703	4-14-16	201 Bubbler	Initial	2.81	6-1-16	
128	16-4705	4-14-16	202 Sink 1	Initial	2.78	4-21-16	
130	16-4707	4-14-16	202 Sink 2	Initial	8.48	6-1-16	
132	16-4709	4-14-16	202 Bubbler	Initial	2.40	4-21-16	
134	16-4711	4-14-16	310 Sink ***	Initial	17.8	4-21-16	REPLACED & SHUT OFF*
135	16-4712	4-14-16	"	Flushed	1.95	4-22-16	
136	16-4713	4-14-16	302 Sink	Initial	5.54	4-21-16	
138	16-4715	4-14-16	?? In hallway by 302	Initial	LT 1.00	4-21-16	
140	16-4717	4-14-16	Faucet Rm 305	Initial	16.0	4-21-16	REPLACED & SHUT OFF*
141	16-4718	4-14-16	"	Flushed	10.2	4-22-16	
13-001A	16-13189	10-1-16	301 Girls bathroom sink A	Initial	5.2	11-11-16	
002A	16-13190	10-1-16	301 Girls bathroom sink B	Initial	8.51	11-11-16	
003	16-13191	10-1-16	310 Sink (replacment fixture)	Initial	34.3	11-11-16	SHUT OFF***
004	16-13192	10-1-16	304 Slop Sink	Initial	3.15	11-11-16	
005A	16-13193	10-1-16	306 Boys bathroom sink A	Initial	9.38	11-11-16	
006B	16-13194	10-1-16	306 Boys bathroom sink B	Initial	4.49	11-21-16	

SCHOOL 13

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
007	16-13195	10-1-16	203.1 Slop Sink	Initial	1.18	11-11-16	
008A	16-13196	10-1-16	203.02 Boys Bathroom Sink A	Initial	1.45	11-11-16	
009B	16-13197	10-1-16	203.02 Boys Bathroom Sink B	Initial	42.9	11-21-16	SHUT OFF
010C	16-13198	10-1-16	203.02 Boys Bathroom Sink C	Initial	3.09	11-21-16	
011D	16-13199	10-1-16	203.02 Boys Bathroom Sink D	Initial	2.13	11-21-16	
012A	16-13200	10-1-16	202 Sink A	Initial	4.41	11-11-16	
013B	16-13201	10-1-16	202 Sink B	Initial	350	11-21-16	SHUT OFF
014	16-13202	10-1-16	207 Sink (replacement fixture)	Initial	5.94	11-11-16	***
015	16-13203	10-1-16	203 Sink (replacement fixture)	Initial	23.6	11-21-16	SHUT OFF***
016	16-13204	10-1-16	214B bathroom sink	Initial	2.69	11-21-16	
017A	16-13205	10-1-16	208 bathroom sink A	Initial	6.24	11-21-16	
018B		10-1-16	208 bathroom sink B	Initial	3.38	11-22-16	
019C		10-1-16	208 bathroom sink C	Initial	3.12	11-22-16	
020D		10-1-16	208 bathroom sink D	Initial	2.18	11-22-16	
021		10-1-16	209 Slop Sink	Initial	27.1	11-22-16	POSTED
022A		10-1-16	Boys bathroom west sink A	Initial	1.66	11-22-16	
022B		10-1-16	Boys bathroom west sink B	Initial	2.11	11-22-16	
024		10-1-16	2nd floor west slop sink	Initial	3.49	11-22-16	
025A		10-1-16	Girls bathroom west sink A	Initial	1.56	11-22-16	
026B		10-1-16	Girls bathroom west sink B	Initial	2.30	11-22-16	
026C		10-1-16	Girls bathroom west sink C	Initial	3.00	11-22-16	
028		10-1-16	215 Sink (replacement fixture)***	Initial	77.1	11-28-16	SHUT OFF
029		10-1-16	112 Sink (replacement fixture)	Initial	10.1	11-28-16	***
031		10-1-16	1st floor west slop sink	Initial	23.8	11-28-16	POSTED
032		10-1-16	111 Bubbler	Initial	3.02	11-28-16	
033A		10-1-16	111 Sink A	Initial	2.63	11-28-16	
034B		10-1-16	111 Sink B (or Sink 2)	Initial	2.42	11-28-16	
035		10-1-16	111 bathroom sink	Initial	4.04	11-28-16	
036		10-1-16	109 bathroom sink	Initial	3.08	11-28-16	
037		10-1-16	219 speech room sink	Initial	6.24	11-28-16	
038		10-1-16	108 bathroom sink	Initial	5.32	11-28-16	

SCHOOL 13

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
039		10-1-16	107 bathroom sink	Initial	6.63	11-28-16	
040		10-1-16	113.01 Slop Sink	Initial	4.98	11-28-16	
041		10-1-16	106A bathroom sink	Initial	4.03	11-28-16	
042		10-1-16	Staff bathroom by 119	Initial	8.36	11-28-16	
043		10-1-16	121 nurses sink	Initial	3.11	11-28-16	
044		10-1-16	Teacher's lounge sink	Initial	9.63	11-28-16	
045C		10-1-16	120 girls bathroom sink C	Initial	2.00	11-28-16	
046A		10-1-16	122.1 boys bathroom sink A	Initial	1.24	11-28-16	
047C		10-1-16	122.1 boys bathroom sink C	Initial	1.12	11-28-16	
048		10-1-16	124 Slop Sink	Initial	5.54	11-28-16	
049		10-1-16	Boiler Room bathroom sink	Initial	1.49	11-28-16	
050		10-1-16	Slop sink Rm 24 Basement	Initial	42.80	3-7-17	POSTED

OUTLETS SAMPLED	110
OUTLETS ACTIONABLE	20
OUTLETS PENDING	0
POST 9-6-16	50

- * "REPLACED & SHUT OFF" is shut off pending re-testing new fixture
- ** "RECONDITION/RE-TEST" is shut down, then flushed for 1 hour daily, 1 week prior to re-test; all testing in compliance with current regulations.
- *** Location fixture appears more than once; affecting actionable count accordingly.