

Siragusa 14

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-4758	4-15-16		Initial	5.35	4-21-16	
003	16-4760	4-15-16		Initial	LT 1.00	4-21-16	
004	16-4761	4-15-16		Initial	1.40	4-21-16	
006	16-4763	4-15-16		Initial	1.79	4-21-16	
008	16-4765	4-15-16		Initial	1.45	4-21-16	
010	16-4767	4-15-16		Initial	3.42	4-21-16	
012	16-4769	4-15-16	Faucet Coach's Office	Initial	31.6	4-21-16	SHUT OFF
013	16-4770	4-15-16	"	Flushed	3.01	4-22-16	
014	16-4771	4-15-16		Initial	4.39	4-21-16	
016	16-4773	4-15-16	Faucet Rm. 7	Initial	206	4-21-16	SHUT OFF
017	16-4774	4-15-16	"	Flushed	390	4-22-16	
018	16-4775	4-15-16		Initial	3.20	4-21-16	
020	16-4777	4-15-16		Initial	4.82	4-21-16	
022	16-4779	4-15-16		Initial	LT 1.00	4-21-16	
026	16-4781	4-15-16		Initial	1.36	4-21-16	
028	16-4783	4-15-16		Initial	3.00	4-21-16	
030	16-4785	4-15-16		Initial	1.22	4-21-16	
032	16-4787	4-15-16	Faucet # 2 Nurse's Office	Initial	60.6	4-21-16	POSTED
033	16-4788	4-15-16	"	Flushed	5.27	4-22-16	
034	16-4789	4-15-16	Faucet # 3 Nurse's Office	Initial	32.0	4-21-16	POSTED
035	16-4790	4-15-16	"	Flushed	1040	5-26-16	
036	16-4791	4-15-16		Initial	3.81	4-21-16	
038	16-4793	4-15-16		Initial	LT 1.00	4-21-16	
14-1	16-12504	9-28-16		Initial	2.40	10-10-16	
2	16-12505	9-28-16		Initial	2.41	10-10-16	
3	16-12506	9-28-16		Initial	LT 1.00	10-10-16	
4	16-12507	9-28-16	Boy's Bathrm Tap Top Flr sink 2	Initial	30.4	10-10-16	SHUT OFF
5	16-12508	9-28-16		Initial	5.42	3-1-17	
6	16-12509	9-28-16		Initial	LT 1.00	10-10-16	
7	16-12510	9-28-16		Initial	1.64	3-1-17	
8	16-12511	9-28-16		Initial	LT 1.00	10-10-16	
9	16-12512	9-28-16		Initial	3.99	3-1-17	
10	16-12513	9-28-16		Initial	1.08	10-10-16	
11	16-12514	9-28-16		Initial	LT 1.00	10-10-16	
12	16-12515	9-28-16		Initial	1.44	10-10-16	

Siragusa 14

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
13	16-12516	9-28-16		Initial	LT 1.00	10-10-16	
14	16-12517	9-28-16		Initial	1.18	10-10-16	
15	16-12518	9-28-16		Initial	3.35	10-10-16	
16	16-12519	9-28-16		Initial	1.22	10-10-16	
17	16-12520	9-28-16		Initial	1.61	10-10-16	
18	16-12521	9-28-16		Initial	1.98	10-10-16	
19	16-12522	9-28-16		Initial	LT 1.00	10-10-16	
20	16-12523	9-28-16		Initial	LT 1.00	10-10-16	
21	16-12524	9-28-16		Initial	LT 1.00	10-10-16	
22	16-12525	9-28-16		Initial	LT 1.00	10-10-16	
23	16-12526	9-28-16		Initial	14.5	10-10-16	
24	16-12642	9-28-16		Initial	1.50	10-13-16	
25	16-12643	9-28-16		Initial	LT 1.00	10-13-16	
26	16-12644	9-28-16		Initial	5.14	10-13-16	
27	16-12645	9-28-16		Initial	2.75	10-13-16	
28	16-12646	9-28-16		Initial	3.41	10-13-16	
29	16-12647	9-28-16		Initial	1.96	10-13-16	
30	16-12648	9-28-16		Initial	LT 1.00	10-13-16	
31	16-12649	9-28-16		Initial	1.62	10-13-16	
32	16-12650	9-28-16		Initial	1.00	10-13-16	
33	16-12651	9-28-16		Initial	2.01	10-13-16	
34	16-12652	9-28-16		Initial	2.24	10-13-16	

OUTLETS SAMPLED	53
OUTLETS ACTIONABLE	5
OUTLETS PENDING	0
POST 9-6-16	34