

# SCHOOL 16 ANNEX

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-3164	3-31-16	<b>Basement Service Spigot</b>	<b>Initial</b>	<b>592</b>	<b>4-2-16</b>	<b>SHUT OFF</b>
002	16-3165	3-31-16	"	Flushed	3.25	4-2-16	
003	16-3166	3-31-16	Kitchen Sink	Initial	LT 1.00	4-2-16	
004	16-3168	3-31-16	Kitchen Hand Sink	Flushed	LT 1.00	4-2-16	
005	16-3169	3-31-16	"	Initial	7.60	4-2-16	
006	16-3170	3-31-16	Faculty Rm Sink	Initial	LT 1.00	4-2-16	
007	16-3172	3-31-16	Nurse's Office	Flushed	LT 1.00	4-2-16	
008	16-3173	3-31-16	"	Initial	2.23	4-2-16	
009	16-3174	3-31-16	1st Floor by Rm 1 Bubbler	Flushed	LT 1.00	4-2-16	
010	16-3175	3-31-16	"	Initial	LT 1.00	4-2-16	
012	16-3176	3-31-16	By Rm 5 Bubbler	Initial	1.08	4-2-16	
16A-1	16-12944	10-1-16		Initial	1.17	10-26-16	
2	16-12945	10-1-16		Initial	LT 1.00	10-26-16	
3	16-12946	10-1-16		Initial	LT 1.00	10-26-16	
4	16-12947	10-1-16		Initial	7.21	10-26-16	
5	16-12948	10-1-16		Initial	4.05	10-26-16	
6	16-12949	10-1-16		Initial	1.11	10-26-16	
7	16-12950	10-1-16		Initial	3.23	10-26-16	
8	16-12951	10-1-16		Initial	2.74	10-26-16	
9	16-12952	10-1-16		Initial	LT 1.00	10-26-16	
10	16-12953	10-1-16		Initial	2.71	10-26-16	
11	16-12954	10-1-16		Initial	1.03	10-26-16	
12	16-12955	10-1-16		Initial	3.36	10-26-16	
13	16-12956	10-1-16		Initial	6.86	10-26-16	
14	16-12957	10-1-16		Initial	2.09	10-26-16	
15	16-12958	10-1-16	<b>Hose Bib outside Kitchen</b>	<b>Initial</b>	<b>58.2</b>	<b>3-7-17</b>	<b>SHUT OFF</b>
16	16-12959	10-1-16	<b>Hose Bib at rear center of Bldg.</b>	<b>Initial</b>	<b>249</b>	<b>3-7-17</b>	<b>SHUT OFF</b>
17	16-12960	10-1-16	<b>Hose Bib at rear north of Bldg.</b>	<b>Initial</b>	<b>586</b>	<b>3-7-17</b>	<b>SHUT OFF</b>
18	16-12961	10-1-16	<b>Hose Bib @ N center side of Bldg.</b>	<b>Initial</b>	<b>118</b>	<b>3-7-17</b>	<b>SHUT OFF</b>
19	16-12962	10-1-16	<b>Hose Bib @North Front of Bldg.</b>	<b>Initial</b>	<b>128</b>	<b>10-26-16</b>	<b>SHUT OFF</b>

OUTLETS SAMPLED	26
OUTLETS ACTIONABLE	6
OUTLETS PENDING	0
POST 9-6-16	19