

SCHOOL 17

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
01	16-5529	4-26-16	BUILDING SERVICE SPIGOT	Initial	26.0	5-26-16	SHUT OFF
02	16-5530	4-26-16	"	Flushed	LT 1.00	5-26-16	
03	16-5531	4-26-16		Initial	2.31	4-30-16	
05	16-5533	4-26-16		Initial	1.82	4-30-16	
07	16-5535	4-26-16		Initial	LT 1.00	4-30-16	
09	16-5537	4-26-16		Initial	6.43	4-30-16	
11	16-5539	4-26-16		Initial	10.1	5-26-16	
13	16-5541	4-26-16		Initial	1.54	4-30-16	
15	16-5543	4-26-16		Initial	2.52	5-2-16	
17	16-5545	4-26-16		Initial	LT 1.00	5-2-16	
19	16-5547	4-26-16		Initial	LT 1.00	5-2-16	
17-1	16-12789	9-30-16		Initial	4.46	10-18-16	
2	16-12790	9-30-16		Initial	LT 1.00	10-18-16	
3	16-12791	9-30-16		Initial	2.20	10-18-16	
4	16-12792	9-30-16		Initial	LT 1.00	10-18-16	
5	16-12793	9-30-16		Initial	1.18	10-18-16	
6	16-12794	9-30-16		Initial	4.56	10-18-16	
7	16-12795	9-30-16		Initial	2.08	10-18-16	
8	16-12796	9-30-16		Initial	2.65	10-18-16	
9	16-12797	9-30-16		Initial	1.36	10-18-16	
10	16-12798	9-30-16		Initial	14.4	3-1-17	
11	16-12799	9-30-16		Initial	1.68	10-18-16	
12	16-12800	9-30-16		Initial	3.16	10-18-16	
13	16-12801	9-30-16		Initial	1.43	10-18-16	
14	16-12802	9-30-16		Initial	LT 1.00	10-18-16	
15	16-12803	9-30-16		Initial	LT 1.00	10-18-16	
16	16-12804	9-30-16		Initial	LT 1.00	10-18-16	
17	16-12805	9-30-16		Initial	LT 1.00	10-18-16	
18	16-12806	9-30-16		Initial	LT 1.00	10-18-16	
19	16-12807	9-30-16		Initial	LT 1.00	10-18-16	
20	16-12808	9-30-16		Initial	1.11	10-18-16	

SCHOOL 17

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
21	16-12809	9-30-16		Initial	14.1	10-18-16	
22	16-12810	9-30-16		Initial	6.61	10-18-16	
23	16-12811	9-30-16	Boiler Rm Sink	Initial	155	3-1-17	POSTED
24	16-12812	9-30-16		Initial	1.86	10-18-16	
25	16-12813	9-30-16	Coach's Office BR faucet	Initial	61	3-1-17	POSTED
26	16-12814	9-30-16		Initial	LT 1.00	10-18-16	
27	16-12815	9-30-16		Initial	LT 1.00	10-22-16	
28	16-12816	9-30-16		Initial	1.55	10-22-16	
29	16-12817	9-30-16		Initial	LT 1.00	10-22-16	
30	16-12818	9-30-16		Initial	LT 1.00	10-22-16	
31	16-12819	9-30-16		Initial	LT 1.00	10-22-16	
32	16-12820	9-30-16	Hose Bib Front of Bldg.	Initial	998	3-1-17	SHUT OFF

OUTLETS SAMPLED	42
OUTLETS ACTIONABLE	4
OUTLETS PENDING	0
POST 9-6-16	32