

SCHOOL 21

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
01	16-5684	4-29-16	BUILDING SERVICE SPIGOT	Initial	331	5-23-16	SHUT OFF
02	16-5685	4-29-16	"	Flushed	1.41	5-24-16	
03	16-5686	4-29-16	Faucet Room 11	Initial	38.2	5-2-16	SHUT OFF
04	16-5687	4-29-16	"	Flushed	1.67	5-4-16	
05	16-5688	4-29-16		Initial	1.23	5-2-16	
07	16-5690	4-29-16		Initial	5.31	5-2-16	
09	16-5692	4-29-16		Initial	1.99	5-2-16	
11	16-5694	4-29-16		Initial	2.14	5-2-16	
13	16-5696	4-29-16		Initial	1.49	5-2-16	
15	16-5698	4-29-16		Initial	LT 1.00	5-2-16	
16	16-5699	4-29-16		Initial	LT 1.00	5-2-16	
21-1	16-12730	9-30-16		Initial	3.13	10-14-16	
2	16-12731	9-30-16		Initial	1.70	10-17-16	
3	16-12732	9-30-16		Initial	5.28	10-17-16	
4	16-12733	9-30-16		Initial	LT 1.00	10-17-16	
5	16-12734	9-30-16		Initial	LT 1.00	10-17-16	
6	16-12735	9-30-16	Slop Sink by Girl's Bathrm @ Rm 33	Initial	33.1	10-17-16	POSTED
7	16-12736	9-30-16		Initial	2.29	10-17-16	
8	16-12737	9-30-16		Initial	LT 1.00	10-17-16	
9	16-12738	9-30-16		Initial	LT 1.00	10-17-16	
10	16-12739	9-30-16		Initial	2.02	10-17-16	
11	16-12740	9-30-16		Initial	LT 1.00	10-17-16	
12	16-12741	9-30-16		Initial	1.19	10-17-16	
13	16-12742	9-30-16		Initial	1.17	10-17-16	
14	16-12743	9-30-16	Rm 20 Faucet by Window	Initial	42.4	3-1-17	POSTED
15	16-12744	9-30-16		Initial	1.28	10-17-16	
16	16-12745	9-30-16		Initial	1.42	10-17-16	
17	16-12746	9-30-16		Initial	LT 1.00	10-17-16	
18	16-12747	9-30-16		Initial	LT 1.00	10-17-16	
19	16-12748	9-30-16		Initial	LT 1.00	10-17-16	
20	16-12749	9-30-16		Initial	1.76	10-17-16	
21	16-12750	9-30-16		Initial	5.96	10-17-16	

SCHOOL 21

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
22	16-12751	9-30-16		Initial	2.11	10-17-16	
23	16-12752	9-30-16	Slop Sink Faucet Boiler Rm.	Initial	70.4	10-17-16	POSTED
24	16-12753	9-30-16		Initial	2.20	10-17-16	

OUTLETS SAMPLED	33
OUTLETS ACTIONABLE	5
OUTLETS PENDING	0
POST 9-6-16	24