

SCHOOL 23

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-6827	5-14-16		Initial	3.00	5-18-16	
003	16-6829	5-14-16		Initial	3.71	5-18-16	
005	16-6831	5-14-16		Initial	6.50	5-18-16	
007	16-6833	5-14-16		Initial	6.77	5-18-16	
009	16-6835	5-14-16		Initial	3.83	5-18-16	
011	16-6837	5-14-16		Initial	3.44	5-18-16	
013	16-6839	5-14-16	Faucet Room # 13	Initial	24.3	5-23-16	SHUT OFF
014	16-6840	5-14-16	"	Flushed	2.83	5-24-16	
015	16-6841	5-14-16	Bubbler Room 13	Initial	22.7	5-18-16	SHUT OFF
016	16-6842	5-14-16	"	Flushed	6.86	5-18-16	
017	16-6843	5-14-16		Initial	4.44	5-18-16	
019	16-6845	5-14-16		Initial	2.52	5-18-16	
021	16-6847	5-14-16	Library Faucet	Initial	15.4	5-18-16	SHUT OFF
022	16-6848	5-14-16		Flushed	1.12	5-18-16	
023	16-6849	5-14-16		Initial	1.01	5-18-16	
024	16-6850	5-14-16		Initial	1.69	5-18-16	
026	16-6852	5-14-16		Initial	1.49	5-18-16	
028	16-6854	5-14-16	Kitchen Faucet #1	Initial	22.2	5-18-16	SHUT OFF
029	16-6855	5-14-16	"	Flushed	LT 1.00	5-18-16	
030	16-6856	5-14-16		Initial	1.79	5-18-16	
032	16-6858	5-14-16		Initial	3.56	5-18-16	
23-01	16-12008	9-24-16		Initial	LT 1.00	10-3-16	
03	16-12010	9-24-16		Initial	LT 1.00	10-3-16	
05	16-12012	9-24-16		Initial	5.32	1-23-17	
07	16-12014	9-24-16		Initial	3.79	10-3-16	
09	16-12016	9-24-16		Initial	4.81	10-3-16	
11	16-12018	9-24-16	Front Entrance Slop Sink	Initial	16.9	1-23-17	POSTED
12	16-12019	9-24-16	"	Flushed	LT 1.00	1-25-17	
13	12-12020	9-24-16		Initial	LT 1.00	10-3-16	
15	16-12022	9-24-16		Initial	4.41	10-3-16	
17	16-12024	9-24-16		Initial	4.01	10-3-16	
19	16-12026	9-24-16	Faucet Rm 7	Initial	153	1-23-17	POSTED
20	16-12027	9-24-16	"	Flushed	21.0	1-25-17	"
21	16-12028	9-24-16		Initial	3.74	10-3-16	

SCHOOL 23

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
23	16-12030	9-24-16	Rm 9 Faucet	Initial	17.5	1-23-17	POSTED
24	16-12031	9-24-16	"	Flushed	1.11	1-25-17	
25	16-12032	9-24-16		Initial	2.24	10-3-16	
27	16-12034	9-24-16		Initial	1.94	10-3-16	
29	16-12036	9-24-16		Initial	3.16	10-3-16	
31	16-12038	9-24-16		Initial	2.91	10-3-16	
33A	16-12040	9-24-16		Initial	3.70	10-3-16	
35B	16-12042	9-24-16		Initial	5.15	10-3-16	
37	16-12044	9-24-16		Initial	1.71	10-3-16	
39A	16-12046	9-24-16		Initial	4.99	10-3-16	
41B	16-12048	9-24-16		Initial	2.65	10-3-16	
43C	16-12050	9-24-16		Initial	3.30	10-3-16	
45A	16-12052	9-24-16		Initial	1.56	10-3-16	
47B	16-12054	9-24-16		Initial	1.29	10-3-16	
49C	16-12056	9-24-16		Initial	1.30	10-3-16	
51D	16-12058	9-24-16		Initial	1.29	10-3-16	
53E	16-12060	9-24-16		Initial	1.06	10-3-16	
55A	16-12062	9-24-16		Initial	2.20	10-3-16	
57B	16-12064	9-24-16		Initial	1.19	10-3-16	
59	16-12066	9-24-16		Initial	7.81	1-23-17	
61	16-12068	9-24-16		Initial	LT 1.00	10-3-16	
63A	16-12070	9-24-16		Initial	4.18	10-3-16	
65B	16-12072	9-24-16		Initial	1.48	10-3-16	
67A	16-12074	9-24-16		Initial	1.67	10-3-16	
69B	16-12076	9-24-16		Initial	1.10	10-3-16	
71C	16-12078	9-24-16		Initial	1.00	10-3-16	
73A	16-12080	9-24-16		Initial	6.19	10-3-16	
75B	16-12082	9-24-16		Initial	3.30	10-3-16	
77	16-12084	9-24-16		Initial	2.93	10-3-16	

SCHOOL 23

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
79	16-12086	9-24-16	Room #1 Bathroom Faucet	Initial	18.2	10-3-16	POSTED
80	16-12087	9-24-16	"	Flushed	4.06	10-4-16	
81	16-12088	9-24-16		Initial	1.53	10-3-16	

OUTLETS SAMPLED	58
OUTLETS ACTIONABLE	8
OUTLETS PENDING	0
POST 9-6-16	41