

Paideia 24

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-4833	4-16-16		Initial	2.01	4-21-16	
003	16-4835	4-16-16		Initial	1.04	4-21-16	
005	16-4837	4-16-16		Initial	1.69	4-21-16	
007	16-4839	4-16-16		Initial	LT 1.00	4-22-16	
009	16-4841	4-16-16		Initial	LT 1.00	4-22-16	
011	16-4843	4-16-16		Initial	LT 1.00	4-22-16	
013	16-4845	4-16-16		Initial	2.64	4-22-16	
015	16-4847	4-16-16	Main Spigot	Initial	28.3	6-1-16	SHUT OFF
016	16-4848	4-16-16	"	Flushed	11.0	6-1-16	
017	16-4849	4-16-16		Initial	LT 1.00	4-22-16	
24-1A	16-12609	9-29-16		Initial	LT 1.00	10-11-16	
2B	16-12610	9-29-16		Initial	LT 1.00	10-11-16	
3	16-12611	9-28-16		Initial	LT 1.00	10-11-16	
4A	16-12612	9-28-16		Initial	LT 1.00	10-13-16	
5B	16-12613	9-28-16		Initial	LT 1.00	10-13-16	
6C	16-12614	9-28-16		Initial	LT 1.00	10-13-16	
7	16-12615	9-28-16		Initial	LT 1.00	10-13-16	
8	16-12616	9-28-16		Initial	5.98	10-13-16	
9	16-12617	9-28-16		Initial	LT 1.00	10-13-16	
10	16-12618	9-28-16		Initial	1.58	10-13-16	
11	16-12619	9-28-16		Initial	LT 1.00	10-13-16	
12	16-12620	9-28-16		Initial	2.91	10-13-16	
13	16-12621	9-28-16		Initial	LT 1.00	10-13-16	
14	16-12622	9-28-16		Initial	LT 1.00	10-13-16	
15	16-12623	9-28-16		Initial	5.90	10-13-16	
16A	16-12624	9-28-16		Initial	LT 1.00	10-13-16	
17B	16-12625	9-28-16		Initial	LT 1.00	10-13-16	
18	16-12626	9-28-16		Initial	LT 1.00	10-13-16	
19	16-12627	9-28-16		Initial	1.15	10-13-16	
20	16-12628	9-28-16		Initial	1.13	10-13-16	
21	16-12629	9-28-16		Initial	LT 1.00	10-13-16	

Paideia 24

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
22A	16-12630	9-28-16		Initial	LT 1.00	10-13-16	
23B	16-12631	9-28-16		Initial	LT 1.00	10-13-16	
24	16-12632	9-28-16		Initial	LT 1.00	10-13-16	
25	16-12633	9-28-16		Initial	LT 1.00	10-13-16	
26	16-12634	9-28-16		Initial	LT 1.00	10-13-16	
27	16-12635	9-28-16		Initial	LT 1.00	10-13-16	
28	16-12636	9-28-16		Initial	1.97	10-13-16	
29A	16-12637	9-28-16		Initial	LT 1.00	10-13-16	
30B	16-12638	9-28-16		Initial	LT 1.00	10-13-16	
31A	16-12639	9-28-16		Initial	LT 1.00	10-13-16	
32	16-12640	9-28-16		Initial	LT 1.00	10-13-16	
33	16-12641	9-28-16		Initial	11.3	10-13-16	
34	16-12601	9-28-16		Initial	LT 1.00	10-11-16	
35	16-12602	9-28-16		Initial	LT 1.00	10-11-16	
36	16-12603	9-28-16		Initial	LT 1.00	10-11-16	
37	16-12604	9-28-16		Initial	LT 1.00	10-11-16	
39	16-12606	9-28-16		Initial	LT 1.00	10-11-16	
40	16-12607	9-28-16		Initial	3.19	10-11-16	
41	16-12608	9-28-16		Initial	5.31	10-11-16	

OUTLETS SAMPLED	49
OUTLETS ACTIONABLE	1
OUTLETS PENDING	0
POST 9-6-16	40