

Westchester Hills 29

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-3724	4-6-16		Initial	9.75	4-10-16	
002	16-3725	4-6-16		Flushed	LT 1.00	4-12-16	
003	16-3726	4-6-16		Initial	7.30	6-9-16	
004	16-3727	4-6-16		Flushed	2.84	6-9-16	
005	16-3728	4-6-16		Initial	6.22	4-10-16	
007	16-3730	4-6-16		Initial	7.96	4-10-16	
009	16-3732	4-6-16		Initial	3.84	4-10-16	
011	16-3734	4-6-16		Initial	8.60	4-10-16	
013	16-3736	4-6-16	Chiller SS Fountain by old Gym	Initial	LT 1.00	4-10-16	
014	16-3737	4-6-16	Porcelian Sink Teacher's Lounge	Initial	44.9	4-10-16	SHUT OFF
015	16-3738	4-6-16	"	Flushed	2.09	4-12-16	
016	16-3739	4-6-16	Porcelian Sink Room 7	Initial	37.2	4-10-16	SHUT OFF
017	16-3740	4-6-16	"	Flushed	1.84	4-12-16	
018	16-3741	4-6-16		Initial	5.01	4-10-16	
020	16-3743	4-6-16		Initial	3.22	4-10-16	
022	16-3745	4-6-16		Initial	1.44	4-10-16	
024	16-3747	4-6-16		Initial	1.79	4-10-16	
026	16-3749	4-6-16		Initial	6.75	4-10-16	
028	16-3751	4-6-16		Initial	7.09	4-10-16	
030	16-3753	4-6-16		Initial	1.32	4-10-16	
032	16-3755	4-6-16		Initial	LT 1.00	4-10-16	
034	16-3757	4-6-16		Initial	1.56	4-10-16	
036	16-3759	4-6-16		Initial	LT 1.00	4-10-16	
038	16-3761	4-6-16		Initial	1.77	4-12-16	
040	16-3763	4-6-16		Initial	LT 1.00	4-12-16	
042	16-3765	4-6-16		Initial	LT 1.00	4-12-16	
044	16-3767	4-6-16		Initial	1.94	4-12-16	
046	16-3769	4-6-16		Initial	LT 1.00	4-12-16	
048	16-3771	4-6-16		Initial	LT 1.00	4-12-16	
050	16-3773	4-6-16		Initial	LT 1.00	4-12-16	
052	16-3775	4-6-16		Initial	LT 1.00	4-12-16	
054	16-3777	4-6-16		Initial	LT 1.00	4-12-16	
056	16-3779	4-6-16		Initial	LT 1.00	4-12-16	
058	16-3781	4-6-16		Initial	2.51	4-12-16	
060	16-3783	4-6-16		Initial	LT 1.00	4-12-16	
062	16-3785	4-6-16		Initial	2.14	4-12-16	
064	16-3787	4-6-16		Initial	LT 1.00	4-12-16	
066	16-3789	4-6-16		Initial	1.44	4-12-16	

Westchester Hills 29

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
068	16-3791	4-6-16		Initial	LT 1.00	4-12-16	
070	16-3793	4-6-16		Initial	LT 1.00	4-12-16	
072	16-3795	4-6-16		Initial	LT 1.00	6-9-16	
074	16-3797	4-6-16		Initial	1.00	4-12-16	
076	16-3799	4-6-16		Initial	LT 1.00	4-12-16	
078	16-3801	4-6-16		Initial	1.34	4-12-16	
080	16-3803	4-6-16		Initial	LT 1.00	4-12-16	
082	16-3805	4-6-16		Initial	1.29	4-12-16	
084	16-3807	4-6-16		Initial	LT 1.00	4-12-16	
086	16-3809	4-6-16		Initial	5.08	4-12-16	
088	16-3811	4-6-16		Initial	7.84	4-12-16	
090	16-3813	4-6-16		Initial	2.15	4-12-16	
092	16-3815	4-6-16		Initial	7.13	4-12-16	
094	16-3817	4-6-16		Initial	4.35	4-12-16	
096	16-3819	4-6-16		Initial	5.35	4-12-16	
098	16-3821	4-6-16		Initial	2.05	4-12-16	
100	16-3823	4-6-16		Initial	8.59	4-12-16	
102	16-3825	4-6-16		Initial	6.00	4-12-16	
104	16-3827	4-6-16		Initial	2.46	4-12-16	
106	16-3829	4-6-16		Initial	1.56	4-12-16	
108	16-3831	4-6-16		Initial	4.50	4-12-16	
110	16-3833	4-6-16		Initial	3.54	4-12-16	
112	16-3835	4-6-16		Initial	6.74	4-13-16	
29-01	16-11624	9-23-16		Initial	LT 1.00	9-27-16	
03	16-11626	9-23-16		Initial	1.00	9-27-16	
05	16-11628	9-23-16		Initial	LT 1.00	9-27-16	
07	16-11630	9-23-16		Initial	LT 1.00	9-27-16	
09	16-11632	9-23-16		Initial	2.29	9-27-16	
11	16-11634	9-23-16		Initial	LT 1.00	9-27-16	
13	16-11636	9-23-16		Initial	1.16	9-27-16	
15	16-11638	9-23-16		Initial	LT 1.00	9-27-16	
17	16-11640	9-23-16		Initial	3.69	9-27-16	
19	16-11642	9-23-16		Initial	LT 1.00	9-27-16	
21	16-11644	9-23-16		Initial	1.63	9-27-16	
23	16-11646	9-23-16		Initial	1.31	9-27-16	

Westchester Hills 29

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
25	16-11648	9-23-16		Initial	LT 1.00	9-27-16	
27	16-11650	9-23-16		Initial	LT 1.00	9-27-16	
29	16-11652	9-23-16		Initial	LT 1.00	9-27-16	
31	16-11654	9-23-16		Initial	LT 1.00	9-27-16	
33	16-11656	9-23-16		Initial	1.48	9-27-16	
35	16-11658	9-23-16		Initial	1.11	9-27-16	
37	16-11660	9-23-16		Initial	LT 1.00	9-27-16	
39	16-11662	9-23-16		Initial	1.75	9-27-16	
41	16-11664	9-23-16		Initial	1.68	9-27-16	
43	16-11666	9-23-16		Initial	LT 1.00	9-27-16	
45	16-11668	9-23-16		Initial	LT 1.00	9-27-16	
47	16-11670	9-23-16		Initial	LT 1.00	9-27-16	
49	16-11672	9-23-16		Initial	1.01	9-27-16	
51	16-11674	9-23-16		Initial	1.87	9-27-16	
53	16-11676	9-23-16		Initial	11.8	9-29-16	
55	16-11678	9-23-16		Initial	1.10	9-29-16	
57	16-11680	9-23-16		Initial	LT 1.00	9-29-16	
59	16-11682	9-23-16		Initial	4.91	9-29-16	
61	16-11684	9-23-16		Initial	LT 1.00	9-29-16	
63	16-11686	9-23-16		Initial	1.05	9-29-16	
65	16-11688	9-23-16		Initial	2.08	9-29-16	
67	16-11690	9-23-16		Initial	3.97	9-29-16	
69	16-11692	9-23-16		Initial	LT 1.00	9-29-16	
71	16-11694	9-23-16		Initial	1.38	9-29-16	
73	16-11696	9-23-16		Initial	LT 1.00	9-29-16	
75	16-11698	9-23-16		Initial	LT 1.00	9-29-16	
77	16-11700	9-23-16		Initial	7.93	9-29-16	
79	16-11702	9-23-16	Asst. Principal's Office North	Initial	111	9-29-16	POSTED
80	16-11703	9-23-16	"	Flushed	LT 1.00	9-29-16	
81	16-11704	9-23-16		Initial	1.94	9-29-16	
83	16-11706	9-23-16		Initial	1.30	9-29-16	
85	16-11708	9-23-16		Initial	1.67	9-29-16	

Westchester Hills 29

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
87	16-11710	9-23-16		Initial	1.95	9-29-16	
89	16-11712	9-23-16	Hose Bib Courtyard	Initial	21.9	9-29-16	SHUT OFF
90	16-11713	9-23-16	"	Flushed	LT 1.00	9-29-16	
91	16-11714	9-23-16	Hose Bib Croydon Road	Initial	873	1-23-17	SHUT OFF
92	16-11715	9-23-16	"	Flushed	142	1-23-17	

OUTLETS SAMPLED	103
OUTLETS ACTIONABLE	5
OUTLETS PENDING	0
POST 9-6-16	46