

SCHOOL 30

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-6101	5-6-16		Initial	2.01	5-11-16	
003	16-6103	5-6-16		Initial	6.56	5-11-16	
005	16-6105	5-6-16		Initial	LT 1.00	5-11-16	
007	16-6107	5-6-16		Initial	3.44	5-11-16	
009	16-6109	5-6-16		Initial	LT 1.00	5-11-16	
011	16-6111	5-6-16		Initial	LT 1.00	5-11-16	
013	16-6113	5-6-16		Initial	4.11	5-11-16	
015	16-6115	5-6-16		Initial	1.93	5-11-16	
017	16-6117	5-6-16		Initial	7.70	5-23-16	
019	16-6119	5-6-16		Initial	3.52	5-11-16	
021	16-6121	5-6-16		Initial	2.53	5-11-16	
023	16-6123	5-6-16		Initial	1.26	5-11-16	
025	16-6125	5-6-16	Faucet Room 14	Initial	33.3	5-11-16	POSTED
026	16-6126	5-6-16	"	Flushed	LT 1.00	5-12-16	
027	16-6127	5-6-16		Initial	1.71	5-23-16	
029	16-6129	5-6-16		Initial	LT 1.00	5-11-16	
031	16-6131	5-6-16		Initial	1.38	5-11-16	
033	16-6133	5-6-16		Initial	1.39	5-11-16	
30-1	16-12653	9-29-16		Initial	3.84	10-13-16	
2	16-12654	9-29-16		Initial	LT 1.00	10-13-16	
3	16-12655	9-29-16		Initial	LT 1.00	10-13-16	
4	16-12656	9-29-16		Initial	1.08	10-13-16	
5	16-12657	9-29-16		Initial	2.08	10-13-16	
6	16-12658	9-29-16		Initial	LT 1.00	10-13-16	
7	16-12659	9-29-16		Initial	2.43	10-13-16	
8	16-12660	9-29-16		Initial	7.79	10-13-16	
9	16-12661	9-29-16		Initial	7.77	10-13-16	
10	16-12662	9-29-16		Initial	1.85	10-13-16	
11	16-12663	9-29-16		Initial	2.78	10-13-16	
12	16-12664	9-29-16		Initial	1.40	10-13-16	
13	16-12665	9-29-16		Initial	11.1	10-13-16	
14	16-12666	9-29-16		Initial	7.93	10-13-16	

SCHOOL 30

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
15	16-12667	9-29-16		Initial	3.98	10-13-16	
16	16-12668	9-29-16		Initial	2.22	10-13-16	
17	16-12669	9-28-16	Girls Bthrm sink1 by Rock Rm	Initial	33.1	3-1-17	POSTED
18	16-12670	9-29-16		Initial	1.35	10-13-16	
19	16-12671	9-29-16	Slop Sink by Rock Rm.	Initial	16.0	10-13-16	POSTED
20	16-12672	9-29-16		Initial	1.03	10-13-16	
21	16-12673	9-29-16		Initial	1.59	10-14-16	
22	16-12674	9-29-16		Initial	10.3	10-14-16	
23	16-12675	9-29-16		Initial	LT 1.00	10-14-16	
24	16-12676	9-29-16		Initial	1.23	10-14-16	
25	16-12677	9-29-16		Initial	7.71	10-14-16	
26	16-12678	9-29-16		Initial	1.16	10-14-16	
27	16-12679	9-29-16		Initial	3.07	10-14-16	
28	16-12680	9-29-16		Initial	LT 1.00	10-14-16	
29	16-12681	9-29-16	Bubbler Rm 19	Initial	32.3	10-14-16	SHUT OFF
30	16-12682	9-29-16		Initial	1.33	10-14-16	
31	16-12683	9-29-16	Faucet Rm 16	Initial	31.8	10-14-16	POSTED
32	16-12684	9-29-16		Initial	6.37	10-14-16	
33	16-12685	9-29-16		Initial	1.13	10-14-16	
34	16-12686	9-29-16		Initial	LT 1.00	10-14-16	
35	16-12687	9-29-16		Initial	LT 1.00	10-14-16	
36	16-12688	9-29-16		Initial	1.15	10-14-16	
37	16-12689	9-29-16		Initial	1.45	10-14-16	
38	16-12690	9-29-16		Initial	LT 1.00	10-14-16	
39	16-12691	9-29-16		Initial	LT 1.00	10-14-16	
40	16-12692	9-29-16		Initial	2.78	10-14-16	
41	16-12693	9-29-16		Initial	LT 1.00	10-14-16	
42	16-12694	9-29-16		Initial	1.10	10-14-16	
43	16-12695	9-29-16		Initial	2.51	10-14-16	
44	16-12696	9-29-16		Initial	2.62	10-14-16	
45	16-12697	9-29-16		Initial	LT 1.00	10-14-16	
46	16-12698	9-29-16		Initial	LT 1.00	10-14-16	
47	16-12699	9-29-16		Initial	LT 1.00	10-14-16	

SCHOOL 30

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
48	16-12700	9-29-16	Hose Bib by Gym	Initial	122.0	10-14-16	SHUT OFF
49	16-12701	9-29-16		Initial	6.66	10-14-16	

OUTLETS SAMPLED	66
OUTLETS ACTIONABLE	6
OUTLETS PENDING	0
POST 9-6-16	49