

CROSS HILL ACADEMY

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-3655	4-6-16	Bubbler #1(L) 2nd Fl. Hall by Bathroom	Initial	LT 1.00	4-9-16	
003	16-3657	4-6-16	Bubbler #2(R) 2nd Fl. Hall by Bathroom	Initial	LT 1.00	4-9-16	
005	16-3659	4-6-16	Bubbler #1(L) 1st Fl. Hall by T18	Initial	LT 1.00	4-9-16	
007	16-3661	4-6-16	Bubbler #2(R) 1st Fl. Hall by T18	Initial	1.15	4-9-16	
009	16-3663	4-6-16	Faucet Rm 101	Initial	3.48	4-9-16	
011	16-3665	4-6-16	Faucet Rm 102	Initial	22.0	4-9-16	SHUT OFF
012	16-3666	4-6-16	"	Flushed	17.5	4-9-16	
013	16-3667	4-6-16	Faucet Rm 103	Initial	7.13	4-9-16	
015	16-3669	4-6-16	Faucet Rm 104	Initial	7.75	4-9-16	
017	16-3671	4-6-16	Faucet Rm 105A	Initial	3.62	4-9-16	
019	16-3673	4-6-16	Faucet Rm 106	Initial	5.77	4-9-16	
021	16-3675	4-6-16	Faucet Rm 107	Initial	3.81	4-9-16	
023	16-3677	4-6-16	Faucet Rm 110	Initial	55.6	4-9-16	SHUT OFF
024	16-3678	4-6-16	"	Flushed	7.67	4-10-16	
025	16-3679	4-6-16	Faucet Rm 109	Initial	23.1	4-9-16	SHUT OFF
026	16-3680	4-6-16	"	Flushed	1.24	4-10-16	
027	16-3681	4-6-16	Faucet Rm 114	Initial	8.28	4-9-16	
029	16-3683	4-6-16	Faucet Rm 113A	Initial	676	6-9-16	SHUT OFF
030	16-3684	4-6-16	"	Flushed	15.8	6-10-16	
031	16-3685	4-6-16	Faucet Rm 111	Initial	66.3	4-9-16	SHUT OFF
032	16-3686	4-6-16	"	Flushed	6.40	4-10-16	
033	16-3687	4-6-16	Faucet Rm 112	Initial	1.57	4-9-16	
035	16-3689	4-6-16	Kitchen Faucet North	Initial	2.12	6-9-16	SHUT OFF
036	16-3690	4-6-16	"	Flushed	104	6-9-16	
037	16-3691	4-6-16	Kitchen South faucet	Initial	1.56	4-9-16	
039	16-3693	4-6-16	Kitchen Faucet #3 Left	Initial	164	6-9-16	SHUT OFF
040	16-3694	4-6-16	"	Flushed	12.3	6-10-16	
041	16-3695	4-6-16	Faucet Nurses Office	Initial	4.94	4-9-16	
043	16-3697	4-6-16	Faucet Rm 115	Initial	10.5	4-9-16	
045	16-3699	4-6-16	Faucet Assit. Principal's Office	Initial	1.48	4-9-16	
047	16-3701	4-6-16	Faucet Rm 132	Initial	4.41	4-9-16	
049	16-3703	4-6-16	Main Office Kitchen	Initial	4.17	6-9-16	
050	16-3704	4-6-16	"	Flushed	4.58	6-9-16	
052	16-3706	4-6-16	Bubbler #1(L) Hallway by Rm 120	Initial	1.32	4-9-16	
051	16-3705	4-6-16	"	Flushed	1.36	4-12-16	
053	16-3707	4-6-16	Bubbler #2(R) Hallway by Rm 120	Initial	1.08	4-9-16	

CROSS HILL ACADEMY

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
055	16-3709	4-6-16	Faucet #1 Teacher's Lounge	Initial	9.06	4-9-16	
057	16-3711	4-6-16	Faucet #2 Teacher's Lounge	Initial	3.59	4-9-16	
059	16-3713	4-6-16	Faucet Rm 2	Initial	1.96	4-9-16	
061	16-3715	4-6-16	Faucet Rm 6	Initial	201	4-9-16	SHUT OFF
062	16-3716	4-6-16	"	Flushed	2230	4-10-16	
063	16-3717	4-6-16	Chiller Cafeteria-Tech.	Initial	4.10	4-9-16	
064	16-3718	4-6-16	Faucet Rm 113	Initial	LT 1.00	4-10-16	
066	16-3720	4-6-16	Bubbler Gym	Initial	LT 1.00	4-10-16	
068	16-3722	4-6-16	Water Main Spigot	Initial	735	6-9-16	SHUT OFF
069	16-3723	4-6-16	"	Flushed	90.6	6-9-16	
CH-1	16-12850	10-1-16		Initial	1.23	10-22-16	
2	16-12851	10-1-16		Initial	2.25	10-22-16	
3	16-12852	10-1-16		Initial	1.66	10-22-16	
4	16-12853	10-1-16		Initial	2.81	10-22-16	
5	16-12854	10-1-16		Initial	3.30	10-22-16	
6	16-12855	10-1-16		Initial	3.43	10-22-16	
7	16-12856	10-1-16		Initial	2.11	10-22-16	
8	16-12857	10-1-16		Initial	6.20	10-22-16	
9	16-12858	10-1-16		Initial	8.91	10-22-16	
10	16-12859	10-1-16		Initial	8.90	10-22-16	
11	16-12860	10-1-16		Initial	8.31	10-22-16	
12	16-12861	10-1-16		Initial	10.9	10-22-16	
13	16-12862	10-1-16		Initial	5.35	10-22-16	
14	16-12863	10-1-16	Faucet Rm 219 Rear of Room	Initial	18.6	10-22-16	SHUT OFF
15	16-12864	10-1-16		Initial	2.58	10-22-16	
16	16-12865	10-1-16		Initial	3.16	10-22-16	
17	16-12866	10-1-16		Initial	13.0	10-22-16	
18	16-12867	10-1-16	Slop Sink 1st Fl. Rm T13	Initial	135	10-22-16	POSTED
19	16-12868	10-1-16		Initial	3.25	10-22-16	
20	16-12869	10-1-16		Initial	3.08	10-22-16	
21	16-12870	10-1-16		Initial	5.37	10-22-16	
22	16-12871	10-1-16		Initial	10.8	10-22-16	
23	16-12872	10-1-16		Initial	3.04	10-22-16	
24	16-12873	10-1-16		Initial	4.90	10-22-16	

CROSS HILL ACADEMY

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
25	16-12874	10-1-16		Initial	9.03	10-24-16	
26	16-12875	10-1-16		Initial	10.0	10-24-16	
27	16-12876	10-1-16		Initial	2.02	10-24-16	
28	16-12877	10-1-16		Initial	3.42	10-24-16	
29	16-12878	10-1-16		Initial	2.27	10-24-16	
30	16-12879	10-1-16		Initial	3.27	10-24-16	
31	16-12880	10-1-16		Initial	2.68	10-24-16	
32	16-12881	10-1-16		Initial	1.07	10-24-16	
33	16-12882	10-1-16		Initial	1.27	10-24-16	
34	16-12883	10-1-16		Initial	2.94	10-24-16	
35	16-12884	10-1-16		Initial	3.38	10-24-16	
36	16-12885	10-1-16		Initial	2.24	10-24-16	
37	16-12886	10-1-16		Initial	2.65	10-24-16	
38	16-12887	10-1-16		Initial	2.10	10-24-16	
39	16-12888	10-1-16		Initial	3.54	10-24-16	
40	16-12889	10-1-16	Girl's Locker Rm. Sink 1	Initial	80.4	3-1-17	SHUT OFF
41	16-12890	10-1-16	Girl's Locker Room Sink 2	Initial	53.2	3-7-17	SHUT OFF
42	16-12891	10-1-16	Girl's Locker Room Sink 3	Initial	25.3	3-7-17	SHUT OFF
43	16-12892	10-1-16		Initial	6.86	3-7-17	
44	16-12893	10-1-16		Initial	3.11	10-24-16	
45	16-12894	10-1-16		Initial	2.81	10-24-16	
46	16-12895	10-1-16		Initial	3.12	10-24-16	
47	16-12896	10-1-16		Initial	1.38	10-24-16	
48	16-12897	10-1-16		Initial	2.20	10-24-16	
49	16-12898	10-1-16		Initial	2.33	10-24-16	
50	16-12899	10-1-16		Initial	1.88	10-24-16	
51	16-12900	10-1-16		Initial	14.6	10-24-16	
52	16-12901	10-1-16		Initial	6.67	10-24-16	
53	16-12902	10-1-16		Initial	10.4	10-24-16	
53	16-12903	10-1-16		Initial	7.36	10-24-16	
55	16-12904	10-1-16	RM TB1 Wm's Bathr sink #3	Initial	18.1	10-24-16	SHUT OFF
56	16-12905	10-1-16		Initial	9.29	3-7-17	
57	16-12906	10-1-16		Initial	3.52	10-24-16	
58	16-12907	10-1-16		Initial	11.3	10-24-16	
59	16-12908	10-1-16		Initial	5.57	10-24-16	

CROSS HILL ACADEMY

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
60	16-12909	10-1-16	Boy's Locker Room BR Sink 3	Initial	15.1	3-7-17	SHUT OFF
61	16-12910	10-1-16		Initial	2.42	10-24-16	
62	16-12911	10-1-16		Initial	2.06	10-24-16	
63	16-12912	10-1-16		Initial	2.29	10-24-16	
64	16-12913	10-1-16	Hose Bib @ Frnt of Auditorium	Initial	354	10-24-16	SHUT OFF

OUTLETS SAMPLED	99
OUTLETS ACTIONABLE	17
OUTLETS PENDING	0
POST 9-6-16	64