

RIVERSIDE HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

| BOE ID# | Lab ID # | Date of Collection | Sample Description | Initial / Flushed | Lead Concentration ug/L | Date of Analysis | ACTION TAKEN |
|---------|----------|--------------------|--------------------|-------------------|-------------------------|------------------|--------------|
| 001 | 16-4100 | 4-9-16 | Main Spigot | Initial | 441 | 6-3-16 | SHUT OFF |
| 002 | 16-4101 | 4-9-16 | " | Flushed | 1.04 | 6-5-16 | |
| 003 | 16-4102 | 4-9-16 | | Initial | 2.79 | 4-14-16 | |
| 005 | 16-4104 | 4-9-16 | | Initial | LT 1.00 | 4-14-16 | |
| 007 | 16-4106 | 4-9-16 | | Initial | 6.46 | 4-14-16 | |
| 009 | 16-4108 | 4-9-16 | | Initial | 1.40 | 4-15-16 | |
| 011 | 16-4110 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 013 | 16-4112 | 4-9-16 | | Initial | 2.53 | 6-3-16 | |
| 015 | 16-4114 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 017 | 16-4116 | 4-9-16 | | Initial | 1.75 | 4-15-16 | |
| 019 | 16-4118 | 4-9-16 | | Initial | 3.61 | 4-15-16 | |
| 021 | 16-4120 | 4-9-16 | | Initial | 1.31 | 4-15-16 | |
| 023 | 16-4122 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 025 | 16-4124 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 026 | 16-4125 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 028 | 16-4127 | 4-9-16 | | Initial | 1.27 | 4-15-16 | |
| 030 | 16-4129 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 031 | 16-4130 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| 032 | 16-4131 | 4-9-16 | | Initial | LT 1.00 | 4-15-16 | |
| RS HS-1 | 16-14484 | 10-22-16 | | Initial | LT 1.00 | 1-19-17 | |
| 2 | 16-14485 | 10-22-16 | | Initial | LT 1.00 | 1-19-17 | |
| 3 | 16-14486 | 10-22-16 | | Initial | 1.06 | 1-19-17 | |
| 4 | 16-14487 | 10-22-16 | | Initial | 2.66 | 1-19-17 | |
| 5 | 16-14488 | 10-22-16 | | Initial | LT 1.00 | 1-19-17 | |
| 6 | 16-14489 | 10-22-16 | | Initial | 1.51 | 1-19-17 | |
| 7 | 16-14490 | 10-22-16 | | Initial | LT 1.00 | 1-19-17 | |
| 8 | 16-14491 | 10-22-16 | | Initial | 1.11 | 1-19-17 | |
| 9 | 16-14492 | 10-22-16 | | Initial | LT 1.00 | 1-19-17 | |
| 10 | 16-14493 | 10-22-16 | | Initial | LT 1.00 | 1-19-17 | |
| 11 | 16-14494 | 10-22-16 | | Initial | 3.58 | 1-20-17 | |
| 12 | 16-14495 | 10-22-16 | | Initial | 6.09 | 1-20-17 | |
| 13 | 16-14496 | 10-22-16 | | Initial | 3.04 | 1-20-17 | |
| 14 | 16-14497 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 15 | 16-14498 | 10-22-16 | | Initial | 2.11 | 1-20-17 | |
| 16 | 16-14499 | 10-22-16 | | Initial | 10.1 | 1-20-17 | |
| 17 | 16-14500 | 10-22-16 | | Initial | 14.4 | 1-20-17 | |

RIVERSIDE HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

| BOE ID# | Lab ID # | Date of Collection | Sample Description | Initial / Flushed | Lead Concentration ug/L | Date of Analysis | ACTION TAKEN |
|---------|----------|--------------------|--------------------|-------------------|-------------------------|------------------|--------------|
| 18 | 16-14501 | 10-22-16 | | Initial | 3.14 | 1-20-17 | |
| 19 | 16-14502 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 20 | 16-14503 | 10-22-16 | | Initial | 7.35 | 1-20-17 | |
| 21 | 16-14504 | 10-22-16 | | Initial | 1.32 | 1-20-17 | |
| 22 | 16-14505 | 10-22-16 | | Initial | 1.31 | 1-20-17 | |
| 23 | 16-14506 | 10-22-16 | | Initial | 3.03 | 1-20-17 | |
| 24 | 16-14507 | 10-22-16 | | Initial | 1.72 | 1-20-17 | |
| 25 | 16-14508 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 26 | 16-14509 | 10-22-16 | | Initial | 4.95 | 1-20-17 | |
| 27 | 16-14510 | 10-22-16 | | Initial | 1.52 | 1-20-17 | |
| 28 | 16-14511 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 29 | 16-14512 | 10-22-16 | | Initial | 9.03 | 1-20-17 | |
| 30 | 16-14513 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 31 | 16-14514 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 32 | 16-14515 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 33 | 16-14516 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 34 | 16-14517 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 35 | 16-14518 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 36 | 16-14519 | 10-22-16 | | Initial | 1.92 | 1-20-17 | |
| 37 | 16-14520 | 10-22-16 | | Initial | 3.20 | 1-20-17 | |
| 38 | 16-14521 | 10-22-16 | | Initial | 2.68 | 1-20-17 | |
| 39 | 16-14522 | 10-22-16 | | Initial | LT 1.00 | 1-20-17 | |
| 40 | 16-14523 | 10-22-16 | | Initial | LT 1.00 | 3-20-17 | |

| | |
|--------------------|----|
| OUTLETS SAMPLED | 58 |
| OUTLETS ACTIONABLE | 1 |
| OUTLETS PENDING | 0 |
| POST 9-6-16 | 40 |