

LINCOLN

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-5301	4-23-16		Initial	10.2	4-24-16	
003	16-5303	4-23-16	Faucet Rm. 31A	Initial	50.8	5-26-16	SHUT OFF
004	16-5304	4-23-16	"	Flushed	36.9	5-26-16	
005	16-5305	4-23-16		Initial	12.7	5-26-16	
007	16-5307	4-23-16		Initial	7.61	4-24-16	
008	16-5308	4-23-16		Flushed	1.19	4-30-16	
009	16-5309	4-23-16		Initial	2.15	4-24-16	
011	16-5311	4-23-16		Initial	2.61	4-24-16	
013	16-5313	4-23-16		Initial	1.74	4-24-16	
015	16-5315	4-23-16		Flushed	LT 1.00	4-24-16	
016	16-5316	4-23-16		Initial	2.31	4-24-16	
017	16-5317	4-23-16		Initial	2.10	4-24-16	
019	16-5319	4-23-16		Initial	LT 1.00	4-24-16	
021	16-5321	4-23-16		Initial	LT 1.00	4-24-16	
023	16-5323	4-23-16		Initial	4.75	4-24-16	
025	16-5325	4-23-16	Faucet Room 147	Initial	17.1	4-24-16	SHUT OFF
026	16-5326	4-23-16		Flushed	2.25	4-30-16	
027	16-5327	4-23-16		Initial	4.56	4-24-16	
029	16-5329	4-23-16		Initial	1.26	4-14-16	
031	16-5331	4-23-16	Faucet #2 Rm 151	Initial	197	4-24-16	SHUT OFF
031B	16-5332	4-23-16	"	Flushed	4.34	4-30-16	
032	16-5333	4-23-16	Fountain #1 Rm 153	Initial	16.9	4-24-16	SHUT OFF
033	16-5334	4-23-16	"	Flushed	1.36	4-30-16	
034	16-5335	4-23-16	Faucet#2 Room 153	Initial	17.4	4-24-16	SHUT OFF
035	16-5336	4-23-16		Flushed	6.34	4-30-16	
036	16-5337	4-23-16		Initial	LT 1.00	4-24-16	
038	16-5339	4-23-16		Initial	LT 1.00	4-24-16	
039	16-5340	4-23-16		Initial	1.53	4-24-16	
041	16-5342	4-23-16		Initial	11.7	4-30-16	
043	16-5344	4-23-16		Initial	LT 1.00	5-26-16	
045	16-5346	4-23-16		Initial	1.40	4-30-16	
047	16-5348	4-23-16		Initial	1.48	4-30-16	
049	16-5350	4-23-16		Initial	1.48	4-30-16	
051	16-5352	4-23-16		Initial	10.4	5-26-16	
053	16-5354	4-23-16		Initial	9.92	5-26-16	
055	16-5356	4-23-16		Initial	10.2	5-26-16	
057	16-5358	4-23-16		Initial	LT 1.00	4-30-16	
059	16-5360	4-23-16		Initial	8.44	4-30-16	

LINCOLN

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
061	16-5362	4-23-16		Initial	3.25	4-30-16	
063	16-5364	4-23-16	Faucet Rm. 241	Initial	92.0	5-26-16	SHUT OFF
064	16-5365	4-23-16	"	Flushed	3.44	5-26-16	
065	16-5366	4-23-16	Faucet Rm. 243	Initial	33.0	4-30-16	SHUT OFF
066	16-5367	4-23-16	"	Flushed	2.31	5-2-16	
067	16-5368	4-23-16		Initial	5.87	4-30-16	
069	16-5370	4-23-16	Faucet Rm. 244	Initial	17.6	4-30-16	SHUT OFF
070	16-5371	4-23-16	"	Flushed	LT 1.00	5-2-16	
071	16-5372	4-23-16		Initial	LT 1.00	4-30-16	
073	16-5374	4-23-16		Initial	12.9	4-30-16	
075	16-5376	4-23-16		Initial	2.65	4-30-16	
077	16-5378	4-23-16		Initial	7.41	4-30-16	
079	16-5380	4-23-16		Initial	LT 1.00	4-30-16	
081	16-5382	4-23-16		Initial	12.5	4-30-16	
083	16-5384	4-23-16		Initial	2.00	4-30-16	
085	16-5386	4-23-16	Faucet Rm. 221	Initial	66.5	4-30-16	SHUT OFF
086	16-5387	4-23-16	"	Flushed	LT 1.00	5-2-16	
087	16-5388	4-23-16		Initial	LT 1.00	4-30-16	
089	16-5390	4-23-16		Initial	LT 1.00	4-30-16	
092	16-5393	4-23-16		Initial	LT 1.00	4-30-16	
093	16-5394	4-23-16		Initial	8.50	4-30-16	
095	16-5396	4-23-16	Bubbler Rm. 331	Initial	77.8	5-26-16	SHUT OFF
096	16-5397	4-23-16	"	Flushed	LT 1.00	5-26-16	
097	16-5398	4-23-16		Initial	LT 1.00	4-30-16	
099	16-5400	4-23-16	Faucet Rm. 305	Initial	78.7	5-26-16	SHUT OFF
100	16-5401	4-23-16	"	Flushed	49.2	5-26-16	
101	16-5402	4-23-16	Faucet Rm 307	Initial	27.5	4-30-16	SHUT OFF
102	16-5403	4-23-16	"	Flushed	5.49	5-2-16	
103	16-5404	4-23-16	Faucet Rm. 309	Initial	22.9	4-30-16	SHUT OFF
104	16-5405	4-23-16	"	Flushed	5.02	5-2-16	
105	16-5406	4-23-16		Initial	LT 1.00	4-30-16	
107	16-5408	4-23-16		Initial	14.4	4-30-16	
109	16-5410	4-23-16		Initial	14.5	4-30-16	
111	16-5412	4-23-16		Initial	11.9	5-26-16	
113	16-5414	4-23-16		Initial	3.40	4-30-16	
115	16-5416	4-23-16	Faucet Rm. 332	Initial	29.9	4-30-16	SHUT OFF
116	16-5417	4-23-16	"	Flushed	3.75	5-2-16	

LINCOLN

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
LIN--001	16-13829	10-15-16		Initial	2.09	12-1-16	
02-1	16-13830	10-15-16		Initial	LT 1.00	12-1-16	
03-2	16-13831	10-15-16		Initial	1.49	12-1-16	
04-3	16-13832	10-15-16		Initial	1.77	12-1-16	
05-1	16-13833	10-15-16		Initial	1.22	12-1-16	
06-2	16-13834	10-15-16		Initial	1.49	12-1-16	
07-1	16-13835	10-15-16		Initial	3.52	12-1-16	
08-2	16-13836	10-15-16		Initial	1.13	12-1-16	
09-3	16-13837	10-15-16		Initial	4.64	3-10-17	
10	16-13838	10-15-16		Initial	1.86	12-1-16	
11	16-13839	10-15-16	Slop sink opposite 310	Initial	31.8	3-10-17	POSTED
12-1	16-13840	10-15-16		Initial	1.57	12-1-16	
13-2	16-13841	10-15-16		Initial	2.19	12-1-16	
14-3	16-13842	10-15-16		Initial	2.42	12-1-16	
15-1	16-13843	10-15-16		Initial	1.40	12-1-16	
16-2	16-13844	10-15-16		Initial	1.62	12-1-16	
17-3	16-13845	10-15-16		Initial	6.99	12-1-16	
18-1	16-13846	10-15-16		Initial	1.72	12-1-16	
19	16-13847	10-15-16	Slop sink opp. stairwell G	Initial	16.4	12-1-16	POSTED
20	16-13848	10-15-16	2nd Fl. Slop sink next to Elev.	Initial	16.2	3-10-17	POSTED
21-1	16-13849	10-15-16		Initial	3.35	12-2-16	
22-3	16-13850	10-15-16		Initial	1.56	12-2-16	
23-5	16-13851	10-15-16		Initial	1.56	12-2-16	
24-1	16-13852	10-15-16		Initial	1.87	12-2-16	
25-2	16-13853	10-15-16		Initial	1.20	12-2-16	
26-1	16-13854	10-15-16		Initial	1.07	12-2-16	
27-2	16-13855	10-15-16		Initial	1.73	12-2-16	
28-3	16-13856	10-15-16		Initial	1.10	12-2-16	
29	16-13857	10-15-16		Initial	2.28	12-2-16	
30	16-13858	10-15-16	2nd Fl. Slop sink near stairw. F	Initial	38.4	3-10-17	POSTED
31-3	16-13859	10-15-16		Initial	1.04	12-2-16	
32-1	16-13860	10-15-16		Initial	LT 1.00	12-2-16	
33-1	16-13861	10-15-16		Initial	LT 1.00	12-2-16	
34-2	16-13862	10-15-16		Initial	3.31	3-10-17	
35	16-13863	10-15-16		Initial	LT 1.00	12-2-16	
36	16-13864	10-15-16		Initial	3.39	12-2-16	
37-1	16-13865	10-15-16		Initial	1.43	12-2-16	
38-2	16-13866	10-15-16		Initial	1.73	12-2-16	

LINCOLN

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
39-1	16-13867	10-15-16		Initial	LT 1.00	12-2-16	
40	16-13868	10-15-16		Initial	1.57	12-2-16	
41	16-13869	10-15-16		Initial	LT 1.00	12-2-16	
42	16-13870	10-15-16		Initial	LT 1.00	12-2-16	
43	16-13871	10-15-16		Initial	4.53	12-2-16	
44-1	16-13872	10-15-16	Boy's BR Rm 259	Initial	18.9	3-10-17	POSTED
45-2	16-13873	10-15-16	Boy's BR Rm 259	Initial	54.6	3-10-17	POSTED
46-1	16-13874	10-15-16		Initial	1.35	12-2-16	
47-2	16-13875	10-15-16		Initial	4.58	12-2-16	
48	16-13876	10-15-16		Initial	2.67	3-10-17	
49	16-13877	10-15-16		Initial	LT 1.00	12-2-16	
50	16-13878	10-15-16		Initial	LT 1.00	12-2-16	
51	16-13879	10-15-16		Initial	6.23	3-10-17	
52-1	16-13880	10-15-16		Initial	LT 1.00	12-2-16	
53-3	16-13881	10-15-16		Initial	3.05	12-2-16	
54-4	16-13882	10-15-16		Initial	1.01	12-2-16	
55-5	16-13883	10-15-16		Initial	LT 1.00	12-2-16	
56-6	16-13884	10-15-16		Initial	LT 1.00	12-2-16	
57-1	16-13885	10-15-16		Initial	5.42	3-10-17	
58-2	16-13886	10-15-16		Initial	5.17	3-10-17	
59-3	16-13887	10-15-16		Initial	LT 1.00	12-3-16	
60	16-13888	10-15-16		Initial	5.59	12-3-16	
61	16-13889	10-15-16		Initial	4.71	12-3-16	
62	16-13890	10-15-16	Rm. 152 Rear Station	Initial	18.8	12-3-16	SHUT OFF
63	16-13891	10-15-16		Initial	3.84	12-3-16	
64	16-13892	10-15-16	Rm 152 Front, Teacher's	Initial	175	12-3-16	SHUT OFF
65	16-13893	10-15-16	Rm. 153	Initial	79.6	12-3-16	SHUT OFF
66	16-13894	10-15-16		Initial	LT 1.00	12-3-16	
67-1	16-13895	10-15-16	Rm. 114 sink	Initial	509	12-3-16	SHUT OFF
68-2	16-13896	10-15-16	Rm. 114 sink	Initial	178	12-3-16	SHUT OFF
69	16-13897	10-15-16	Rm 115 sink	Initial	109	12-3-16	SHUT OFF
70	16-13898	10-15-16		Initial	3.84	12-3-16	
71	16-13899	10-15-16		Initial	5.43	12-3-16	
72-1	16-13900	10-15-16		Initial	1.31	12-3-16	
73-2	16-13901	10-15-16		Initial	1.49	12-3-16	
74	16-13902	10-15-16		Initial	1.42	12-3-16	
75	16-13903	10-15-16		Initial	1.17	12-3-16	

NY Lab ID No. 10176

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
76-1	16-13904	10-15-16		Initial	1.18	12-3-16	
77	16-13905	10-15-16		Initial	2.69	12-3-16	
78-1	16-13906	10-15-16		Initial	LT 1.00	12-3-16	
79-2	16-13907	10-15-16		Initial	2.20	12-5-16	
80	16-13908	10-15-16		Initial	2.32	12-5-16	
81	16-13909	10-15-16		Initial	1.17	12-5-16	
82-1	16-13910	10-15-16		Initial	1.77	12-5-16	
83-2	16-13911	10-15-16		Initial	1.50	12-5-16	
84-3	16-13912	10-15-16		Initial	1.23	12-5-16	
85	16-13913	10-15-16	Slop sink near 131	Initial	23.3	12-5-16	POSTED
86	16-13914	10-15-16		Initial	6.40	3-10-17	
87	16-13915	10-15-16		Initial	2.14		
88-1	16-13916	10-15-16		Initial	3.11	3-10-17	
89	16-13917	10-15-16	Kitchen by walk in Refrigerator	Initial	35.8	3-10-17	POSTED
90	16-13918	10-15-16	Slop sink near 159	Initial	121	3-10-17	POSTED
91	16-13919	10-15-16		Initial	LT 1.00	12-5-16	
92-1	16-13920	10-15-16		Initial	LT 1.00	12-5-16	
93-2	16-13921	10-15-16		Initial	1.43	12-5-16	
94	16-13922	10-15-16		Initial	2.90	12-5-16	
95	16-13923	10-15-16	Slop sink between Rm 27 & 28	Initial	3530	3-10-17	POSTED
96	16-13924	10-15-16		Initial	2.07	12-5-16	
97	16-13925	10-15-16		Initial	5.60	12-5-16	
98-1	16-13926	10-15-16		Initial	1.13	12-5-16	
99-2	16-13927	10-15-16		Initial	3.83	12-5-16	
100-1	16-13928	10-15-16		Initial	1.68	12-5-16	
101-2	16-13929	10-15-16		Initial	3.13	12-5-16	
102-A	16-13930	10-15-16		Initial	1.71	12-5-16	
103-B	16-13931	10-15-16		Initial	LT 1.00	12-5-16	
104	16-13932	10-15-16		Initial	LT 1.00	12-5-16	

OUTLETS SAMPLED	163
OUTLETS ACTIONABLE	30
OUTLETS PENDING	0
POST 9-6-16	104