

SAUNDERS HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-4851	4-16-16	Main Spigot	Initial	228	5-28-16	SHUT OFF
002	16-4852	4-16-16	"	Flushed	35.1	5-28-16	
003	16-4853	4-16-16	Custodial Faucet	Initial	29.2	4-22-16	Replaced & POSTED
004	16-4854	4-16-16	"	Flushed	1.96	4-23-16	
005	16-4855	4-16-16		Initial	LT 1.00	4-22-16	
007	16-4857	4-16-16		Initial	1.38	4-22-16	
009	16-4859	4-16-16		Initial	3.60	4-22-16	
011	16-4861	4-16-16	Faucet Serving Area #1	Initial	30.8	4-22-16	Replaced & POSTED
012	16-4862	4-16-16	"	Flushed	2.29	4-23-16	
013	16-4863	4-16-16		Initial	1.06	4-22-16	
015	16-4865	4-16-16		Initial	4.94	4-22-16	
017	16-4867	4-16-16	Kitchen Steamer	Initial	19.3	5-28-16	SHUT OFF
018	16-4868	4-16-16		Flushed	5.75	5-26-16	
019	16-4869	4-16-16	Faucet Serving Area #2	Initial	1840	5-28-16	POSTED
020	16-4870	4-16-16	"	Flushed	76.1	5-28-16	
021	16-4871	4-16-16		Initial	1.71	4-22-16	
023	16-4873	4-16-16		Initial	LT 1.00	4-22-16	
025	16-4875	4-16-16		Initial	LT 1.00	4-22-16	
027	16-4877	4-16-16		Initial	LT 1.00	4-22-16	
029	16-4879	4-16-16		Initial	LT 1.00	4-22-16	
031	16-4881	4-16-16		Initial	LT 1.00	4-22-16	
032	16-4882	4-16-16		Initial	LT 1.00	4-22-16	
034	16-4884	4-16-16		Initial	10.8	4-22-16	
036	16-4886	4-16-16	Faucet #1 Rm 105	Initial	38.9	4-22-16	SHUT OFF
037	16-4887	4-16-16	"	Flushed	7.30	4-23-16	
038	16-4888	4-16-16		Initial	9.55	4-22-16	
040	16-4890	4-16-16		Initial	6.03	4-22-16	
042	16-4892	4-16-16		Initial	2.91	4-22-16	
044	16-4894	4-16-16		Initial	LT 1.00	4-22-16	
046	16-4896	4-16-16		Initial	2.31	4-22-16	
048	16-4898	4-16-16		Initial	LT 1.00	4-22-16	
050	16-4900	4-16-16		Initial	5.94	4-22-16	
052	16-4902	4-16-16		Initial	2.99	4-22-16	
054	16-4904	4-16-16		Initial	1.05	4-22-16	
056	16-4906	4-16-16		Initial	LT 1.00	4-22-16	
058	16-4908	4-16-16		Initial	LT 1.00	4-22-16	
060	16-4910	4-16-16		Initial	1.47	4-22-16	
062	16-4912	4-16-16		Initial	LT 1.00	4-22-16	
064	16-4914	4-16-16		Initial	1.91	4-22-16	
066	16-4916	4-16-16	Bubbler #2 3rd Fl. Hallway	Initial	29.5	4-23-16	SHUT OFF

SAUNDERS HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
067	16-4917	4-16-16	"	Flushed	12.5	4-24-16	
068	16-4918	4-16-16		Initial	1.32	4-23-16	
070	16-4920	4-16-16		Initial	LT 1.00	4-23-16	
072	16-4922	4-16-16		Initial	5.39	4-23-16	
074	16-4924	4-16-16		Initial	LT 1.00	4-23-16	
075	16-4925	4-16-16		Initial	LT 1.00	4-23-16	
076	16-4926	4-16-16		Initial	LT 1.00	4-23-16	
078	16-4928	4-16-16		Initial	LT 1.00	4-23-16	
080	16-4930	4-16-16		Initial	LT 1.00	4-23-16	
081	16-4931	4-16-16		Initial	LT 1.00	4-23-16	
082	16-4932	4-16-16		Initial	LT 1.00	4-23-16	
084	16-4934	4-16-16		Initial	LT 1.00	4-23-16	
086	16-4936	4-16-16		Initial	LT 1.00	4-23-16	
088	16-4938	4-16-16		Initial	LT 1.00	4-23-16	
089	16-4939	4-16-16		Initial	LT 1.00	4-23-16	
090	16-4940	4-16-16		Initial	LT 1.00	4-23-16	
092	16-4942	4-16-16		Initial	LT 1.00	4-23-16	
094	16-4944	4-16-16		Initial	1.34	4-23-16	
096	16-4946	4-16-16		Initial	2.92	4-23-16	
098	16-4948	4-16-16		Initial	1.62	4-23-16	
100	16-4950	4-16-16		Initial	LT 1.00	4-23-16	
102	16-4952	4-16-16		Initial	3.31	4-23-16	
104	16-4954	4-16-16		Initial	1.33	4-23-16	
106	16-4956	4-16-16		Initial	1.20	4-23-16	
S--01	16-14353	10-22-16		Initial	2.92	1-3-17	
02	16-14354	10-22-16		Initial	2.29	1-3-17	
03	16-14355	10-22-16		Initial	3.44	1-3-17	
04	16-14356	10-22-16		Initial	4.62	1-3-17	
05	16-14357	10-22-16		Initial	12.5	1-3-17	
06	16-14358	10-22-16		Initial	3.38	1-3-17	
07	16-14359	10-22-16	Sink #1 Boy's Bthrm 3rd Flr	Initial	267	1-3-17	POSTED
08	16-14360	10-22-16		Initial	7.17	1-3-17	
09	16-14361	10-22-16	3rd Fl. Boy's BR Sink 3	Initial	19.80	3-14-17	POSTED
10	16-14362	10-22-16		Initial	5.64	1-3-17	
11	16-14363	10-22-16		Initial	2.17	1-3-17	
12	16-14364	10-22-16	Faucet Rm-302	Initial	476	1-3-17	POSTED
13	16-14365	10-22-16		Initial	14.7	1-3-17	
14	16-14366	10-22-16		Initial	13.0	1-3-17	
15	16-14367	10-22-16		Initial	2.17	1-3-17	

SAUNDERS HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
16	16-14368	10-22-16		Initial	4.08	1-3-17	
17	16-14369	10-22-16		Initial	12.9	1-3-17	
18	16-14370	10-22-16		Initial	4.91	1-3-17	
19	16-14371	10-22-16	Faucet #4 Rm-312	Initial	17.5	1-3-17	POSTED
20	16-14372	10-22-16		Initial	13.5	1-3-17	
21	16-14373	10-22-16	Faucet #6 Rm-312	Initial	31.5	1-3-17	POSTED
22	16-14374	10-22-16	Faucet #7 Rm-312	Initial	146	1-5-17	POSTED
23	16-14375	10-22-16	Faucet #8 Rm-312	Initial	18.4	1-5-17	POSTED
24	16-14376	10-22-16		Initial	11.8	1-5-17	
25	16-14377	10-22-16	Faucet #10 Rm 312	Initial	81.7	1-5-17	POSTED
26	16-14378	10-22-16	Faucet #11 Rm-312	Initial	34.3	1-5-17	POSTED
27	16-14379	10-22-16	Faucet #12 Rm-312	Initial	5023	1-5-17	POSTED
28	16-14380	10-22-16		Initial	11.3	1-5-17	
29	16-14381	10-22-16	Faucet Rm-314- Office	Initial	69.4	1-5-17	POSTED
30	16-14382	10-22-16	Faucet#2 Rm 314 Classroom	Initial	41.3	1-5-17	POSTED
31	16-14383	10-22-16	Faucet#3 Rm-314 Classroom	Initial	773	1-5-17	POSTED
32	16-14384	10-22-16	Faucet#4- Rm-314-Classroom	Initial	47.1	1-5-17	POSTED
33	16-14385	10-22-16		Initial	4.47	1-5-17	
34	16-14386	10-22-16		Initial	7.66	1-5-17	
35	16-14387	10-22-16	Faucet#4 Rm-314-Lab Middle	Initial	108	1-5-17	POSTED
36	16-14388	10-22-16	Faucet#6 Rm-314-Lab Middle	Initial	48.2	1-5-17	POSTED
37	16-14389	10-22-16	Faucet#7 Rm-314-Lab Middle	Initial	183	1-5-17	POSTED
38	16-14390	10-22-16		Initial	3.42	1-5-17	
39	16-14391	10-22-16	Rm 314 Faucet 1 by Lab door	Initial	649.00	3-14-17	POSTED
40	16-14392	10-22-16		Initial	6.08	1-5-17	
41	16-14393	10-22-16	Faucet#3 Rm-314-Lab door	Initial	45.1	1-5-17	POSTED
42	16-14394	10-22-16		Initial	5.44	1-9-17	
43	16-14395	10-22-16		Initial	2.74	1-9-17	
44	16-14396	10-22-16	Faucet#8 Rm-314 Lab door	Initial	203	1-9-17	POSTED
45	16-14397	10-22-16		Initial	2.64	1-9-17	
46	16-14398	10-22-16		Initial	4.55	1-9-17	
47	16-14399	10-22-16		Initial	3.63	1-9-17	
48	16-14400	10-22-16		Initial	3.29	1-9-17	
49	16-14401	10-22-16		Initial	1.24	1-9-17	
50	16-14402	10-22-16		Initial	2.18	1-9-17	
51	16-14403	10-22-16		Initial	4.30	1-9-17	

SAUNDERS HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
52	16-14404	10-22-16		Initial	5.30	1-9-17	
53	16-14405	10-22-16		Initial	2.28	1-9-17	
54	16-14406	10-22-16		Initial	1.84	1-9-17	
55	16-14407	10-22-16	Faucet Rm-212-Women's BR	Initial	42.6	1-9-17	POSTED
56	16-14408	10-22-16		Initial	3.35	1-9-17	
57	16-14409	10-22-16	Faucet Slopsink-2nd Floor	Initial	49.8	1-9-17	POSTED
58	16-14410	10-22-16		Initial	LT 1.00	1-9-17	
59	16-14411	10-22-16		Initial	1.88	1-9-17	
60	16-14412	10-22-16		Initial	3.27	1-9-17	
61	16-14413	10-22-16		Initial	2.05	1-9-17	
62	16-14414	10-22-16		Initial	LT 1.00	1-9-17	
63	16-14415	10-22-16		Initial	3.40	1-9-17	
64	16-14416	10-22-16		Initial	6.33	1-10-17	
65	16-14417	10-22-16		Initial	3.49	1-10-17	
66	16-14418	10-22-16		Initial	2.52	1-10-17	
67	16-14419	10-22-16		Initial	5.15	1-10-17	
68	16-14420	10-22-16		Initial	4.63	1-10-17	
69	16-14421	10-22-16		Initial	2.83	1-10-17	
70	16-14422	10-22-16	Faucet RM-103 Bathroom	Initial	328	1-10-17	POSTED
71	16-14423	10-22-16		Initial	1.00	1-10-17	
72	16-14424	10-22-16		Initial	3.01	1-10-17	
73	16-14425	10-22-16		Initial	4.38	1-10-17	
74	16-14426	10-22-16		Initial	7.82	1-10-17	
75	16-14427	10-22-16		Initial	2.21	1-10-17	
76	16-14428	10-22-16		Initial	3.80	1-10-17	
77	16-14429	10-22-16		Initial	3.18	1-10-17	
78	16-14430	10-22-16	Faucet Rm 109A	Initial	15.5	1-10-17	POSTED
79	16-14431	10-22-16	1st Floor Annex Bathroom	Initial	52.7	1-10-17	POSTED
80	16-14432	10-22-16		Initial	5.04	1-10-17	
81	16-14433	10-22-16		Initial	1.66	1-10-17	
82	16-14434	10-22-16		Initial	1.43	1-10-17	
83	16-14435	10-22-16		Initial	2.55	1-10-17	
84	16-14436	10-22-16	Slop Sink Faucet 2nd Fl. Annex	Initial	31.4	3-14-17	POSTED
85	16-14437	10-22-16		Initial	2.79	1-10-17	
86	16-14438	10-22-16		Initial	6.42	1-10-17	
87	16-14439	10-22-16	3rd Fl. West wing Girl's BR Faucet 1	Initial	21.7	3-14-17	POSTED
88	16-14440	10-22-16		Initial	LT 1.00	1-10-17	
89	16-14441	10-22-16		Initial	5.02	1-10-17	

SAUNDERS HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
90	16-14442	10-22-16		Initial	LT 1.00	1-10-17	
91	16-14443	10-22-16		Initial	5.11	1-10-17	
92	16-14444	10-22-16		Initial	1.53	1-10-17	
93	16-14445	10-22-16		Initial	LT 1.00	1-10-17	
94	16-14446	10-22-16		Initial	LT 1.00	1-10-17	
95	16-14447	10-22-16		Initial	5.21	1-10-17	
96	16-14448	10-22-16		Initial	LT 1.00	1-11-17	
97	16-14449	10-22-16		Initial	LT 1.00	1-11-17	
98	16-14450	10-22-16		Initial	LT 1.00	1-11-17	
99	16-14451	10-22-16	Cosmo-Rm 237 Faucet 1	Initial	19.9	1-11-17	Replaced & POSTED
100	16-14452	10-22-16		Initial	3.21	1-11-17	
101	16-14453	10-22-16	Cosmo-Rm 237 Faucet 3	Initial	24.1	1-11-17	POSTED
102	16-14454	10-22-16	Cosmo Rm 237 Faucet 4	Initial	56.60	3-14-17	POSTED
103	16-14455	10-22-16		Initial	2.62	1-11-17	
104	16-14456	10-22-16		Initial	2.06	1-11-17	
105	16-14457	10-22-16		Initial	1.46	1-11-17	
106	16-14458	10-22-16		Initial	1.85	1-19-17	
107	16-14459	10-22-16		Initial	1.12	1-19-17	
108	16-14460	10-22-16		Initial	1.31	1-19-17	
109	16-14461	10-22-16		Initial	1.96	1-19-17	
110	16-14462	10-22-16	Cosmo Rm 238 Faucet 7	Initial	15.1	1-19-17	Replaced & POSTED
111	16-14463	10-22-16		Initial	1.18	1-19-17	
112	16-14464	10-22-16		Initial	1.07	1-19-17	
113	16-14465	10-22-16		Initial	7.26	3-14-17	
114	16-14466	10-22-16		Initial	5.06	1-19-17	
115	16-14467	10-22-16		Initial	3.18	3-14-17	
116	16-14468	10-22-16		Initial	1.32	1-19-17	
117	16-14469	10-22-16		Initial	LT 1.00	1-19-17	
118	16-14470	10-22-16	Faucet Fan Room, westwing 1st Floor	Initial	13700	1-19-17	POSTED
119	16-14471	10-22-16		Initial	6.50	1-19-17	
120	16-14472	10-22-16		Initial	4.03	1-19-17	
121	16-14473	10-22-16	New Faucet Custodian Office	Initial	148	1-19-17	POSTED
122	16-14474	10-22-16		Initial	LT 1.00	1-19-17	
123	16-14475	10-22-16		Initial	2.55	1-19-17	
124	16-14476	10-22-16		Initial	13.3	1-19-17	

SAUNDERS HIGH SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
125	16-14477	10-22-16	Faucet Sink in Boiler Room	Initial	31.7	1-19-17	POSTED
126	16-14478	10-22-16		Initial	12.8	3-14-17	
127	16-14479	10-22-16	Spigot by Loading Dock	Initial	223.0	3-20-17	SHUT OFF
128	16-14480	10-22-16	Spigot 1 West Wing	Initial	72.4	3-20-17	SHUT OFF
129	16-14481	10-22-16	Spigot 2 West Wing	Initial	47.2	3-20-17	SHUT OFF
130	16-14482	10-22-16	Spigot Outside Main Office	Initial	138	1-19-17	SHUT OFF
131	16-14483	10-22-16	Spigot Outside by Siamese Connection	Initial	29.5	1-19-17	SHUT OFF

OUTLETS SAMPLED	188
OUTLETS ACTIONABLE	46
OUTLETS PENDING	0
POST 9-6-16	131

"Replaced & Posted" means actionable faucet was replaced and new faucet is posted until it can be resampled/tested.