

MARTIN LUTHER KING SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
001	16-3982	4-9-16		Initial	2.50	4-13-16	
003	16-3984	4-9-16		Initial	3.12	4-13-16	
005	16-3986	4-9-16		Initial	2.54	4-13-16	
007	16-3988	4-9-16		Initial	2.80	4-13-16	
009	16-3990	4-9-16		Initial	3.19	4-13-16	
011	16-3992	4-9-16		Initial	LT 1.00	4-13-16	
012	16-3993	4-9-16		Initial	LT 1.00	4-13-16	
013	16-3994	4-9-16		Initial	LT 1.00	4-13-16	
015	16-3996	4-9-16		Initial	1.12	4-13-16	
017	16-3998	4-9-16		Initial	LT 1.00	4-13-16	
019	16-4000	4-9-16		Initial	2.24	4-13-16	
021	16-4002	4-9-16	Bubbler Rm 230B	Initial	20.0	4-13-16	SHUT OFF
022	16-4003	4-9-16	"	Flushed	102	4-14-16	
023	16-4004	4-9-16	Faucet Rm 230F	Initial	16.4	4-13-16	SHUT OFF
024	16-4005	4-9-16		Flushed	15.1	4-14-16	
025	16-4006	4-9-16	Bubbler Rm 230F	Initial	283	4-13-16	SHUT OFF
026	16-4007	4-9-16	"	Flushed	19.9	4-14-16	
027	16-4008	4-9-16		Initial	3.27	4-13-16	
029	16-4010	4-9-16		Initial	3.05	4-13-16	
031	16-4012	4-9-16		Initial	LT 1.00	4-13-16	
033	16-4014	4-9-16		Initial	12.2	4-13-16	
035	16-4016	4-9-16		Initial	1.82	4-13-16	
037	16-4018	4-9-16		Initial	4.50	4-13-16	
039	16-4020	4-9-16		Initial	3.80	4-13-16	
041	16-4022	4-9-16		Initial	2.96	4-13-16	
043	16-4024	4-9-16		Initial	3.60	4-13-16	
045	16-4026	4-9-16		Initial	3.20	4-13-16	
047	16-4028	4-9-16		Flushed	LT 1.00	4-13-16	
048	16-4029	4-9-16		Initial	3.10	4-13-16	
049	16-4030	4-9-16		Initial	1.01	4-13-16	
051	16-4032	4-9-16		Initial	LT 1.00	4-13-16	
052	16-4033	4-9-16		Flushed	LT 1.00	4-14-16	
053	16-4034	4-9-16		Initial	3.92	4-13-16	
055	16-4036	4-9-16	Bubbler Rm 103	Initial	65.9	4-13-16	SHUT OFF
056	16-4037	4-9-16	"	Flushed	9.13	4-14-16	

MARTIN LUTHER KING SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
057	16-4038	4-9-16	Main Boiler Rm Spigot	Initial	49100	6-7-16	SHUT OFF
058	16-4039	4-9-16	"	Flushed	2270	6-7-16	
059	16-4040	4-9-16	Faucet Rm 104	Initial	78.8	4-14-16	SHUT OFF
060	16-4041	4-9-16	"	Flushed	149	6-3-16	
061	16-4042	4-9-16		Initial	6.89	6-3-16	
063	16-4044	4-9-16		Initial	3.74	4-14-16	
065	16-4046	4-9-16		Initial	3.68	4-14-16	
067	16-4048	4-9-16		Initial	2.56	4-14-16	
069	16-4050	4-9-16		Initial	5.97	4-14-16	
071	16-4052	4-9-16		Initial	2.81	4-14-16	
073	16-4054	4-9-16		Initial	6.24	4-14-16	
075	16-4056	4-9-16		Initial	2.50	4-14-16	
077	16-4058	4-9-16		Initial	3.72	4-14-16	
080	16-4060	4-9-16		Initial	2.17	4-14-16	
082	16-4062	4-9-16	Bubbler Rm 112	Initial	60.7	4-14-16	SHUT OFF
083	16-4063	4-9-16		Flushed	15.0	4-15-16	
084	16-4064	4-9-16		Initial	LT 1.00	4-14-16	
086	16-4066	4-9-16		Initial	3.27	4-14-16	
088	16-4068	4-9-16	Bubbler Rm 113	Initial	265	4-14-16	SHUT OFF
089	16-4069	4-9-16	"	Flushed	11.2	4-15-16	
090	16-4070	4-9-16		Initial	4.20	4-14-16	
092	16-4072	4-9-16		Initial	2.93	4-14-16	
094	16-4074	4-9-16		Initial	LT 1.00	4-14-16	
096	16-4076	4-9-16		Initial	3.38	4-14-16	
098	16-4078	4-9-16		Initial	3.47	4-14-16	
100	16-4080	4-9-16	Bubbler Rm G07	Initial	139	4-14-16	SHUT OFF
101	16-4081	4-9-16	"	Flushed	8.50	4-15-16	
102	16-4082	4-9-16		Initial	4.05	4-14-16	
104	16-4084	4-9-16		Initial	2.17	4-14-16	
106	16-4086	4-9-16		Initial	14.9	4-14-16	
107	16-4087	4-9-16		Flushed	LT 1.00	4-15-16	
108	16-4088	4-9-16		Initial	8.01	4-14-16	
110	16-4090	4-9-16		Flushed	LT 1.00	4-14-16	
111	16-4091	4-9-16		Initial	2.80	4-14-16	
112	16-4092	4-9-16	Bubbler Rm G-03	Initial	30.3	4-14-16	SHUT OFF
113	16-4093	4-9-16	"	Flushed	1.38	4-15-16	

MARTIN LUTHER KING SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
114	16-4094	4-9-16		Initial	LT 1.00	4-14-16	
116	16-4096	4-9-16		Initial	LT 1.00	4-14-16	
118	16-4098	4-6-16		Initial	LT 1.00	4-14-16	
King-1	16-12963	10-1-16		Initial	1.97	10-26-16	
2	16-12964	10-1-16		Initial	5.59	10-26-16	
3	16-12965	10-1-16		Initial	3.16	10-26-16	
4	16-12966	10-1-16		Initial	6.68	10-26-16	
5	16-12967	10-1-16		Initial	2.45	10-26-16	
6	16-12968	10-1-16		Initial	1.19	10-26-16	
7	16-12969	10-1-16		Initial	5.73	10-26-16	
8	16-12970	10-1-16		Initial	1.29	10-26-16	
9	16-12971	10-1-16		Initial	2.71	10-26-16	
10	16-12972	10-1-16		Initial	1.95	10-26-16	
11	16-12973	10-1-16		Initial	1.92	10-26-16	
12	16-12974	10-1-16		Initial	3.36	10-26-16	
13	16-12975	10-1-16		Initial	3.33	10-26-16	
14	16-12976	10-1-16		Initial	1.39	10-27-16	
15	16-12977	10-1-16		Initial	1.04	10-27-16	
16	16-12978	10-1-16		Initial	1.09	10-27-16	
17	16-12979	10-1-16		Initial	3.77	10-27-16	
18	16-12980	10-1-16		Initial	4.12	10-27-16	
19	16-12981	10-1-16		Initial	8.7	3-7-17	
20	16-12982	10-1-16	Boiler Room Sink	Initial	40.1	3-7-17	POSTED
21	16-12983	10-1-16		Initial	LT 1.00	10-27-16	
22	16-12984	10-1-16		Initial	1.11	10-27-16	
23	16-12985	10-1-16		Initial	LT 1.00	10-27-16	
24	16-12986	10-1-16		Initial	LT 1.00	10-27-16	
25	16-12987	10-1-16		Initial	6.34	10-27-16	
26	16-12988	10-1-16		Initial	1.80	10-27-16	
27	16-12989	10-1-16		Initial	1.41	10-27-16	
28	16-12990	10-1-16		Initial	1.54	10-27-16	
29	16-12991	10-1-16		Initial	LT 1.00	10-27-16	
30	16-12992	10-1-16		Initial	LT 1.00	10-27-16	
31	16-12993	10-1-16		Initial	LT 1.00	10-27-16	
32	16-12994	10-1-16		Initial	LT 1.00	10-27-16	
33	16-12995	10-1-16		Initial	LT 1.00	10-27-16	

MARTIN LUTHER KING SCHOOL

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
34	16-12996	10-1-16		Initial	2.04	10-27-16	
35	16-12997	10-1-16		Initial	2.23	10-27-16	
36	16-12998	10-1-16		Initial	1.74	10-27-16	
37	16-12999	10-1-16		Initial	4.25	10-27-16	
38	16-13000	10-1-16		Initial	9.02	3-7-17	
39	16-13001	10-1-16		Initial	2.86	10-27-16	
40	16-13002	10-1-16		Initial	1.68	10-27-16	
41	16-13003	10-1-16		Initial	1.35	10-27-16	
42	16-13004	10-1-16		Initial	12.6	10-27-16	
43	16-13005	10-1-16		Initial	3.42	10-27-16	
44	16-13006	10-1-16	Hose Bib Front	Initial	62.40	3-7-17	SHUT OFF

OUTLETS SAMPLED	104
OUTLETS ACTIONABLE	12
OUTLETS PENDING	0
POST 9-6-16	44