

CEDAR PLACE

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
01	16-5634	4-27-16		Initial	3.46	5-2-16	
03	16-5636	4-27-16		Initial	10.5	5-24-16	
05	16-5638	4-27-16	Serving Area #2	Initial	16.2	5-24-16	SHUT OFF
07	16-5640	4-27-16		Initial	2.36	5-2-16	
09	16-5642	4-27-16		Initial	2.40	5-2-16	
11	16-5645	4-27-16		Initial	LT 1.00	5-2-16	
13	16-5647	4-27-16		Initial	LT 1.00	5-2-16	
15	16-5649	4-27-16		Initial	1.02	5-24-16	
CP-1	16-13079	10-1-16		Initial	2.16	11-4-16	
2	16-13080	10-1-16		Initial	2.31	11-4-16	
3	16-13081	10-1-16		Initial	LT 1.00	11-4-16	
4	16-13082	10-1-16		Initial	LT 1.00	11-4-16	
5	16-13083	10-1-16		Initial	1.18	11-4-16	
6	16-13084	10-1-16		Initial	LT 1.00	11-4-16	
7	16-13085	10-1-16		Initial	LT 1.00	11-4-16	
8	16-13086	10-1-16		Initial	LT 1.00	11-4-16	
9	16-13087	10-1-16		Initial	1.13	11-4-16	
10	16-13088	10-1-16		Initial	LT 1.00	11-4-16	
11	16-13089	10-1-16		Initial	11.0	3-7-17	
12	16-13090	10-1-16		Initial	LT 1.00	11-4-16	
13	16-13091	10-1-16		Initial	LT 1.00	11-4-16	
14	16-13092	10-1-16		Initial	LT 1.00	11-4-16	
15	16-13093	10-1-16		Initial	1.20	11-4-16	
16	16-13094	10-1-16		Initial	LT 1.00	11-8-16	
17	16-13095	10-1-16		Initial	1.58	11-4-16	
18	16-13096	10-1-16		Initial	LT 1.00	11-4-16	
19	16-13097	10-1-16		Initial	LT 1.00	11-4-16	
20	16-13098	10-1-16		Initial	LT 1.00	11-4-16	

CEDAR PLACE

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
21	16-13099	10-1-16		Initial	1.18	11-4-16	
22	16-13100	10-1-16		Initial	LT 1.00	11-4-16	
23	16-13101	10-1-16		Initial	LT 1.00	11-4-16	
24	16-13102	10-1-16		Initial	LT 1.00	11-4-16	
25	16-13103	10-1-16		Initial	LT 1.00	11-4-16	
26	16-13104	10-1-16		Initial	LT 1.00	11-4-16	
27	16-13105	10-1-16		Initial	LT 1.00	11-4-16	
28	16-13106	10-1-16		Initial	1.08	11-4-16	
29	16-13107	10-1-16		Initial	LT 1.00	11-4-16	
30	16-13108	10-1-16		Initial	LT 1.00	11-4-16	
31	16-13109	10-1-16		Initial	LT 1.00	11-4-16	
32	16-13110	10-1-16		Initial	1.65	11-4-16	
33	16-13111	10-1-16		Initial	LT 1.00	11-4-16	
34	16-13112	10-1-16		Initial	LT 1.00	11-4-16	
35	16-13113	10-1-16		Initial	LT 1.00	11-4-16	
36	16-13114	10-1-16		Initial	LT 1.00	11-4-16	
37	16-13115	10-1-16		Initial	LT 1.00	11-4-16	
38	16-13116	10-1-16		Initial	LT 1.00	11-4-16	
39	16-13117	10-1-16		Initial	LT 1.00	11-4-16	
40	16-13118	10-1-16		Initial	LT 1.00	11-4-16	
41	16-13119	10-1-16		Initial	LT 1.00	11-4-16	
42	16-13120	10-1-16		Initial	LT 1.00	11-4-16	
43	16-13121	10-1-16		Initial	LT 1.00	11-8-16	
44	16-13122	10-1-16		Initial	LT 1.00	11-8-16	
45	16-13123	10-1-16		Initial	LT 1.00	11-8-16	
46	16-13124	10-1-16		Initial	LT 1.00	11-8-16	
47	16-13125	10-1-16		Initial	LT 1.00	11-8-16	

CEDAR PLACE

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
48	16-13126	10-1-16		Initial	1.01	11-8-16	
49	16-13127	10-1-16		Initial	1.20	11-8-16	
50	16-13128	10-1-16		Initial	2.36	11-8-16	
51	16-13129	10-1-16		Initial	LT 1.00	11-8-16	
52	16-13130	10-1-16		Initial	LT 1.00	11-8-16	
53	16-13131	10-1-16		Initial	LT 1.00	11-8-16	
54	16-13132	10-1-16		Initial	1.08	11-8-16	
55	16-13133	10-1-16		Initial	LT 1.00	11-8-16	
56	16-13134	10-1-16		Initial	5.96	11-8-16	
57	16-13135	10-1-16		Initial	LT 1.00	11-8-16	
58	16-13136	10-1-16		Initial	LT 1.00	11-8-16	
59	16-13137	10-1-16		Initial	LT 1.00	11-8-16	
60	16-13138	10-1-16		Initial	LT 1.00	11-8-16	
61	16-13139	10-1-16		Initial	LT 1.00	11-8-16	
62	16-13140	10-1-16		Initial	LT 1.00	11-8-16	
63	16-13141	10-1-16		Initial	14.30	3-7-17	
64	16-13142	10-1-16		Initial	LT 1.00	11-8-16	
65	16-13143	10-1-16		Initial	LT 1.00	11-8-16	
66	16-13144	10-1-16		Initial	1.75	11-8-16	
67	16-13145	10-1-16	Faucet 3 Kitchen serving area	Initial	163	11-8-16	SHUT OFF
68	16-13146	10-1-16		Initial	3.11	3-7-17	
69	16-13147	10-1-16		Initial	1.07	11-8-16	
70	16-13148	10-1-16		Initial	5.18	11-8-16	
71	16-13149	10-1-16	Faucet #3 Kitchen	Initial	123.00	3-20-17	POSTED
72	16-13150	10-1-16		Initial	1.94	11-8-16	
73	16-13151	10-1-16	Faucet #5 Kitchen	Initial	124.00	3-20-17	POSTED
74	16-13152	10-1-16		Initial	2.90	11-8-16	
75	16-13153	10-1-16		Initial	8.18	3-20-17	

CEDAR PLACE

City of Yonkers, Bureau of Water's Laboratory

NY Lab ID No. 10176

Method of Analysis EPA Method 200.8 Rev. 5.4

BOE ID#	Lab ID #	Date of Collection	Sample Description	Initial / Flushed	Lead Concentration ug/L	Date of Analysis	ACTION TAKEN
76	16-13154	10-1-16		Initial	LT 1.00	11-8-16	
77	16-13155	10-1-16		Initial	5.02	3-20-17	
78	16-13156	10-1-16		Initial	2.80	11-8-16	
79	16-13157	10-1-16		Initial	3.01	11-8-16	
80	16-13158	10-1-16		Initial	5.58	11-8-16	
81	16-13159	10-1-16		Initial	5.38	11-8-16	
82	16-13160	10-1-16	Dishwashing Rm. Faucet #2 Sprayer	Initial	48.30	3-20-17	POSTED
83	16-13161	10-1-16		Initial	LT 1.00	11-8-16	
84	16-13162	10-1-16	Faucet 1 slop sink by loading dock	Initial	31.1	11-8-16	POSTED
85	16-13163	10-1-16		Initial	LT 1.00	11-8-16	

OUTLETS SAMPLED	93
OUTLETS ACTIONABLE	6
OUTLETS PENDING	0
POST 9-6-16	85